

CORK, Ireland

WMO: 039550

Lat: 51.850N

Lon: 8.483W

Elev: 502

StdP: 14.43

Time Zone: 1.00 (IRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.8	32.0	24.5	19.0	32.8	27.1	21.5	35.0	34.4	45.0	31.3	46.1	10.1	330	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	70.3	62.1	67.6	60.6	65.5	59.4	63.9	67.8	62.5	65.3	61.2	63.7	9.4	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.5	86.2	64.9	61.2	82.4	63.5	60.2	79.2	62.4	29.3	68.0	28.3	65.3	27.5	63.7	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
28.5	25.1	22.3	DB	27.1	74.5	2.7	2.7	25.2	76.4	23.6	78.0	22.1	79.5	20.2	81.5
			WB	26.1	66.4	2.5	1.6	24.3	67.5	22.9	68.4	21.5	69.3	19.7	70.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.0	42.6	42.6	44.2	47.2	51.6	56.2	59.2	58.9	56.0	51.5	46.2	43.4
	DBStd	7.35	4.59	4.30	4.22	3.95	3.98	3.65	3.41	3.08	3.27	3.95	4.61	4.96
	HDD50	1120	232	208	184	99	28	1	0	0	1	30	128	209
	HDD65	5481	696	627	645	534	417	265	184	191	270	418	563	671
	CDD50	1120	1	1	4	16	76	187	284	276	181	76	15	3
	CDD65	6	0	0	0	0	0	1	3	2	0	0	0	0
	CDH74	13	0	0	0	0	0	3	5	5	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	11.0	12.3	12.3	11.8	11.1	10.7	10.0	9.4	9.7	10.1	11.1	11.3	12.2
Precipitation	PrecAvg	47.8	5.5	4.0	3.7	3.0	3.3	2.9	3.1	3.5	3.8	5.1	4.6	5.2
	PrecMax	61.5	13.5	12.0	9.2	9.3	8.5	9.0	8.0	9.1	8.5	9.4	9.0	15.8
	PrecMin	35.7	1.3	0.2	0.2	0.6	0.2	0.4	0.5	0.5	0.2	1.1	1.2	0.9
	PrecStd	6.0	2.6	2.5	1.9	1.8	1.8	1.6	1.6	2.1	2.0	2.4	2.1	2.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.7	53.9	57.2	62.1	68.4	73.3	74.4	73.5	68.1	62.1	57.4	54.5
		MCWB	52.4	51.7	52.0	54.0	59.0	62.5	64.4	65.1	62.3	58.5	56.4	53.9
	2%	DB	52.1	52.0	53.8	57.9	63.9	68.4	70.6	68.9	65.0	60.1	55.8	53.2
		MCWB	51.1	50.5	50.0	51.9	56.9	59.8	62.5	62.1	59.7	58.0	54.7	52.6
	5%	DB	51.0	50.7	51.9	55.4	60.6	65.3	67.7	66.3	63.1	58.7	54.5	52.1
		MCWB	50.1	49.4	49.0	50.1	54.5	58.3	60.8	60.3	58.6	57.0	53.4	51.4
	10%	DB	49.7	49.3	50.4	53.3	58.0	62.8	65.3	64.4	61.6	57.6	53.2	50.8
		MCWB	48.8	48.0	48.1	49.2	52.9	56.8	59.6	59.2	58.0	56.1	52.1	50.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.1	52.6	53.1	55.6	60.7	63.8	66.2	65.8	63.8	60.9	56.9	54.1
		MCDB	53.3	53.2	55.3	59.8	66.3	70.7	72.2	70.6	66.2	61.3	57.0	54.2
	2%	WB	51.5	51.1	51.3	53.2	57.8	61.2	63.9	63.8	61.8	59.0	55.2	52.9
		MCDB	51.8	51.7	52.7	56.0	62.4	66.5	68.1	67.1	63.4	59.4	55.6	53.1
	5%	WB	50.3	49.7	50.1	51.7	55.8	59.4	62.4	62.4	60.4	57.7	53.8	51.7
		MCDB	50.7	50.3	51.2	53.8	59.2	63.5	65.6	64.5	61.8	58.2	54.2	52.0
	10%	WB	49.0	48.4	48.8	50.3	54.2	58.0	61.0	61.1	59.2	56.5	52.4	50.3
		MCDB	49.6	49.3	50.1	52.3	56.9	61.4	63.9	63.0	60.7	57.2	53.1	50.8
Mean Daily Temperature Range	5% DB	MDBR	8.1	8.7	9.8	10.9	11.3	11.5	11.2	11.1	10.4	9.0	8.4	7.8
		MCDBR	9.0	9.0	10.6	13.0	14.4	14.9	14.1	13.0	11.8	9.2	8.1	8.6
		MCWBR	9.2	8.3	8.1	8.5	8.8	8.8	7.9	7.7	7.9	7.8	7.9	9.0
	5% WB	MCDBR	9.0	8.8	9.7	11.1	12.9	12.7	11.9	10.8	10.1	8.3	7.8	8.5
		MCWBR	9.4	8.7	8.5	8.3	8.7	8.5	7.9	7.9	8.4	8.1	8.1	9.1
Clear-Sky Solar Irradiance	taub	0.333	0.342	0.365	0.370	0.381	0.365	0.371	0.353	0.351	0.343	0.326	0.324	
	taud	2.294	2.355	2.314	2.338	2.338	2.411	2.398	2.460	2.465	2.445	2.361	2.260	
	Ebn at Noon	207	245	261	275	277	282	278	278	265	242	210	187	
	Edh at Noon	21	26	33	36	37	35	35	31	28	23	19	18	
All-Sky Solar Radiation	RadAvg	245	463	823	1314	1594	1728	1568	1336	971	561	306	186	
	RadStd	24	36	81	97	92	141	128	79	74	52	23	23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page