

CORK, Ireland

WMO: 039550

Lat: 51.850N

Lon: 8.483W

Elev: 153

StdP: 99.50

Time Zone: 1.00 (IRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.2	0.0	-4.2	2.7	0.5	-2.7	3.1	1.7	15.4	7.2	14.0	7.8	4.5	330	0.665

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	21.3	16.7	19.8	15.9	18.6	15.2	17.7	19.9	16.9	18.5	16.2	17.6	4.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	12.3	18.3	16.2	11.8	17.5	15.6	11.3	16.9	50.4	20.0	48.0	18.5	46.0	17.6	20.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	11.2	10.0	DB	-2.7	23.6	1.5	1.5	-3.8	24.7	-4.7	25.6	-5.5	26.4	-6.6	27.5	(4)
(5)			WB	-3.3	19.1	1.4	0.9	-4.3	19.7	-5.1	20.2	-5.8	20.7	-6.8	21.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	5.9	5.9	6.8	8.5	10.9	13.4	15.1	15.0	13.3	10.8	7.9	6.3	(6)	
	DBStd	4.08	2.55	2.39	2.35	2.19	2.21	2.03	1.90	1.71	1.81	2.19	2.56	2.76	(7)	
	HDD10.0	622	129	116	102	55	16	1	0	0	1	17	71	116	(8)	
	HDD18.3	3045	387	348	358	297	232	147	102	106	150	232	313	373	(9)	
	CDD10.0	622	1	1	2	9	42	104	158	153	101	42	8	2	(10)	
	CDD18.3	3	0	0	0	0	0	1	2	1	0	0	0	0	(11)	
	CDH23.3	7	0	0	0	0	0	2	3	3	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	4.9	5.5	5.5	5.3	5.0	4.8	4.5	4.2	4.4	4.5	5.0	5.0	5.5	(14)	
(15) Precipitation	PrecAvg	1213	139	102	94	77	84	74	78	90	97	129	118	132	(15)	
	PrecMax	1562	343	304	234	235	216	228	204	231	216	240	228	402	(16)	
	PrecMin	907	33	5	4	16	4	10	12	12	5	28	31	23	(17)	
	PrecStd	153	65	63	49	45	45	41	41	53	50	62	54	68	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	12.1	14.0	16.7	20.2	22.9	23.6	23.0	20.1	16.7	14.1	12.5	(19)	
		MCWB	11.3	11.0	11.1	12.2	15.0	16.9	18.0	18.4	16.9	14.7	13.6	12.2	(20)	
	2%	DB	11.2	11.1	12.1	14.4	17.7	20.2	21.5	20.5	18.4	15.6	13.2	11.8	(21)	
		MCWB	10.6	10.3	10.0	11.1	13.8	15.4	17.0	16.7	15.4	14.5	12.6	11.4	(22)	
	5%	DB	10.6	10.4	11.1	13.0	15.9	18.5	19.8	19.0	17.3	14.9	12.5	11.2	(23)	
		MCWB	10.0	9.7	9.4	10.1	12.5	14.6	16.0	15.7	14.8	13.9	11.9	10.8	(24)	
	10%	DB	9.8	9.6	10.2	11.8	14.5	17.1	18.5	18.0	16.4	14.2	11.8	10.5	(25)	
		MCWB	9.3	8.9	9.0	9.6	11.6	13.8	15.3	15.1	14.5	13.4	11.2	10.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.5	11.7	13.1	16.0	17.6	19.0	18.8	17.7	16.0	13.8	12.3	(27)	
		MCDB	11.8	11.8	12.9	15.4	19.1	21.5	22.4	21.4	19.0	16.3	13.9	12.4	(28)	
	2%	WB	10.8	10.6	10.7	11.8	14.4	16.2	17.7	17.7	16.5	15.0	12.9	11.6	(29)	
		MCDB	11.0	10.9	11.5	13.3	16.9	19.2	20.0	19.5	17.5	15.2	13.1	11.7	(30)	
	5%	WB	10.2	9.8	10.0	11.0	13.2	15.2	16.9	16.9	15.8	14.3	12.1	11.0	(31)	
		MCDB	10.4	10.2	10.6	12.1	15.1	17.5	18.7	18.0	16.6	14.6	12.4	11.1	(32)	
	10%	WB	9.5	9.1	9.4	10.2	12.3	14.5	16.1	16.2	15.1	13.6	11.3	10.2	(33)	
		MCDB	9.8	9.6	10.0	11.3	13.8	16.3	17.7	17.2	15.9	14.0	11.7	10.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.5	4.8	5.5	6.1	6.3	6.4	6.2	6.2	5.8	5.0	4.6	4.3	(35)	
		MCDBR	5.0	5.0	5.9	7.2	8.0	8.3	7.8	7.2	6.6	5.1	4.5	4.8	(36)	
	5% WB	MCWBR	5.1	4.6	4.5	4.7	4.9	4.9	4.4	4.3	4.4	4.3	4.4	5.0	(37)	
		MCWBR	5.0	4.9	5.4	6.2	7.2	7.1	6.6	6.0	5.6	4.6	4.3	4.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.333	0.342	0.365	0.370	0.381	0.365	0.371	0.353	0.351	0.343	0.326	0.324	(40)	
		taud	2.294	2.355	2.314	2.338	2.338	2.411	2.398	2.460	2.465	2.445	2.361	2.260	(41)	
	Ebn at Noon		653	771	823	867	872	889	876	876	836	763	662	588	(42)	
		Edh at Noon	66	82	103	112	118	111	111	99	88	74	61	58	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.77	1.46	2.60	4.14	5.03	5.45	4.94	4.21	3.06	1.77	0.96	0.59	(44)	
	RadStd		0.08	0.11	0.26	0.31	0.29	0.44	0.40	0.25	0.23	0.16	0.07	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page