

ROSSLARE, Ireland

WMO: 039570

Lat: 52.250N

Lon: 6.333W

Elev: 82

StdP: 14.65

Time Zone: 1.00 (IRL)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	33.8	35.7	27.0	21.0	37.7	28.8	22.8	38.1	38.0	43.5	33.6	43.7	9.9	270	0.647

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.0	68.3	62.3	66.6	61.4	65.1	60.5	64.0	67.0	62.7	65.2	61.7	64.0	9.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.6	85.2	65.2	61.5	81.9	64.0	60.6	79.1	63.1	29.2	67.3	28.3	65.2	27.6	64.0	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
30.1	27.3	23.4	30.7	72.7	2.0	2.3	29.2	74.3	28.1	75.7	26.9	77.0	25.5	78.6
			28.6	66.6	1.7	1.6	27.4	67.7	26.4	68.6	25.4	69.5	24.1	70.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	44.8	44.4	45.9	48.4	52.3	56.8	60.1	60.8	58.3	53.8	48.9	45.7	(6)
	DBStd	6.81	3.88	3.64	3.53	3.37	3.05	2.76	2.57	2.66	2.85	3.75	4.18	4.37	(7)
	HDD50	757	165	157	131	67	13	0	0	0	0	12	70	142	(8)
	HDD65	4854	627	576	592	499	395	247	153	134	202	348	483	598	(9)
	CDD50	1382	3	2	4	18	83	204	312	335	248	129	36	8	(10)
	CDD65	4	0	0	0	0	0	1	0	3	0	0	0	0	(11)
	CDH74	2	0	0	0	0	0	1	0	1	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	11.3	13.2	12.6	11.7	11.5	11.5	10.1	9.3	9.3	10.8	12.1	11.4	12.7	(14)
(15) Precipitation	PrecAvg	34.5	3.5	2.7	2.6	2.3	2.2	2.0	2.2	2.8	3.0	4.0	4.0	3.7	(15)
	PrecMax	45.5	8.0	5.4	7.6	7.2	5.8	5.0	5.0	10.3	6.5	11.1	9.0	7.9	(16)
	PrecMin	25.6	0.7	0.1	0.1	0.0	0.1	0.0	0.3	0.1	0.0	0.0	1.3	1.2	(17)
	PrecStd	3.9	1.7	1.4	1.4	1.3	1.4	1.3	1.1	1.7	1.7	2.3	1.9	1.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.9	53.6	55.1	58.8	63.2	69.2	70.1	72.3	67.2	62.8	58.3	55.4	(19)
		MCWB	51.7	51.1	51.4	53.0	57.4	61.2	63.3	65.3	62.0	58.3	56.4	53.9	(20)
	2%	DB	52.8	52.0	53.1	56.0	60.4	65.1	67.8	68.8	65.3	60.9	57.0	54.2	(21)
		MCWB	50.9	50.0	50.0	51.7	55.6	59.4	62.0	63.1	60.8	57.9	55.3	52.7	(22)
	5%	DB	51.7	50.9	51.8	54.5	58.5	63.0	66.2	66.9	63.9	59.8	55.8	53.2	(23)
		MCWB	50.1	49.0	49.2	51.0	54.3	58.1	61.0	61.9	59.9	57.3	54.1	51.7	(24)
	10%	DB	50.8	50.0	50.8	53.3	56.8	61.4	64.6	65.5	62.6	59.1	55.0	52.1	(25)
		MCWB	49.3	48.2	48.6	50.1	53.1	57.2	60.1	61.0	59.2	56.9	53.2	50.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.3	52.1	52.3	55.0	58.7	62.9	64.8	66.6	63.3	60.1	57.3	54.6	(27)
		MCDB	53.1	52.7	53.8	56.7	61.7	67.6	68.5	70.7	65.4	61.2	57.7	54.9	(28)
	2%	WB	51.5	50.7	50.9	53.2	56.5	60.5	63.3	64.6	62.1	59.2	55.9	53.5	(29)
		MCDB	52.3	51.4	52.1	55.2	59.3	63.6	66.3	67.5	63.9	60.2	56.4	54.0	(30)
	5%	WB	50.4	49.8	50.2	51.7	55.2	59.2	62.2	63.2	61.1	58.4	54.9	52.1	(31)
		MCDB	51.3	50.6	51.2	53.8	57.7	61.9	64.8	65.6	62.8	59.5	55.7	52.9	(32)
	10%	WB	49.7	48.6	49.4	50.5	53.9	58.2	61.1	62.1	60.3	57.4	53.6	51.0	(33)
		MCDB	50.7	49.7	50.5	52.4	55.9	60.7	63.6	64.4	62.1	58.7	54.8	52.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.3	7.2	8.0	7.9	8.5	8.6	9.0	8.1	7.5	7.4	6.6	(35)
		MCDBR	7.0	7.8	8.0	9.1	10.1	10.7	10.6	10.7	8.8	7.4	7.0	6.4	(36)
	5% WB	MCWBR	7.3	7.5	6.5	6.5	7.0	6.8	6.7	7.0	6.6	6.4	7.1	7.3	(37)
		MCWBR	7.0	7.2	7.2	8.3	8.7	9.3	9.3	9.5	7.8	7.0	6.3	6.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.335	0.346	0.373	0.383	0.392	0.378	0.385	0.366	0.361	0.353	0.329	0.323	(40)
		taud	2.311	2.371	2.322	2.330	2.352	2.420	2.406	2.473	2.477	2.444	2.384	2.291	(41)
	Ebn at Noon		205	242	258	270	273	278	273	273	261	237	207	186	(42)
		Edh at Noon	20	25	32	36	37	35	35	31	28	23	19	18	(43)
(44) All-Sky Solar Radiation	RadAvg		239	464	826	1298	1622	1744	1594	1346	986	558	299	183	(44)
	RadStd		23	36	83	109	105	148	138	86	68	49	28	23	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page