

ROSSLARE, Ireland

WMO: 039570

Lat: 52.250N

Lon: 6.333W

Elev: 25

StdP: 101.03

Time Zone: 1.00 (IRL)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	1.0	2.0	-2.8	3.0	3.1	-1.8	3.3	3.4	17.0	6.4	15.0	6.5	4.4	270	0.647

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	20.2	16.9	19.2	16.3	18.4	15.8	17.8	19.4	17.1	18.4	16.5	17.8	4.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	12.2	18.5	16.4	11.7	17.8	15.9	11.3	17.3	50.0	19.6	47.9	18.5	46.2	17.8	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.5	12.2	10.5	-0.7	22.6	1.1	1.3	-1.5	23.5	-2.2	24.3	-2.8	25.0	-3.6	25.9		
(5)			-1.9	19.2	1.0	0.9	-2.6	19.9	-3.1	20.4	-3.7	20.8	-4.4	21.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	7.1	6.9	7.7	9.1	11.3	13.8	15.6	16.0	14.6	12.1	9.4	7.6
	DBStd	3.79	2.15	2.02	1.96	1.87	1.70	1.53	1.43	1.48	1.59	2.08	2.32	2.43
	HDD10.0	421	92	87	73	37	7	0	0	0	0	7	39	79
	HDD18.3	2697	348	320	329	277	219	137	85	74	112	193	268	332
	CDD10.0	768	2	1	2	10	46	113	173	186	138	72	20	4
	CDD18.3	2	0	0	0	0	0	1	0	2	0	0	0	0
	CDH23.3	1	0	0	0	0	0	1	0	1	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.1	5.9	5.6	5.2	5.1	5.1	4.5	4.2	4.2	4.8	5.4	5.1	5.7
Precipitation	PrecAvg	877	90	69	66	59	56	50	55	70	75	101	102	93
	PrecMax	1156	204	137	194	183	147	127	127	261	165	283	229	200
	PrecMin	649	18	3	3	0	2	0	7	3	0	0	34	30
	PrecStd	100	43	36	35	33	36	32	29	44	42	59	47	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	12.0	12.9	14.9	17.4	20.7	21.2	22.4	19.6	17.1	14.6	13.0
		MCWB	10.9	10.6	10.8	11.7	14.1	16.2	17.4	18.5	16.7	14.6	13.5	12.2
	2%	DB	11.5	11.1	11.7	13.3	15.8	18.4	19.9	20.4	18.5	16.0	13.9	12.3
		MCWB	10.5	10.0	10.0	10.9	13.1	15.2	16.6	17.3	16.0	14.4	12.9	11.5
	5%	DB	11.0	10.5	11.0	12.5	14.7	17.2	19.0	19.4	17.7	15.5	13.2	11.8
		MCWB	10.0	9.4	9.5	10.6	12.4	14.5	16.1	16.6	15.5	14.1	12.3	11.0
	10%	DB	10.4	10.0	10.4	11.8	13.8	16.3	18.1	18.6	17.0	15.0	12.8	11.2
		MCWB	9.6	9.0	9.2	10.0	11.7	14.0	15.6	16.1	15.1	13.8	11.8	10.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	11.2	11.3	12.8	14.8	17.2	18.2	19.2	17.4	15.6	14.1	12.6
		MCDB	11.7	11.5	12.1	13.7	16.5	19.8	20.3	21.5	18.6	16.2	14.3	12.7
	2%	WB	10.8	10.4	10.5	11.8	13.6	15.9	17.4	18.1	16.7	15.1	13.3	11.9
		MCDB	11.3	10.8	11.2	12.9	15.2	17.6	19.0	19.7	17.7	15.6	13.6	12.2
	5%	WB	10.2	9.9	10.1	10.9	12.9	15.1	16.8	17.3	16.2	14.6	12.7	11.2
		MCDB	10.7	10.3	10.7	12.1	14.3	16.6	18.2	18.7	17.1	15.3	13.2	11.6
	10%	WB	9.9	9.2	9.7	10.3	12.2	14.6	16.1	16.7	15.7	14.1	12.0	10.5
		MCDB	10.4	9.8	10.3	11.3	13.3	15.9	17.6	18.0	16.7	14.8	12.7	11.1
Mean Daily Temperature Range	5% DB	MDBR	3.6	4.1	4.0	4.5	4.4	4.7	4.8	5.0	4.5	4.2	4.1	3.7
		MCDBR	3.9	4.4	4.5	5.0	5.6	5.9	5.9	6.0	4.9	4.1	3.9	3.6
		MCWBR	4.1	4.1	3.6	3.6	3.9	3.8	3.7	3.9	3.6	3.6	3.9	4.0
	5% WB	MCDBR	3.9	4.0	4.0	4.6	4.8	5.2	5.2	5.3	4.3	3.9	3.5	3.7
		MCWBR	4.2	4.2	3.7	3.6	3.7	3.7	3.7	3.9	3.7	3.9	3.9	4.4
Clear-Sky Solar Irradiance	taub	0.335	0.346	0.373	0.383	0.392	0.378	0.385	0.366	0.361	0.353	0.329	0.323	
	taud	2.311	2.371	2.322	2.330	2.352	2.420	2.406	2.473	2.477	2.444	2.384	2.291	
	Ebn at Noon	645	763	812	851	861	875	862	862	822	748	653	586	
	Edh at Noon	64	80	102	113	116	110	110	97	87	74	59	56	
All-Sky Solar Radiation	RadAvg	0.76	1.46	2.60	4.09	5.11	5.50	5.03	4.24	3.11	1.76	0.94	0.58	
	RadStd	0.07	0.11	0.26	0.34	0.33	0.47	0.44	0.27	0.21	0.15	0.09	0.07	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page