

STYKKISHOLMUR, Iceland

WMO: 040130

Lat: 65.0740N

Lon: 22.7339W

Elev: 8

StdP: 101.23

Time Zone: 0.00 (E00)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.9	-6.3	-13.1	1.2	-7.1	-11.2	1.4	-5.9	22.5	3.4	18.7	2.5	5.3	20	0.818

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	15.6	12.5	14.6	11.9	13.8	11.4	13.1	14.9	12.4	14.1	11.7	13.4	4.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	8.8	14.1	11.3	8.3	13.4	10.6	8.0	12.8	37.1	15.0	35.1	14.2	33.5	13.5	19.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	12.7	12.0	-10.2	18.3	1.7	1.4	-11.4	19.3	-12.4	20.1	-13.3	20.9	-14.5	21.9
			-11.1	14.6	1.1	1.7	-11.9	15.8	-12.6	16.8	-13.2	17.8	-14.0	19.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	0.4	0.3	0.9	3.2	5.9	9.5	11.1	10.7	8.3	4.7	2.0	0.6
	DBStd	4.90	3.24	3.46	3.15	2.98	2.66	1.90	1.69	1.75	2.53	3.00	3.21	3.59
	HDD10.0	1993	297	272	281	204	131	32	8	12	61	166	241	290
	HDD18.3	4930	556	505	539	454	387	266	226	236	301	423	491	548
	CDD10.0	105	0	0	0	1	2	16	41	34	11	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.4	6.2	6.4	6.1	5.5	5.1	4.4	4.2	4.2	5.1	5.7	6.1	6.1
Precipitation	PrecAvg	705	70	75	70	48	36	39	39	50	57	74	69	72
	PrecMax	1035	212	176	197	103	82	80	100	143	103	204	267	152
	PrecMin	491	13	1	2	9	5	2	6	8	16	10	18	18
	PrecStd	150	43	39	40	26	23	19	20	29	20	40	42	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	8.6	9.4	12.4	14.0	16.2	17.5	16.6	15.6	12.6	10.3	9.9
		MCWB	7.6	7.2	7.5	8.9	10.1	11.8	13.9	14.2	12.5	10.2	8.7	8.2
	2%	DB	7.7	7.6	8.1	9.8	11.9	14.4	15.9	15.1	13.6	11.1	9.0	8.5
		MCWB	6.4	6.2	6.7	7.3	8.7	10.9	12.8	12.5	11.4	9.0	7.5	7.3
	5%	DB	6.5	6.6	7.0	8.6	10.7	13.4	14.8	14.2	12.6	10.1	7.7	7.3
		MCWB	5.2	5.2	5.6	6.4	8.0	10.5	12.0	12.0	10.7	8.4	6.1	6.1
	10%	DB	5.0	5.2	5.5	7.5	9.7	12.6	13.9	13.5	11.8	9.1	6.3	6.0
		MCWB	3.6	3.9	4.0	5.5	7.4	10.0	11.5	11.4	10.0	7.6	4.9	4.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	7.8	7.9	9.2	10.4	12.6	14.3	14.8	12.8	10.7	9.0	8.5
		MCDB	8.7	8.4	8.9	11.9	13.3	14.9	16.8	16.1	14.8	12.1	10.1	9.3
	2%	WB	6.6	6.3	6.7	7.6	9.2	11.6	13.2	13.2	11.8	9.3	7.6	7.3
		MCDB	7.5	7.4	8.0	9.5	11.3	13.6	15.3	14.4	13.2	10.7	8.8	8.4
	5%	WB	5.3	5.3	5.6	6.6	8.3	10.8	12.4	12.4	11.0	8.5	6.2	6.2
		MCDB	6.5	6.6	6.9	8.4	10.3	12.9	14.3	13.7	12.4	9.9	7.5	7.3
	10%	WB	3.7	4.0	4.1	5.6	7.6	10.2	11.7	11.7	10.2	7.6	5.0	4.7
		MCDB	4.8	5.1	5.4	7.3	9.5	12.2	13.5	13.1	11.6	9.0	6.2	5.9
Mean Daily Temperature Range	5% DB	MDBR	3.6	3.7	3.8	4.4	4.6	4.6	4.4	4.2	3.8	3.5	3.5	3.9
		MCDBR	4.7	4.9	4.9	5.6	5.7	5.7	5.8	4.8	4.2	4.2	4.6	4.8
		MCWBR	4.4	4.6	4.5	4.1	3.8	3.7	3.7	3.3	3.2	3.6	4.5	4.5
	5% WB	MCDBR	4.7	4.9	4.8	5.4	5.2	4.9	5.1	4.2	4.0	4.2	4.7	4.9
		MCWBR	4.5	4.6	4.6	4.2	3.6	3.4	3.5	3.3	3.4	3.9	4.7	4.8
Clear-Sky Solar Irradiance	taub	0.389	0.300	0.331	0.352	0.364	0.351	0.354	0.349	0.339	0.297	0.361	0.377	
	taud	2.479	2.187	2.262	2.325	2.354	2.452	2.479	2.501	2.441	2.302	2.627	2.604	
	Ebn at Noon	228	576	737	816	840	864	850	819	736	582	274	101	
	Edh at Noon	25	57	82	98	104	97	92	82	70	49	22	13	
All-Sky Solar Radiation	RadAvg	0.09	0.46	1.49	3.15	4.70	5.43	4.70	3.57	1.96	0.76	0.15	0.03	
	RadStd	0.01	0.08	0.21	0.28	0.52	0.71	0.46	0.30	0.19	0.07	0.01	0.00	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		+0.54	+1.14	+1.36	+0.48	N/A	N/A	-146	-180	+32	N/A

Nomenclature: See separate page