

KEFLAVIK INTL, Iceland

WMO: 040180

Lat: 63.975N

Lon: 22.588W

Elev: 154

StdP: 14.61

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 16201

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.0	21.2	6.7	7.8	21.1	10.3	9.4	23.3	50.1	36.4	45.7	36.2	12.4	10	0.888

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	60.7	53.4	58.6	52.4	56.9	51.7	55.3	58.1	54.1	56.5	53.1	55.5	11.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.9	62.2	55.7	53.2	60.5	55.0	51.9	57.6	53.9	23.5	57.7	22.7	56.3	22.1	55.3	64.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
40.9	35.7	31.1	14.5	65.9	3.3	3.5	12.1	68.4	10.1	70.4	8.3	72.4	5.8	74.9
			12.3	58.2	3.1	2.1	10.1	59.7	8.3	61.0	6.5	62.2	4.3	63.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.3	33.7	33.2	34.3	38.6	43.7	49.2	52.4	51.6	47.3	40.9	36.5	34.0
	DBStd	8.51	5.77	6.02	5.90	5.14	4.02	3.09	2.69	2.86	3.98	5.01	5.66	6.13
	HDD50	3350	505	471	486	341	198	49	8	14	96	282	405	495
	HDD65	8637	970	891	951	791	662	473	392	416	530	746	855	960
	CDD50	186	0	0	0	0	2	25	80	63	15	1	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	1	0	0	0	0	0	0	0	1	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.8	16.6	17.2	16.6	15.2	13.7	12.1	11.8	12.3	14.8	14.9	16.0	16.6
Precipitation	PrecAvg	43.3	4.1	3.8	3.9	3.0	2.6	2.5	2.6	3.7	4.4	4.5	4.2	4.5
	PrecMax	93.0	10.8	8.2	9.0	8.9	6.1	5.8	5.5	11.9	11.0	12.2	10.1	8.0
	PrecMin	27.5	0.9	0.6	0.2	0.7	0.6	0.1	0.6	0.6	1.3	0.6	1.1	1.5
	PrecStd	9.5	1.7	1.7	1.7	1.5	1.1	1.3	1.3	2.2	2.0	2.2	1.9	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.8	47.2	48.2	52.0	56.9	61.2	64.4	64.0	57.5	53.5	50.0	48.5
		MCWB	45.9	46.4	46.7	45.4	48.2	51.4	55.5	56.8	53.2	50.7	48.8	47.9
	2%	DB	45.3	45.9	46.4	48.6	53.6	57.9	61.0	59.4	55.6	51.5	48.2	46.7
		MCWB	44.4	45.0	45.2	45.0	46.7	50.5	53.5	54.0	52.0	49.0	47.1	45.8
	5%	DB	44.3	44.3	44.8	47.2	51.5	55.8	59.0	57.4	53.9	49.8	46.6	45.0
		MCWB	43.3	43.3	43.4	44.4	46.1	49.5	52.6	52.7	51.2	48.0	45.4	44.0
	10%	DB	42.4	42.4	42.9	46.1	49.7	54.2	57.2	55.8	53.1	48.2	44.7	43.1
		MCWB	40.9	41.0	41.0	43.7	45.5	48.9	52.0	51.8	50.6	46.7	43.1	41.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	46.7	46.8	47.5	50.0	54.0	57.2	58.2	54.9	51.9	49.1	47.7
		MCDB	46.6	46.8	47.1	48.6	53.4	57.6	61.7	62.1	56.0	52.4	49.3	47.9
	2%	WB	44.7	44.8	45.3	46.2	48.5	52.3	55.3	55.6	53.4	49.6	47.3	45.9
		MCDB	45.0	45.1	45.9	47.6	50.9	55.6	58.6	58.0	54.5	50.4	47.7	46.4
	5%	WB	42.9	43.0	43.5	44.9	47.4	51.3	54.1	54.2	52.2	48.1	45.4	44.1
		MCDB	43.7	43.8	44.4	46.4	49.6	54.4	57.1	56.5	53.4	49.1	46.2	44.8
	10%	WB	40.4	40.6	41.1	43.6	46.3	50.2	53.1	53.1	51.1	46.6	43.2	41.7
		MCDB	41.7	41.8	42.7	45.4	48.4	53.2	56.0	55.3	52.6	48.0	44.3	43.0
Mean Daily Temperature Range	5% DB	MDBR	7.4	7.8	8.0	8.8	9.0	8.6	8.3	7.8	7.6	7.1	7.1	7.3
		MCDBR	8.3	8.4	8.2	8.9	10.8	11.2	11.7	9.9	7.9	7.5	7.6	8.0
		MCWBR	9.2	8.9	8.1	7.2	6.9	6.4	6.7	6.3	6.4	7.2	8.5	8.9
	5% WB	MCDBR	8.4	8.4	7.9	8.2	8.5	9.5	9.2	8.1	6.6	7.3	7.7	8.1
		MCWBR	9.3	9.2	8.6	7.6	6.5	6.4	6.3	6.1	6.6	7.7	8.8	9.1
Clear-Sky Solar Irradiance	taub	0.409	0.313	0.338	0.363	0.361	0.350	0.351	0.346	0.343	0.306	0.367	0.371	
	taud	2.541	2.240	2.330	2.323	2.396	2.480	2.503	2.527	2.452	2.326	2.672	2.588	
	Ebn at Noon	88	189	237	257	270	276	272	263	236	191	105	50	
	Edh at Noon	10	18	25	32	32	30	29	26	23	16	8	5	
All-Sky Solar Radiation	RadAvg	37	169	482	1017	1511	1628	1482	1136	658	276	61	16	
	RadStd	3	26	66	120	179	226	148	88	62	23	7	1	

Historical Trends

DBAvg	Heating		Cooling			Degree-Days				
	99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+0.70	+1.64	+2.68	N/A	N/A	N/A	-221	-254	+45	N/A
Regional (7 neighbors)	+0.95	+1.87	+2.09	+1.30	N/A	N/A	-288	-347	+67	N/A

Nomenclature: See separate page