

REYKJAVIK, Iceland

WMO: 040300

Lat: 64.1275N

Lon: 21.9028W

Elev: 171

StdP: 14.61

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.7	18.7	3.6	6.7	17.9	7.1	8.0	20.6	42.7	36.2	38.6	35.4	8.2	100	0.788

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	62.3	54.1	59.7	53.0	58.1	52.2	55.8	59.7	54.6	58.2	53.4	56.8	9.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.8	62.0	57.2	52.4	58.9	56.0	51.5	57.0	55.2	23.8	59.7	23.0	58.3	22.3	56.7	65.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.8	29.4	25.6	11.3	68.1	3.0	3.6	9.1	70.7	7.3	72.8	5.7	74.8	3.5	77.4
			9.5	58.8	2.9	2.4	7.4	60.5	5.7	62.0	4.1	63.3	1.9	65.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.4	33.3	32.9	34.1	38.9	44.2	49.9	53.2	52.2	47.7	40.8	36.0	33.5	(6)
	DBStd	9.22	6.56	6.63	6.34	5.55	4.45	3.54	3.04	3.11	4.53	5.73	6.56	6.90	(7)
	HDD50	3386	519	480	493	333	185	44	6	12	93	288	421	512	(8)
	HDD65	8602	984	900	958	783	646	454	364	396	518	751	871	977	(9)
	CDD50	258	0	0	0	0	4	40	106	81	25	2	0	0	(10)
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	11.2	12.6	13.2	12.6	11.9	10.6	9.4	8.8	9.1	11.1	11.0	12.1	12.3	(14)
(15) Precipitation	PrecAvg	32.7	3.2	3.2	3.2	2.3	1.9	1.9	2.0	2.4	3.0	3.3	3.1	3.4	(15)
	PrecMax	44.4	6.0	6.7	5.7	5.9	5.1	4.6	4.4	5.9	6.9	8.1	10.2	7.8	(16)
	PrecMin	23.4	1.1	0.2	0.1	0.7	0.4	0.1	0.5	0.4	0.9	0.7	0.4	0.9	(17)
	PrecStd	5.5	1.3	1.5	1.4	1.1	1.1	0.9	0.8	1.1	1.3	1.5	1.5	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.0	48.2	48.6	53.9	59.0	63.0	66.4	64.8	60.5	55.5	51.5	49.9	(19)
		MCWB	46.4	46.8	45.7	46.4	49.0	53.4	56.5	56.5	54.1	50.3	47.3	48.0	(20)
	2%	DB	46.1	46.3	46.8	50.3	55.0	59.3	62.7	60.9	57.5	52.4	49.2	47.9	(21)
		MCWB	44.3	44.3	44.4	45.1	47.6	51.2	54.2	54.4	52.2	48.5	46.5	46.2	(22)
	5%	DB	44.4	44.5	45.0	48.3	52.3	57.3	60.5	59.0	55.6	51.0	47.7	46.0	(23)
		MCWB	42.3	42.2	42.3	44.2	46.5	50.5	53.5	53.4	51.3	47.5	45.0	43.8	(24)
	10%	DB	42.4	42.4	43.0	46.6	50.4	55.5	58.6	57.3	53.9	49.2	45.2	43.2	(25)
		MCWB	40.0	39.9	40.2	43.0	45.6	49.7	52.6	52.3	50.2	46.0	42.4	41.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.5	46.7	46.8	48.3	50.4	55.1	58.3	58.5	55.5	51.8	49.2	48.3	(27)
		MCDB	47.4	47.7	48.0	50.8	55.4	59.9	63.6	62.7	58.1	54.0	50.3	49.1	(28)
	2%	WB	44.4	44.3	44.9	46.1	49.0	53.0	55.8	55.8	53.5	49.6	46.7	46.1	(29)
		MCDB	45.5	45.7	46.5	49.1	53.1	57.2	60.3	59.2	56.3	51.8	48.4	47.5	(30)
	5%	WB	42.5	42.2	42.9	44.7	47.7	51.8	54.6	54.6	52.2	47.9	44.7	43.7	(31)
		MCDB	43.9	43.8	44.7	47.5	51.3	55.8	58.8	57.8	54.9	50.4	47.0	45.2	(32)
	10%	WB	40.0	40.0	40.5	43.3	46.5	50.6	53.5	53.3	51.0	46.2	42.5	41.1	(33)
		MCDB	41.7	41.7	42.6	46.0	49.9	54.4	57.2	56.3	53.7	49.0	44.9	43.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	8.7	9.1	9.5	9.7	9.0	8.8	8.7	8.6	8.4	8.0	8.1	(35)
		MCDBR	8.7	8.7	8.8	10.0	11.5	11.7	12.4	11.0	9.5	8.8	8.4	8.6	(36)
	5% WB	MCWBR	8.8	8.4	7.8	7.6	7.4	7.0	7.3	7.0	7.0	7.5	8.3	8.4	(37)
		MCWBR	8.7	8.7	8.4	8.9	9.7	10.0	10.2	8.8	7.8	8.4	8.3	8.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.408	0.314	0.338	0.366	0.368	0.353	0.355	0.345	0.339	0.305	0.366	0.377	(40)
		taud	2.520	2.189	2.281	2.286	2.346	2.450	2.479	2.514	2.458	2.312	2.647	2.574	(41)
	Ebn at Noon		85	184	235	255	266	274	271	263	237	189	102	45	(42)
		Edh at Noon	9	19	26	33	34	31	30	26	23	16	8	5	(43)
(44) All-Sky Solar Radiation	RadAvg		38	172	514	1059	1526	1633	1469	1142	654	278	63	16	(44)
	RadStd		3	27	70	119	156	206	133	82	62	25	7	1	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (9 neighbors)	+1.01	+2.12	N/A	+1.13	N/A	N/A	-292	-376	+72	N/A
		+0.92	+1.87	+2.38	+1.15	N/A	N/A	-288	-347	+67	N/A

Nomenclature: See separate page