

REYKJAVIK, Iceland

WMO: 040300

Lat: 64.1275N

Lon: 21.9028W

Elev: 52

StdP: 100.70

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.1	-7.4	-15.8	1.0	-7.8	-13.8	1.1	-6.3	19.1	2.3	17.3	1.9	3.7	100	0.788

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.9	16.8	12.3	15.4	11.7	14.5	11.2	13.2	15.4	12.5	14.6	11.9	13.8	4.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	8.9	14.0	11.4	8.4	13.3	10.9	8.1	12.9	37.4	15.4	35.6	14.6	34.1	13.7	18.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.1	13.1	11.4	DB	-11.5	20.0	1.7	2.0	-12.7	21.5	-13.7	22.7	-14.6	23.8	-15.8	25.2	(4)
(5)			WB	-12.5	14.9	1.6	1.4	-13.6	15.9	-14.6	16.6	-15.5	17.4	-16.7	18.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.2	0.7	0.5	1.2	3.8	6.8	9.9	11.8	11.2	8.7	4.9	2.2	0.8
	DBStd	5.12	3.64	3.68	3.52	3.08	2.47	1.97	1.69	1.73	2.52	3.18	3.65	3.83
	HDD10.0	1881	288	267	274	185	103	24	3	7	52	160	234	284
	HDD18.3	4779	547	500	532	435	359	252	202	220	288	417	484	543
	CDD10.0	143	0	0	0	0	2	22	59	45	14	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.0	5.6	5.9	5.6	5.3	4.8	4.2	3.9	4.1	5.0	4.9	5.4	5.5
Precipitation	PrecAvg	831	81	81	81	59	48	48	51	62	75	83	79	87
	PrecMax	1127	153	170	146	150	129	116	113	149	174	207	260	197
	PrecMin	594	28	5	2	18	10	2	12	9	23	19	10	23
	PrecStd	139	34	38	36	29	29	23	20	29	32	38	37	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	9.0	9.2	12.2	15.0	17.2	19.1	18.2	15.8	13.1	10.9	9.9
		MCWB	8.0	8.2	7.6	8.0	9.5	11.9	13.6	13.6	12.3	10.2	8.5	8.9
	2%	DB	7.8	8.0	8.2	10.2	12.8	15.2	17.1	16.1	14.2	11.3	9.6	8.9
		MCWB	6.8	6.8	6.9	7.3	8.7	10.6	12.3	12.4	11.2	9.1	8.0	7.9
	5%	DB	6.9	6.9	7.2	9.1	11.3	14.0	15.9	15.0	13.1	10.5	8.7	7.8
		MCWB	5.7	5.7	5.7	6.8	8.1	10.3	11.9	11.9	10.7	8.6	7.2	6.5
	10%	DB	5.8	5.8	6.1	8.1	10.2	13.1	14.8	14.0	12.2	9.6	7.3	6.2
		MCWB	4.4	4.4	4.5	6.1	7.5	9.8	11.5	11.3	10.1	7.8	5.8	5.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	8.2	8.2	9.1	10.2	12.8	14.6	14.7	13.0	11.0	9.6	9.1
		MCDB	8.5	8.7	8.9	10.5	13.0	15.5	17.5	17.0	14.5	12.2	10.2	9.5
	2%	WB	6.9	6.8	7.2	7.8	9.5	11.7	13.2	13.2	11.9	9.8	8.2	7.9
		MCDB	7.5	7.6	8.0	9.5	11.7	14.0	15.7	15.1	13.5	11.0	9.1	8.6
	5%	WB	5.8	5.7	6.1	7.1	8.7	11.0	12.6	12.6	11.2	8.8	7.1	6.5
		MCDB	6.6	6.6	7.1	8.6	10.7	13.2	14.9	14.3	12.7	10.2	8.3	7.3
	10%	WB	4.4	4.5	4.7	6.3	8.1	10.3	12.0	11.8	10.6	7.9	5.8	5.0
		MCDB	5.4	5.4	5.9	7.8	9.9	12.4	14.0	13.5	12.0	9.4	7.1	6.1
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.8	5.0	5.3	5.4	5.0	4.9	4.8	4.8	4.7	4.4	4.5
		MCDBR	4.8	4.8	4.9	5.5	6.4	6.5	6.9	6.1	5.3	4.9	4.6	4.8
		MCWBR	4.9	4.7	4.3	4.2	4.1	3.9	4.1	3.9	3.9	4.2	4.6	4.7
	5% WB	MCDBR	4.8	4.8	4.7	5.0	5.4	5.5	5.7	4.9	4.3	4.7	4.6	4.8
		MCWBR	5.1	4.9	4.6	4.2	3.9	3.9	3.7	3.5	3.8	4.4	4.9	4.9
Clear-Sky Solar Irradiance	taub	0.408	0.314	0.338	0.366	0.368	0.353	0.355	0.345	0.339	0.305	0.366	0.377	
	taud	2.520	2.189	2.281	2.286	2.346	2.450	2.479	2.514	2.458	2.312	2.647	2.574	
	Ebn at Noon	267	581	742	805	840	865	853	830	748	596	320	143	
	Edh at Noon	29	60	83	103	106	98	93	82	71	52	25	16	
All-Sky Solar Radiation	RadAvg	0.12	0.54	1.62	3.34	4.81	5.15	4.63	3.60	2.06	0.88	0.20	0.05	
	RadStd	0.01	0.09	0.22	0.38	0.49	0.65	0.42	0.26	0.20	0.08	0.02	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.56	+1.18	N/A	+0.63	N/A	N/A	-162	-209	+40	N/A
Regional (9 neighbors)		+0.51	+1.04	+1.32	+0.64	N/A	N/A	-160	-193	+37	N/A

Nomenclature: See separate page