

STORHOFDI, Iceland

WMO: 040480

Lat: 63.400N

Lon: 20.288W

Elev: 118

StdP: 99.92

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.4	-5.0	-13.1	1.2	-5.6	-11.4	1.4	-4.3	34.4	0.8	30.9	1.7	11.5	0	1.126

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.0	14.2	11.6	13.2	11.3	12.5	10.9	12.5	13.4	11.9	12.6	11.4	12.1	5.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	8.9	12.7	11.5	8.5	12.1	11.0	8.3	11.7	35.7	13.4	34.2	12.7	33.0	12.2	16.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
28.9	25.6	22.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-8.8	16.7	2.0	1.8	-10.2	18.0	-11.4	19.1	-12.5	20.1	-13.9	21.4		
			-10.3	13.5	1.9	1.1	-11.7	14.3	-12.8	15.0	-13.8	15.6	-15.2	16.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	2.3	1.9	2.1	4.0	6.4	8.9	10.8	10.7	8.5	5.3	3.4	2.4
	DBStd	4.08	2.97	3.15	3.10	2.54	1.78	1.43	1.22	1.20	2.00	2.66	2.91	3.19
	HDD10.0	1677	238	226	246	180	112	38	6	6	49	144	197	236
	HDD18.3	4652	496	459	504	430	369	283	235	236	294	403	447	494
	CDD10.0	67	0	0	0	0	0	4	29	28	6	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	10.3	12.1	12.4	11.9	11.1	8.8	7.9	7.4	7.9	10.4	10.4	11.8	11.7
Precipitation	PrecAvg	1572	151	138	140	110	99	100	97	134	140	155	146	148
	PrecMax	2035	268	301	302	215	247	193	206	270	293	281	329	236
	PrecMin	1199	45	26	9	39	11	12	39	4	44	51	27	55
	PrecStd	201	56	59	59	38	50	47	38	67	56	53	63	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	8.2	8.1	9.1	11.7	14.1	15.6	16.4	12.7	10.7	9.2	8.8
		MCWB	7.6	7.9	7.5	7.2	8.9	10.4	12.2	12.8	11.4	9.5	9.0	8.3
	2%	DB	7.5	7.7	7.5	8.1	10.2	12.6	14.4	14.0	12.0	10.0	8.6	8.1
		MCWB	6.9	7.3	7.0	7.0	7.9	10.1	11.9	11.8	11.0	9.2	8.2	7.7
	5%	DB	7.0	7.0	7.0	7.6	9.4	11.6	13.5	13.1	11.5	9.5	8.0	7.5
		MCWB	6.4	6.5	6.5	6.6	7.5	9.6	11.5	11.4	10.6	8.8	7.4	6.9
	10%	DB	6.3	6.2	6.3	7.1	8.7	10.9	12.7	12.4	11.0	8.9	7.3	6.7
		MCWB	5.6	5.5	5.5	6.2	7.2	9.3	11.1	11.0	10.1	8.2	6.6	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	8.1	7.7	8.2	9.6	11.5	13.2	13.5	12.2	10.2	9.2	8.6
		MCDB	7.9	8.1	7.8	8.4	11.0	12.8	14.7	15.1	12.4	10.3	9.2	8.7
	2%	WB	7.2	7.4	7.2	7.6	8.7	10.7	12.5	12.7	11.5	9.6	8.4	7.9
		MCDB	7.4	7.5	7.3	7.8	9.4	11.7	13.6	13.5	11.7	9.8	8.5	8.1
	5%	WB	6.6	6.6	6.6	7.1	8.2	10.2	11.9	12.0	10.8	9.0	7.6	7.1
		MCDB	6.9	6.9	6.9	7.4	8.8	11.1	12.8	12.6	11.1	9.4	7.9	7.4
	10%	WB	5.6	5.7	5.6	6.5	7.8	9.6	11.4	11.4	10.4	8.3	6.8	6.1
		MCDB	6.2	6.2	6.2	7.0	8.4	10.5	12.3	12.1	10.8	8.8	7.3	6.6
Mean Daily Temperature Range	5% DB	MDBR	3.2	3.4	3.3	3.3	3.3	3.0	3.0	2.7	2.6	2.8	3.0	3.2
		MCDBR	3.0	3.3	3.0	3.3	4.1	4.3	4.4	3.9	2.7	2.6	2.9	3.0
		MCWBR	3.6	4.0	3.6	3.2	2.9	3.1	3.2	2.9	2.6	3.0	3.5	3.7
	5% WB	MCDBR	3.2	3.2	3.1	2.7	3.1	3.5	3.6	2.9	2.2	2.4	3.0	3.1
		MCWBR	3.9	4.0	3.8	3.1	2.6	2.8	2.8	2.5	2.6	3.0	3.7	3.8
Clear-Sky Solar Irradiance	taub	0.410	0.312	0.331	0.361	0.359	0.352	0.354	0.341	0.343	0.306	0.374	0.373	
	taud	2.659	2.233	2.340	2.300	2.383	2.461	2.485	2.529	2.446	2.332	2.772	2.592	
	Ebn at Noon	330	610	764	816	854	869	856	839	750	616	378	188	
	Edh at Noon	31	60	80	103	103	98	93	82	73	53	27	18	
All-Sky Solar Radiation	RadAvg	0.14	0.57	1.57	3.25	4.74	5.00	4.59	3.67	2.13	0.91	0.22	0.07	
	RadStd	0.02	0.10	0.22	0.39	0.47	0.62	0.38	0.26	0.21	0.09	0.04	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.65	+1.12	N/A	+1.33	+0.69	+0.60	-207	-260	+55	N/A
(47) Regional (5 neighbors)		+0.51	+1.04	+1.32	+0.64	N/A	N/A	-160	-193	+37	N/A

Nomenclature: See separate page