

BERGSTADIR, Iceland

WMO: 040530

Lat: 65.700N

Lon: 19.617W

Elev: 141

StdP: 14.62

Time Zone: 0.00 (E00)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.4	13.3	4.9	7.1	10.3	9.2	8.8	13.9	58.8	38.9	53.5	36.3	6.3	160	0.920

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	63.2	54.6	60.7	53.2	58.8	52.2	56.0	61.5	54.4	59.4	53.0	57.6	15.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.0	60.1	58.3	51.6	56.9	56.7	50.2	54.1	55.4	23.9	61.9	22.9	59.5	22.1	57.6	63.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 46.8	40.7	34.6	DB	6.4	68.8	3.8	2.2	3.7	70.4	1.5	71.7	-0.6	72.9	-3.4	74.5	(4)
(5)			WB	5.3	59.0	3.4	2.5	2.8	60.9	0.8	62.4	-1.0	63.8	-3.5	65.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.8	31.0	29.8	31.0	36.2	42.0	47.4	51.2	50.3	45.3	37.1	32.7	30.4	
	DBStd	10.18	7.27	8.05	7.37	6.47	5.87	5.06	4.82	4.48	6.15	6.43	6.66	8.42	
	HDD50	4309	588	567	588	415	256	110	43	50	164	401	520	607	
	HDD65	9578	1053	987	1053	864	713	529	428	454	590	865	970	1072	
	CDD50	207	0	0	0	1	8	31	81	61	24	1	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	15.3	17.7	17.4	17.1	15.3	14.7	13.5	12.2	12.4	14.9	14.6	16.5	17.4	
Precipitation	PrecAvg	20.4	1.6	1.7	1.8	1.2	1.1	1.1	1.5	1.9	2.4	2.0	2.1	2.0	
	PrecMax	25.3	3.1	3.6	4.3	2.0	2.8	4.6	4.8	3.4	5.7	4.5	3.7	4.1	
	PrecMin	17.6	0.0	0.7	0.7	0.3	0.3	0.2	0.3	0.5	1.0	0.6	0.8	0.5	
	PrecStd	2.2	0.8	0.7	0.8	0.4	0.6	0.9	0.9	0.8	1.1	0.9	0.8	0.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.8	48.2	50.0	56.2	61.4	64.5	67.5	65.0	63.4	54.8	51.1	50.1	
		MCWB	43.5	44.6	44.7	48.4	50.2	53.7	56.8	56.3	54.2	49.1	46.9	45.6	
	2%	DB	45.7	45.4	46.4	51.7	56.5	60.6	63.8	61.2	59.1	51.9	47.3	46.7	
		MCWB	41.4	41.6	42.1	45.2	48.2	52.1	55.5	53.9	52.4	47.3	42.9	42.5	
	5%	DB	43.5	43.7	44.0	48.8	53.6	58.1	61.1	59.4	56.8	49.5	44.5	44.0	
		MCWB	39.8	40.1	40.2	43.3	46.7	50.4	53.8	53.1	50.7	45.3	41.0	39.9	
	10%	DB	41.2	41.0	41.4	46.2	51.1	55.8	58.9	57.6	54.6	46.6	41.8	41.6	
		MCWB	37.8	37.7	37.8	41.7	45.3	49.1	52.8	52.0	49.5	43.1	38.6	38.0	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.3	45.4	45.2	49.1	51.5	56.7	58.4	57.9	55.2	49.9	47.1	45.7
			MCDB	47.2	47.6	49.3	54.6	59.2	63.6	65.0	62.6	61.7	53.7	51.0	49.4
2%		WB	41.9	42.0	42.4	45.9	49.1	53.0	56.4	55.6	53.1	47.5	43.3	42.8	
		MCDB	45.1	44.9	46.2	50.7	55.4	58.5	62.4	60.1	58.0	51.5	46.8	46.4	
5%		WB	39.8	40.2	40.4	43.7	47.3	51.1	54.8	53.9	51.4	45.5	41.0	40.3	
		MCDB	43.2	43.3	43.9	48.2	52.8	56.6	59.9	58.2	56.1	49.0	44.4	43.7	
10%		WB	38.0	38.0	38.0	41.9	45.6	49.6	53.4	52.3	49.8	43.4	39.0	38.2	
		MCDB	41.1	40.8	41.1	46.0	50.6	54.8	58.0	56.3	54.2	46.4	41.6	41.4	
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.3	8.7	9.6	9.4	9.1	8.9	9.2	8.8	7.9	8.2	8.8	
		MCDBR	9.4	9.4	10.4	12.6	13.3	13.0	13.0	11.5	11.2	10.4	11.0	9.8	
		MCWBR	8.1	8.1	8.2	8.5	8.1	8.0	7.5	7.5	7.6	8.2	9.5	8.3	
	5% WB	MCDBR	9.6	9.7	10.3	12.0	12.3	11.6	11.5	10.5	10.4	10.2	11.1	9.9	
		MCWBR	8.6	8.6	8.4	8.7	8.3	7.9	7.2	7.6	7.7	8.4	9.9	8.7	
Clear-Sky Solar Irradiance	taub	0.390	0.289	0.317	0.349	0.351	0.350	0.352	0.338	0.325	0.293	0.380	0.398		
	taud	2.555	2.112	2.199	2.186	2.300	2.411	2.450	2.494	2.456	2.211	2.618	2.578		
	Ebn at Noon	69	178	235	256	269	273	269	262	237	175	72	19		
	Edh at Noon	7	18	27	35	35	32	30	26	21	16	7	4		
All-Sky Solar Radiation	RadAvg	27	150	508	1076	1507	1744	1451	1114	621	235	49	6		
	RadStd	2	17	49	102	104	167	113	88	36	22	3	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (11 neighbors)		+0.88	+1.40	+2.16	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page