

AKUREYRI 1, Iceland

WMO: 040630

Lat: 65.6856N

Lon: 18.1002W

Elev: 75

StdP: 14.66

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.1	10.2	0.2	5.6	5.8	5.0	7.1	11.0	39.4	40.7	33.1	37.5	5.2	190	0.774

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	66.1	55.5	63.0	54.0	61.0	52.9	57.1	63.9	55.2	61.4	53.7	59.7	11.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.6	61.3	59.6	51.8	57.3	57.6	50.2	54.0	56.1	24.5	64.2	23.4	61.5	22.5	59.6	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
28.9	24.6	21.2	DB	-3.1	72.1	5.9	2.5	-7.3	73.9	-10.8	75.3	-14.0	76.7	-18.3	78.5	
			WB	-3.7	62.2	5.7	2.7	-7.8	64.1	-11.1	65.7	-14.3	67.2	-18.4	69.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	39.0	30.0	29.6	31.3	36.3	42.6	48.9	52.3	51.1	46.2	37.4	32.1	29.8
	DBStd	11.12	8.64	8.88	8.28	7.22	6.19	5.29	4.67	4.69	6.43	7.29	8.01	9.49
	HDD50	4278	620	571	579	412	240	83	28	42	148	393	537	625
	HDD65	9478	1084	991	1044	860	695	483	395	432	564	854	986	1090
	CDD50	276	0	0	0	3	11	50	98	75	35	3	1	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	8.8	9.3	9.6	9.4	9.3	9.4	8.8	8.1	7.8	8.3	7.9	8.5	9.3
Precipitation	PrecAvg	20.4	2.2	1.7	1.8	1.1	0.9	0.9	1.3	1.5	1.8	2.5	2.5	2.3
	PrecMax	29.3	5.1	5.0	5.0	2.6	2.4	2.8	2.9	4.3	5.6	6.9	5.6	6.2
	PrecMin	12.6	0.0	0.0	0.3	0.2	0.0	0.1	0.4	0.2	0.2	0.2	0.6	0.5
	PrecStd	3.8	1.1	1.1	0.9	0.5	0.6	0.6	0.6	0.8	1.1	1.3	1.2	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.8	50.3	53.4	58.8	62.9	68.2	70.2	68.6	65.0	57.6	55.1	52.1
		MCWB	44.9	44.0	45.8	48.1	51.8	56.5	58.9	57.0	55.3	50.2	48.7	45.2
	2%	DB	48.1	47.6	49.7	54.0	58.9	64.2	66.2	64.5	61.4	54.7	49.7	48.3
		MCWB	42.7	42.1	43.5	45.9	49.4	53.0	55.9	55.5	53.3	48.4	44.6	43.1
	5%	DB	44.9	44.8	46.3	50.5	55.5	60.8	63.0	61.9	59.0	51.8	46.1	45.0
		MCWB	40.0	39.9	40.9	43.6	47.4	51.7	54.5	54.0	51.8	46.3	41.6	40.4
	10%	DB	42.2	42.0	42.9	48.0	52.7	58.2	60.6	59.2	56.3	48.3	43.0	42.4
		MCWB	37.8	37.6	38.1	42.0	45.4	50.4	53.3	52.6	49.7	43.9	39.1	38.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.8	44.7	46.6	49.4	52.8	57.6	60.6	59.2	56.6	51.3	49.1	45.9
		MCDB	50.5	49.5	52.4	57.1	61.5	66.5	68.2	65.6	63.2	56.4	54.5	50.8
	2%	WB	42.6	42.0	43.4	46.3	50.0	54.4	57.4	56.6	53.9	48.9	44.7	43.2
		MCDB	47.5	46.8	48.9	53.0	57.9	61.7	64.1	62.8	60.4	54.1	48.6	47.8
	5%	WB	40.2	40.1	40.9	44.0	47.9	52.4	55.4	54.8	52.1	46.6	41.6	40.7
		MCDB	44.7	44.5	45.9	50.0	54.7	59.1	61.6	60.5	58.0	51.2	45.2	44.7
	10%	WB	37.8	37.7	38.3	41.9	46.0	50.9	53.8	53.2	50.3	44.3	39.3	38.3
		MCDB	41.7	41.7	42.7	47.3	51.6	57.0	59.3	58.6	55.4	47.7	42.4	41.7
Mean Daily Temperature Range	5% DB	MDBR	11.2	11.3	10.9	11.5	11.8	12.1	11.1	11.8	11.6	10.1	10.5	11.7
		MCDBR	12.7	13.3	14.0	15.7	17.1	17.5	16.4	16.5	15.0	13.9	13.8	13.4
		MCWBR	10.6	10.8	10.8	10.7	10.5	10.5	9.8	10.4	10.1	10.8	11.7	10.9
	5% WB	MCDBR	12.5	12.9	14.0	15.5	15.9	15.7	14.7	14.9	14.5	13.0	13.3	13.1
		MCWBR	10.6	10.8	11.0	11.0	10.3	10.1	9.5	10.2	10.5	10.6	11.6	11.0
Clear-Sky Solar Irradiance	taub	0.255	0.306	0.330	0.364	0.372	0.382	0.367	0.351	0.333	0.294	N/A	0.249	
	taud	1.881	2.007	2.074	2.038	2.114	2.253	2.367	2.413	2.364	2.147	N/A	1.857	
	Ebn at Noon	53	163	225	248	260	261	263	256	231	171	N/A	6	
	Edh at Noon	7	20	30	41	42	37	32	28	23	17	N/A	2	
All-Sky Solar Radiation	RadAvg	29	163	541	1131	1575	1795	1795	1481	1131	640	250	54	6
	RadStd	2	16	43	90	88	161	161	115	85	36	20	3	0

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	+0.58	N/A	+1.64	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page