

KIRKJUBAEJARKLAUSTUR, Iceland

WMO: 040640

Lat: 63.793N

Lon: 18.012W

Elev: 72

StdP: 14.66

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.8	19.7	3.5	6.6	18.4	7.0	7.9	21.1	34.1	27.8	28.7	34.5	8.7	340	0.725

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	64.5	56.4	61.9	54.8	59.5	53.6	57.7	62.7	55.9	59.8	54.6	57.9	9.7	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.3	65.3	59.1	53.9	62.1	57.1	52.9	59.6	55.8	24.9	63.2	23.8	60.0	23.0	58.1	66.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
31.3	26.6	20.9	DB	12.4	70.7	3.0	3.1	10.3	72.9	8.5	74.7	6.9	76.5	4.7	78.7
			WB	10.3	62.2	2.8	2.5	8.2	64.0	6.6	65.4	5.0	66.9	3.0	68.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	41.5	33.3	32.4	34.0	39.3	44.8	50.2	53.5	52.7	47.5	40.8	35.6	32.9	(6)
(7)		DBStd	9.23	5.87	6.13	6.07	5.47	4.46	3.94	2.92	3.06	4.33	5.40	5.85	6.03	(7)
(8)		HDD50	3398	519	492	496	321	171	43	4	8	95	287	433	529	(8)
(9)		HDD65	8590	984	912	961	771	628	443	357	380	526	751	883	994	(9)
(10)		CDD50	282	0	0	0	0	8	50	112	93	19	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	1	0	0	0	0	0	1	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	8.3	8.4	8.0	8.8	9.4	8.2	7.8	7.1	7.3	8.4	9.1	8.6	8.4	(14)
(15)	Precipitation	PrecAvg	78.5	7.3	7.2	6.1	5.6	4.5	4.4	5.2	7.4	8.2	7.8	6.7	8.6	(15)
(16)		PrecMax	104.6	15.1	17.0	12.0	12.3	8.3	7.7	11.2	14.2	14.7	17.8	13.0	12.8	(16)
(17)		PrecMin	57.5	2.1	1.9	2.2	1.7	0.8	0.9	1.7	3.5	4.6	3.5	1.3	4.0	(17)
(18)		PrecStd	9.7	3.3	3.6	2.6	2.8	1.5	2.2	2.4	2.8	2.6	3.5	2.7	2.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.3	47.8	48.3	53.4	62.0	67.8	68.3	68.2	59.7	52.5	48.9	47.7	(19)
(20)		MCWB	46.1	47.2	45.5	46.2	52.5	58.0	58.5	60.6	53.4	49.3	47.3	47.0	(20)	
(21)		2%	DB	44.4	45.0	46.1	50.0	57.1	63.0	64.5	63.1	56.5	51.1	47.1	45.6	(21)
(22)		MCWB	43.0	44.0	43.9	44.8	49.7	54.2	56.4	56.7	52.3	49.2	45.9	44.6	(22)	
(23)		5%	DB	42.4	43.1	44.4	48.1	53.8	60.0	62.0	60.5	54.6	49.9	45.7	43.4	(23)
(24)		MCWB	41.0	41.8	42.6	44.6	47.9	52.7	55.3	54.7	51.4	48.5	44.5	42.1	(24)	
(25)		10%	DB	40.7	41.0	42.3	46.7	51.4	57.1	59.5	58.2	53.2	48.5	44.0	41.4	(25)
(26)		MCWB	38.9	39.8	40.1	43.9	46.5	51.3	54.0	53.5	50.6	46.7	42.4	39.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	47.0	46.6	48.4	53.9	59.0	60.1	61.1	55.3	51.2	48.4	47.2	(27)
(28)		MADB	46.6	47.6	47.6	50.6	60.9	65.9	65.8	66.1	57.1	51.5	48.6	47.5	(28)	
(29)		2%	WB	43.5	44.3	44.8	46.9	50.8	55.4	57.6	57.9	53.7	50.0	46.4	44.9	(29)
(30)		MADB	44.1	44.8	45.6	48.4	55.3	61.0	62.7	62.0	55.4	50.5	46.8	45.3	(30)	
(31)		5%	WB	41.4	42.1	42.9	45.7	49.1	53.5	55.9	55.8	52.5	48.9	44.8	42.6	(31)
(32)		MADB	42.2	42.8	44.2	47.2	52.3	58.4	60.2	58.8	53.9	49.6	45.5	43.1	(32)	
(33)		10%	WB	39.5	39.9	40.6	44.4	47.7	51.9	54.6	54.5	51.3	47.3	42.6	40.0	(33)
(34)		MADB	40.4	40.9	42.1	46.3	50.3	56.0	58.2	57.0	52.6	48.2	43.7	40.9	(34)	
(35)	Mean Daily Temperature Range		MDBR	6.9	7.8	8.5	9.8	10.3	10.3	9.6	9.6	8.4	7.8	6.9	7.1	(35)
(36)		5% DB	MADB	8.0	8.9	8.9	10.1	13.9	15.8	15.4	13.9	10.0	8.1	7.4	8.4	(36)
(37)		MCWBR	8.0	8.9	7.9	7.4	8.9	9.9	9.7	9.4	7.6	7.4	7.6	8.3	(37)	
(38)		5% WB	MADB	8.1	8.6	8.2	8.3	11.5	13.7	12.6	11.7	7.8	7.1	7.0	8.5	(38)
(39)		MCWBR	8.4	8.8	8.0	6.8	8.1	9.3	8.6	8.7	6.9	7.2	7.6	8.7	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.268	0.315	0.340	0.366	0.369	0.382	0.365	0.357	0.355	0.317	0.393	0.396	(40)	
(41)		taud	1.938	2.114	2.158	2.167	2.255	2.276	2.385	2.400	2.304	2.200	2.654	2.486	(41)	
(42)		Ebn at Noon	86	183	232	254	266	264	267	258	228	180	99	41	(42)	
(43)		Edh at Noon	10	21	30	37	37	37	32	29	26	19	9	6	(43)	
(44)	All-Sky Solar Radiation	RadAvg	45	207	587	1175	1662	1762	1549	1232	712	305	76	20	(44)	
(45)		RadStd	4	30	51	113	138	144	106	71	54	30	9	1	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	+3.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		+1.08	+2.00	+2.34	+1.13	N/A	N/A	-304	-405	+81	N/A	

Nomenclature: See separate page