

HORNAFJORDUR AP, Iceland

WMO: 040820

Lat: 64.296N

Lon: 15.227W

Elev: 24

StdP: 14.68

Time Zone: 0.00 (E00)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.3	20.0	3.2	6.5	18.4	7.1	7.9	21.2	48.7	36.2	43.6	35.9	13.3	340	0.807

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	60.2	53.7	58.0	52.7	56.4	52.0	55.3	58.1	54.1	56.4	53.1	55.3	10.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
53.9	61.8	56.2	52.9	59.5	55.1	51.9	57.4	54.2	23.4	58.3	22.7	56.7	22.1	55.4	65.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.6	33.8	28.8	13.6	66.7	3.3	4.0	11.3	69.6	9.4	71.9	7.6	74.1	5.2	77.0
			11.6	58.5	3.2	2.4	9.3	60.2	7.4	61.6	5.6	63.0	3.3	64.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.2	33.6	33.5	34.6	38.4	43.4	48.6	51.6	51.5	47.4	41.4	36.3	33.7	
	DBStd	8.54	5.96	6.26	6.13	5.65	4.28	3.50	2.72	2.80	4.22	5.33	6.02	6.36	
	HDD50	3371	507	463	476	347	205	64	14	15	94	269	412	505	
	HDD65	8679	972	883	941	797	670	492	415	417	527	733	862	970	
	CDD50	167	0	0	0	0	1	22	64	62	17	1	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	11.9	13.4	13.9	13.7	12.7	11.8	10.2	8.7	8.6	11.2	12.1	13.3	13.5	
Precipitation	PrecAvg	55.0	6.0	5.4	4.6	3.6	3.2	2.9	3.3	4.1	5.3	6.7	5.0	5.7	
	PrecMax	81.2	15.0	10.9	10.1	10.5	9.2	7.3	9.1	9.2	13.1	13.9	13.8	12.8	
	PrecMin	33.5	1.5	0.2	0.1	0.5	0.6	0.2	0.6	0.2	0.9	1.5	1.1	1.3	
	PrecStd	10.1	2.9	2.6	2.4	2.0	2.0	1.7	2.1	2.1	2.7	3.1	2.9	2.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.4	46.7	48.0	53.1	56.1	63.0	63.7	64.6	59.1	53.0	49.1	48.0	
		MCWB	45.0	44.9	44.7	47.0	49.0	53.5	55.5	57.2	52.8	50.4	47.1	46.5	
	2%	DB	44.7	45.1	46.0	49.4	52.9	58.0	59.8	59.8	55.8	51.3	47.6	46.2	
		MCWB	43.1	43.8	44.0	45.3	47.5	51.6	54.0	53.9	51.7	49.0	46.0	45.0	
	5%	DB	43.2	43.8	44.7	47.6	51.1	55.6	57.8	57.5	54.3	50.2	46.4	44.7	
		MCWB	41.6	42.5	42.7	44.4	46.5	50.5	53.1	52.7	50.9	48.4	44.7	43.4	
	10%	DB	41.9	42.4	43.1	46.2	49.6	53.8	56.3	56.0	53.1	48.9	45.0	43.0	
		MCWB	40.1	40.9	40.9	43.6	45.8	49.5	52.3	52.0	50.2	47.0	43.2	41.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.1	46.1	46.3	48.5	50.9	54.9	57.7	58.1	54.7	51.3	47.7	47.3
			MCDB	47.5	46.4	47.0	51.0	54.4	60.4	61.9	63.3	56.5	51.8	48.2	47.6
2%		WB	43.9	44.2	44.8	46.6	48.9	52.8	55.5	55.4	53.1	50.1	46.6	45.4	
		MCDB	44.5	44.7	45.6	48.1	51.2	56.2	58.0	58.0	54.6	50.7	47.4	45.9	
5%		WB	42.3	42.8	43.1	45.3	47.6	51.4	54.2	54.1	52.0	49.0	45.2	43.6	
		MCDB	43.1	43.6	44.2	47.0	49.8	54.3	56.6	56.2	53.5	49.8	46.2	44.4	
10%		WB	40.5	41.1	41.3	43.9	46.6	50.3	53.1	53.1	51.0	47.5	43.6	41.4	
		MCDB	41.6	42.3	42.8	45.9	48.8	52.9	55.4	55.1	52.6	48.6	44.9	42.7	
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.6	8.1	8.8	8.7	8.0	7.9	8.6	7.8	7.1	7.2	7.6	
		MCDBR	8.1	7.5	8.8	10.1	10.4	10.7	10.6	11.2	9.1	6.6	7.6	8.2	
		MCWBR	7.9	8.0	8.0	7.6	7.2	6.7	6.8	7.4	6.3	6.0	7.8	8.4	
	5% WB	MCDBR	7.9	7.3	8.1	8.5	9.0	9.3	9.3	9.5	7.7	5.9	7.4	8.1	
		MCWBR	8.3	8.3	8.0	7.0	6.7	6.3	6.6	6.7	6.1	6.1	8.0	8.9	
Clear-Sky Solar Irradiance	taub	0.224	0.314	0.335	0.375	0.367	0.365	0.368	0.357	0.353	0.316	0.393	0.401		
	taud	2.092	2.109	2.188	2.120	2.253	2.340	2.372	2.406	2.313	2.185	2.493	2.432		
	Ebn at Noon	112	179	233	249	266	269	265	257	227	175	79	30		
	Edh at Noon	8	20	29	38	37	35	33	29	25	18	9	5		
All-Sky Solar Radiation	RadAvg	38	175	542	1064	1463	1586	1412	1103	633	253	61	15		
	RadStd	4	26	42	123	129	143	97	84	51	27	7	1		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.35	+2.05	+2.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.85	+2.45	+2.25	N/A	N/A	N/A	-263	-243	N/A	N/A

Nomenclature: See separate page