

DALATANGI, Iceland

WMO: 040970

Lat: 65.268N

Lon: 13.576W

Elev: 11

StdP: 101.19

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-7.4	-5.9	-15.1	1.0	-4.6	-13.1	1.2	-3.8	21.2	5.4	18.9	4.8	5.4	340	0.866

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.0	14.5	10.1	13.0	9.6	12.0	9.3	11.1	13.1	10.5	12.0	10.0	11.2	4.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
10.2	7.7	11.1	9.7	7.5	10.6	9.2	7.2	10.3	32.1	13.2	30.4	12.1	29.3	11.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.6	15.6	13.6	DB	-9.2	18.5	2.1	2.1	-10.6	20.0	-11.9	21.3	-13.0	22.5	-14.5	24.0	(4)
(5)			WB	-10.7	13.1	1.7	1.6	-11.9	14.2	-12.9	15.2	-13.9	16.1	-15.2	17.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	1.8	1.4	1.2	2.2	4.2	6.8	8.8	9.3	8.1	5.2	3.1	1.9	(6)	
	DBStd	4.04	3.18	3.45	3.37	3.03	2.43	2.07	1.71	1.51	2.37	2.83	3.14	3.54	(7)	
	HDD10.0	2028	255	241	272	233	180	98	44	31	64	151	208	250	(8)	
	HDD18.3	5039	513	474	530	483	438	346	294	280	306	408	457	508	(9)	
	CDD10.0	30	1	0	0	0	0	2	8	9	8	1	1	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	Wind	WSAvg	5.8	6.4	6.3	6.0	5.7	5.4	4.9	4.8	4.8	5.8	6.4	6.2	6.6	(14)
	Precipitation	PrecAvg	1492	154	110	112	93	86	77	90	115	148	201	164	143	(15)
(16) Precipitation	PrecMax	1901	280	217	215	201	316	188	224	356	297	415	389	301	(16)	
	PrecMin	1235	50	37	27	38	11	13	8	25	33	36	45	60	(17)	
	PrecStd	194	59	41	46	38	62	52	47	78	70	85	74	57	(18)	
	PrecStd	194	59	41	46	38	62	52	47	78	70	85	74	57	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	11.2	10.8	11.2	12.4	15.3	16.3	16.4	16.1	12.9	12.3	11.5	(19)	
	0.4%	MCWB	7.6	5.7	5.8	6.7	7.9	10.0	11.3	11.7	10.4	8.9	8.7	6.8	(20)	
	2%	DB	8.5	8.7	8.4	8.9	10.1	12.4	13.6	13.6	13.7	11.0	9.6	9.1	(21)	
	2%	MCWB	5.3	5.7	5.1	5.7	7.1	9.2	10.3	10.4	9.5	8.0	6.3	6.0	(22)	
	5%	DB	7.3	7.3	7.0	7.4	8.7	10.9	12.3	12.3	12.4	9.7	8.2	7.7	(23)	
	5%	MCWB	4.5	4.7	4.2	4.8	6.4	8.3	9.8	9.9	9.3	7.4	5.7	5.2	(24)	
	10%	DB	5.9	6.0	5.7	6.1	7.5	9.8	11.2	11.4	11.2	8.8	7.1	6.4	(25)	
	10%	MCWB	3.7	3.9	3.3	4.2	5.6	7.8	9.3	9.5	8.9	7.1	5.5	4.4	(26)	
	0.4%	WB	7.9	7.6	7.1	7.7	9.2	11.0	12.3	12.5	11.7	10.0	9.1	8.1	(27)	
	0.4%	MCDB	11.1	9.8	9.6	10.0	11.0	13.3	15.0	15.2	13.8	11.9	11.8	10.6	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	6.1	6.2	5.7	6.4	7.7	9.6	10.9	11.1	10.7	8.8	7.4	6.7	(29)	
	2%	MCDB	8.0	8.0	7.6	8.2	9.5	11.6	12.7	12.8	12.5	9.8	8.5	8.3	(30)	
	5%	WB	5.1	5.2	4.7	5.5	6.8	8.7	10.2	10.4	10.0	8.2	6.6	5.8	(31)	
	5%	MCDB	6.6	6.9	6.4	6.9	8.3	10.3	11.6	11.7	11.4	9.2	7.5	7.1	(32)	
	10%	WB	4.2	4.3	3.7	4.7	5.9	8.0	9.7	9.9	9.4	7.6	5.8	4.9	(33)	
	10%	MCDB	5.5	5.9	5.3	5.7	7.1	9.3	10.8	10.9	10.7	8.5	6.7	6.1	(34)	
(35) Mean Daily Temperature Range		MDBR	3.7	3.9	3.9	3.6	3.4	3.5	3.3	3.0	3.3	3.1	3.6	3.8	(35)	
	5% DB	MCDBR	6.0	6.1	6.3	5.8	5.8	6.0	5.6	4.9	5.6	5.0	6.1	6.1	(36)	
	5% DB	MCWBR	5.0	5.0	5.0	4.4	3.9	3.8	3.6	3.2	3.8	4.0	5.0	5.1	(37)	
	5% WB	MCDBR	5.3	5.6	5.7	5.1	5.3	5.6	4.6	4.2	4.4	4.0	5.0	5.2	(38)	
	5% WB	MCWBR	4.7	4.8	4.9	4.1	3.9	3.7	3.3	3.0	3.4	3.6	4.6	4.8	(39)	
	5% WB	MCWBR	4.7	4.8	4.9	4.1	3.9	3.7	3.3	3.0	3.4	3.6	4.6	4.8	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.387	0.296	0.329	0.356	0.357	0.353	0.358	0.343	0.347	0.311	0.379	0.390	(40)	
	taud		2.523	2.208	2.259	2.267	2.374	2.459	2.477	2.529	2.410	2.240	2.468	2.489	(41)	
	Ebn at Noon		232	581	736	807	848	861	844	825	722	544	207	66	(42)	
	Edh at Noon		24	55	82	103	102	96	92	80	72	52	23	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.08	0.43	1.43	2.88	4.18	4.81	4.25	3.25	1.90	0.70	0.14	0.02	(44)	
	RadStd		0.01	0.06	0.14	0.27	0.42	0.45	0.30	0.27	0.16	0.06	0.02	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.58	+1.49	N/A	N/A	N/A	+0.54	-189	-186	N/A	N/A
(47) Regional (4 neighbors)		+0.48	+1.38	+0.96	N/A	N/A	N/A	-146	-135	N/A	N/A

Nomenclature: See separate page