

GUFUSKALAR, Iceland

WMO: 041040

Lat: 64.9041N

Lon: 23.9346W

Elev: 7

StdP: 101.24

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-6.5	-5.2	-12.0	1.3	-5.4	-10.4	1.5	-4.2	21.4	1.8	19.7	1.0	6.5	100	0.929

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	15.2	12.0	14.3	11.5	13.5	11.0	12.6	14.4	12.0	13.8	11.4	13.1	5.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	8.5	13.7	10.9	8.1	13.0	10.3	7.8	12.5	35.7	14.5	34.2	13.8	32.8	13.2	17.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.0	16.7	14.9	DB	-8.9	17.3	1.6	1.6	-10.0	18.5	-11.0	19.4	-11.9	20.3	-13.0	21.5	(4)
(5)			WB	-9.9	13.7	1.4	1.3	-11.0	14.7	-11.8	15.4	-12.6	16.1	-13.7	17.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.9	0.9	0.7	1.0	3.1	5.9	8.9	11.0	10.3	8.4	4.8	2.6	1.0	(6)	
	DBStd	4.55	2.94	3.09	2.80	2.80	2.41	1.83	1.66	1.64	2.37	2.76	2.81	3.20	(7)	
	HDD10.0	1944	283	260	280	206	129	41	8	15	59	161	221	280	(8)	
	HDD18.3	4900	541	493	538	456	387	282	228	248	299	419	471	538	(9)	
	CDD10.0	87	0	0	0	1	1	9	39	26	11	1	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	Wind	WSAvg	7.3	8.2	8.3	8.3	7.5	6.7	5.7	5.4	5.9	6.8	8.0	8.5	8.5	(14)
(15) Precipitation	PrecAvg	1260	111	99	104	71	72	54	68	90	125	112	130	113	(15)	
	PrecMax	1556	240	193	341	155	145	177	112	201	270	241	329	229	(16)	
	PrecMin	889	54	16	6	8	10	1	37	27	21	45	20	19	(17)	
	PrecStd	180	50	50	69	35	45	40	24	40	52	47	74	56	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	8.7	8.9	11.9	12.9	15.0	17.0	15.7	15.3	11.8	10.4	9.4	(19)	
		MCWB	7.5	7.5	6.9	8.7	9.3	10.9	12.9	12.8	12.4	9.7	8.9	8.0	(20)	
	2%	DB	7.8	7.6	7.6	9.7	11.5	13.6	15.5	14.6	13.6	10.7	8.9	8.2	(21)	
		MCWB	6.8	6.4	6.3	7.5	8.6	10.3	12.1	12.0	11.6	9.0	7.5	7.1	(22)	
	5%	DB	6.4	6.6	6.2	8.2	10.4	12.7	14.6	13.7	12.5	9.9	7.8	7.1	(23)	
		MCWB	5.3	5.5	5.0	6.2	8.0	9.9	11.7	11.3	10.7	8.3	6.5	5.9	(24)	
	10%	DB	5.0	5.4	5.0	7.2	9.5	11.9	13.9	13.0	11.7	9.0	6.5	5.8	(25)	
		MCWB	3.7	4.2	3.7	5.5	7.4	9.4	11.3	10.8	10.1	7.5	5.2	4.6	(26)	
	0.4%	WB	8.0	7.7	7.5	9.0	9.9	11.9	13.7	13.5	13.0	10.1	9.2	8.2	(27)	
		MCDB	8.8	8.4	8.3	11.6	11.7	13.6	16.1	15.0	14.9	11.3	10.0	8.9	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	6.9	6.5	6.4	7.6	9.1	10.9	12.7	12.5	11.8	9.2	7.6	7.2	(29)	
		MCDB	7.7	7.4	7.4	9.5	10.8	12.7	14.6	14.0	13.3	10.5	8.6	8.1	(30)	
	5%	WB	5.4	5.6	5.1	6.6	8.4	10.3	12.1	11.8	11.1	8.4	6.5	6.0	(31)	
		MCDB	6.4	6.5	6.1	7.9	10.0	12.2	14.1	13.3	12.3	9.7	7.6	7.0	(32)	
	10%	WB	3.9	4.2	3.7	5.7	7.7	9.7	11.6	11.2	10.3	7.6	5.4	4.6	(33)	
		MCDB	4.9	5.3	4.9	7.0	9.3	11.6	13.5	12.6	11.6	8.9	6.5	5.8	(34)	
	5% DB	MDBR	3.7	3.7	3.9	4.2	4.4	4.2	4.3	4.1	4.0	3.6	3.7	3.9	(35)	
		MCDBR	4.8	4.3	4.8	4.9	5.4	5.5	5.4	4.6	4.1	4.3	4.9	4.7	(36)	
		MCWBR	4.7	4.0	4.4	3.8	3.6	3.5	3.4	3.1	3.1	3.8	4.7	4.6	(37)	
		MCWBR	4.9	4.1	4.6	4.7	4.7	4.8	4.9	4.0	3.8	4.3	4.9	4.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.381	0.311	0.335	0.367	0.359	0.346	0.353	0.351	0.345	0.303	0.361	0.375	(40)	
		taud	2.454	2.209	2.320	2.295	2.404	2.488	2.503	2.510	2.427	2.298	2.597	2.570	(41)	
	Ebn at Noon		235	570	739	799	849	870	852	818	730	576	274	103	(42)	
		Edh at Noon	25	57	79	101	100	94	90	82	71	50	22	13	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.09	0.46	1.46	3.09	4.66	5.29	4.65	3.51	1.97	0.77	0.15	0.03	(44)	
	RadStd		0.01	0.07	0.19	0.30	0.53	0.70	0.48	0.28	0.18	0.07	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.53	+1.18	+1.28	+0.49	N/A	N/A	-146	-180	+32	N/A

Nomenclature: See separate page