

DYNJANDIHEIDI, Iceland

WMO: 041150

Lat: 65.700N

Lon: 23.083W

Elev: 2037

StdP: 13.65

Time Zone: 0.00 (E00)

Period: 06-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.4	21.7	10.1	9.9	22.5	13.0	11.5	23.5	41.0	37.3	35.8	40.2	10.8	120	0.817

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	60.1	53.6	58.2	52.4	56.7	51.6	54.7	58.7	53.4	57.1	52.3	55.8	9.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.3	62.8	56.9	51.1	60.1	55.7	50.0	57.7	54.7	23.8	58.8	23.0	57.2	22.3	56.0	60.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
34.1	29.7	25.8	15.2	64.7	3.7	1.9	12.5	66.1	10.4	67.2	8.3	68.2	5.7	69.6
			13.3	56.4	3.9	2.2	10.5	58.0	8.2	59.2	6.1	60.4	3.3	62.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.6	33.1	32.6	33.2	37.2	43.0	49.0	51.9	51.0	47.0	40.7	35.4	32.9
	DBStd	8.67	5.25	5.71	5.14	4.70	4.61	3.38	3.12	3.12	4.55	5.14	5.66	6.08
	HDD50	3599	525	486	520	384	220	58	15	24	110	289	438	530
	HDD65	8890	990	906	985	833	682	481	405	434	539	752	888	995
	CDD50	183	0	0	0	1	3	27	74	56	21	1	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	12.2	13.2	13.7	13.9	12.1	11.4	10.1	9.5	9.9	11.9	13.0	14.1	14.0
	PrecAvg	41.9	4.5	4.0	4.0	2.2	2.8	1.7	2.0	2.6	4.3	4.2	4.4	5.1
(15) Precipitation	PrecMax	59.1	13.3	7.6	12.2	4.0	6.5	5.9	3.4	4.9	8.9	10.3	10.2	9.0
	PrecMin	28.6	1.9	0.8	0.5	0.4	0.2	0.0	0.9	0.7	1.4	1.5	1.4	0.9
	PrecStd	8.2	2.6	1.8	2.6	1.1	2.1	1.7	0.6	1.2	2.1	1.9	2.6	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.8	47.3	48.1	53.1	57.0	60.7	63.5	61.7	60.9	53.9	50.8	48.6
		MCWB	44.4	44.2	44.7	47.3	50.0	52.3	55.0	55.8	54.7	48.5	47.3	46.5
	2%	DB	45.3	45.2	45.7	48.8	53.7	57.6	60.8	58.7	57.0	52.1	48.3	46.8
		MCWB	42.9	41.9	42.7	44.4	47.7	50.5	54.1	53.1	52.7	48.0	45.1	44.5
	5%	DB	43.1	43.4	43.2	46.1	51.4	55.7	58.8	57.3	55.0	50.3	45.7	45.0
		MCWB	40.4	40.6	40.2	41.6	46.3	49.7	52.9	52.3	50.9	46.8	42.8	42.2
	10%	DB	40.4	40.9	40.7	44.2	49.5	54.3	57.1	55.8	53.3	48.4	43.1	42.0
		MCWB	37.7	38.2	37.4	40.5	45.4	49.0	51.9	51.2	49.6	45.4	40.7	39.2
	0.4%	WB	44.8	45.1	45.3	48.4	50.7	53.7	56.6	56.7	55.1	50.4	48.0	46.6
		MCDB	46.3	47.1	47.5	53.1	55.4	57.2	61.7	60.8	59.7	52.4	50.2	47.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.9	42.4	42.8	45.4	48.6	51.7	54.7	54.4	53.3	48.7	45.4	44.4
		MCDB	45.0	44.8	45.5	48.6	52.7	55.7	58.9	58.1	56.7	51.3	47.9	46.3
	5%	WB	40.0	40.9	40.1	42.6	47.2	50.6	53.4	53.2	51.6	47.1	43.0	42.1
		MCDB	42.2	43.6	42.7	45.6	50.9	54.6	57.4	56.7	54.3	50.0	45.7	44.5
	10%	WB	37.6	38.3	37.4	40.8	45.8	49.5	52.4	52.0	50.2	45.6	41.0	39.2
		MCDB	39.7	40.7	40.1	44.1	49.2	53.5	56.2	55.1	53.0	48.5	43.3	41.7
	5% DB	MDBR	7.0	6.6	7.4	8.6	8.3	8.6	8.5	7.9	7.3	6.9	6.9	7.8
		MCDBR	9.4	9.0	10.5	11.0	10.5	10.6	10.6	9.0	7.8	7.6	8.8	9.7
		MCWBR	8.5	8.2	9.7	8.5	6.8	6.1	6.2	5.8	5.8	6.6	8.3	9.5
		MCDBR	9.7	9.0	10.7	11.1	9.8	9.3	8.9	8.3	7.4	7.9	8.7	9.8
(35) Mean Daily Temperature Range	5% WB	MCWBR	8.9	8.3	9.9	9.2	6.8	6.0	5.8	5.8	6.4	7.3	8.4	9.8
(40) Clear-Sky Solar Irradiance	taub		0.383	0.264	0.295	0.315	0.320	0.313	0.320	0.316	0.307	0.264	0.357	0.371
	taud		2.685	2.212	2.330	2.378	2.453	2.521	2.530	2.559	2.512	2.324	2.797	2.785
	Ebn at Noon		82	197	248	272	281	286	281	271	246	197	94	36
	Edh at Noon		7	16	23	29	30	29	27	24	20	14	6	4
(44) All-Sky Solar Radiation	RadAvg		23	131	453	960	1441	1729	1466	1112	593	217	42	5
	RadStd		2	23	59	76	156	216	142	107	54	20	3	0

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (9 neighbors)		+0.97	+2.05	+2.45	+0.86	N/A	N/A	-263	-324	+58	N/A	

Nomenclature: See separate page