

HORNBJARGSVITI, IcelandWMO: **041230**Lat: **66.4107N**Lon: **22.3789W**Elev: **72**StdP: **14.66**Time Zone: **0.00 (E00)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	17.6	20.2	8.7	8.6	20.0	11.6	10.0	22.8	57.5	39.0	47.0	38.9	17.4	20	0.863

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	58.2	52.7	55.8	51.3	53.9	50.1	54.2	57.0	52.4	54.9	50.8	52.8	13.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.9	59.6	54.5	50.9	55.5	53.0	49.5	52.6	51.5	22.7	57.0	21.7	55.1	20.8	52.9	61.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
41.2	35.4	31.4	14.7	61.3	4.2	2.2	11.7	62.9	9.2	64.2	6.8	65.4	3.8	67.0
			13.6	56.8	4.4	2.4	10.4	58.5	7.9	59.9	5.4	61.3	2.2	63.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.2	31.7	32.0	31.6	34.6	38.8	43.8	46.7	46.8	44.6	39.5	35.7	32.4
	DBStd	7.63	5.71	5.44	5.59	5.20	4.44	4.23	3.51	3.83	5.16	5.45	5.06	5.79
	HDD50	4357	567	504	570	462	348	193	117	116	177	327	430	546
	HDD65	9778	1032	924	1035	912	813	636	567	565	612	791	880	1011
	CDD50	54	0	0	0	0	1	6	14	16	15	2	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	12.7	16.2	16.2	15.4	12.7	9.8	7.7	6.7	8.7	9.9	15.6	15.5	17.7
Precipitation	PrecAvg	38.3	3.5	3.4	3.2	2.2	1.9	2.1	2.4	3.1	4.2	4.2	3.8	3.9
	PrecMax	44.6	5.1	5.6	5.2	3.4	2.9	4.4	3.9	4.8	6.3	7.7	6.7	6.1
	PrecMin	30.4	2.3	1.6	1.6	1.3	0.8	0.6	0.8	1.3	2.0	1.5	1.5	1.1
	PrecStd	3.8	0.9	1.0	1.0	0.7	0.6	1.0	0.7	0.9	1.5	1.9	1.4	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	47.4	46.7	48.9	54.9	58.4	60.9	61.3	60.5	54.7	50.5	48.5
		MCWB	45.0	43.0	44.1	44.5	51.0	52.6	53.6	55.3	53.8	52.0	49.0	46.0
	2%	DB	45.2	45.3	44.3	46.0	50.6	54.9	57.1	57.7	57.1	51.9	47.6	45.4
		MCWB	42.3	42.2	41.6	42.0	46.7	50.4	51.1	53.1	52.3	49.9	44.1	42.5
	5%	DB	42.4	42.8	41.9	44.2	48.0	52.3	54.5	54.9	54.4	49.3	44.1	43.2
		MCWB	39.5	39.2	39.6	40.9	45.0	48.2	50.3	50.7	50.6	47.4	42.4	40.8
	10%	DB	39.7	39.8	38.8	42.2	45.5	50.0	52.1	52.6	51.8	47.1	42.4	40.6
		MCWB	37.6	37.6	36.9	39.6	42.5	46.9	49.1	49.3	48.8	45.6	40.9	39.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	44.9	45.6	45.5	52.0	53.9	55.1	56.9	55.1	54.2	50.1	47.0
		MCDB	48.3	45.7	45.9	47.4	52.0	57.0	59.4	58.6	58.2	54.2	50.4	48.4
	2%	WB	42.8	42.3	42.2	43.0	47.8	51.4	52.4	54.2	53.4	50.3	44.7	43.4
		MCDB	45.0	45.1	43.8	45.1	49.0	53.8	55.5	57.2	56.4	50.7	46.1	44.8
	5%	WB	40.2	39.8	40.1	41.4	44.7	49.2	50.9	51.7	51.4	47.7	42.8	41.2
		MCDB	42.0	42.1	42.1	43.7	47.2	51.0	53.4	54.1	53.5	48.8	44.1	42.8
	10%	WB	37.8	37.7	37.5	40.1	42.7	47.3	49.5	50.0	49.5	45.9	41.3	39.3
		MCDB	39.3	39.6	38.9	42.1	44.7	49.2	51.5	51.5	51.4	47.0	42.3	40.8
Mean Daily Temperature Range	5% DB	MDBR	6.8	6.3	6.4	6.7	6.1	5.5	5.4	5.7	6.2	5.5	6.0	6.7
		MCDBR	9.7	9.7	9.4	9.8	9.7	9.6	10.4	10.0	8.9	7.2	7.8	8.3
		MCWBR	9.0	8.6	8.2	8.1	7.3	7.1	7.0	7.2	7.1	6.5	7.3	7.8
	5% WB	MCDBR	9.4	9.2	9.1	9.6	9.5	8.4	9.0	8.9	8.8	6.8	7.2	7.7
		MCWBR	9.1	8.2	8.3	8.3	7.8	7.1	6.5	7.7	7.7	6.5	6.8	7.3
Clear-Sky Solar Irradiance	taub	0.380	0.294	0.318	0.341	0.352	0.332	0.349	0.339	0.334	0.286	0.361	0.377	
	taud	2.537	2.168	2.311	2.336	2.386	2.501	2.479	2.523	2.432	2.265	2.640	2.626	
	Ebn at Noon	59	173	235	260	269	279	269	261	230	175	66	14	
	Edh at Noon	6	16	24	30	32	29	29	25	22	15	6	3	
All-Sky Solar Radiation	RadAvg	17	106	370	836	1279	1544	1342	1011	544	174	31	2	
	RadStd	1	17	41	84	153	181	131	100	43	21	3	0	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (7 neighbors)		+1.22	+2.74	+2.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page