

HORNBJARGSVITI, IcelandWMO: **041230**Lat: **66.4107N**Lon: **22.3789W**Elev: **22**StdP: **101.06**Time Zone: **0.00 (E00)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-8.0	-6.5	-12.9	1.2	-6.7	-11.3	1.4	-5.1	25.7	3.9	21.0	3.9	7.8	20	0.863

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.1	14.6	11.5	13.2	10.7	12.1	10.0	12.3	13.9	11.4	12.7	10.4	11.5	5.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.6	8.5	12.5	10.5	7.9	11.7	9.7	7.5	10.8	35.0	13.9	32.6	12.8	30.4	11.6	16.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	15.8	14.0	-9.6	16.3	2.4	1.2	-11.3	17.2	-12.7	17.9	-14.0	18.5	-15.7	19.4		
(5)			-10.2	13.8	2.4	1.3	-12.0	14.7	-13.4	15.5	-14.8	16.3	-16.5	17.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-0.2	0.0	-0.2	1.4	3.8	6.6	8.2	8.2	7.0	4.2	2.0	0.2
	DBStd	4.24	3.17	3.02	3.11	2.89	2.47	2.35	1.95	2.13	2.87	3.03	2.81	3.22
	HDD10.0	2421	315	280	317	257	193	107	65	64	98	182	239	303
	HDD18.3	5432	573	513	575	507	452	353	315	314	340	439	489	562
	CDD10.0	30	0	0	0	0	1	3	8	9	8	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.7	7.2	7.2	6.9	5.7	4.4	3.4	3.0	3.9	4.4	7.0	6.9	7.9
Precipitation	PrecAvg	973	90	87	81	55	49	54	62	79	107	107	97	98
	PrecMax	1132	130	141	133	87	73	111	98	122	161	196	169	156
	PrecMin	773	58	40	41	34	20	15	21	34	52	37	38	29
	PrecStd	97	22	25	26	17	16	25	19	24	38	48	36	32
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	8.6	8.2	9.4	12.7	14.7	16.1	16.3	15.8	12.6	10.3	9.2
		MCWB	7.2	6.1	6.7	6.9	10.6	11.4	12.0	13.0	12.1	11.1	9.4	7.8
	2%	DB	7.3	7.4	6.8	7.8	10.3	12.7	13.9	14.3	13.9	11.1	8.7	7.4
		MCWB	5.7	5.7	5.3	5.6	8.1	10.2	10.6	11.7	11.3	10.0	6.7	5.9
	5%	DB	5.8	6.0	5.5	6.8	8.9	11.3	12.5	12.7	12.5	9.6	6.7	6.2
		MCWB	4.2	4.0	4.2	4.9	7.2	9.0	10.2	10.4	10.4	8.5	5.8	4.9
	10%	DB	4.3	4.3	3.8	5.7	7.5	10.0	11.2	11.5	11.0	8.4	5.8	4.8
		MCWB	3.1	3.1	2.7	4.2	5.8	8.3	9.5	9.6	9.3	7.5	5.0	4.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	7.2	7.5	7.5	11.1	12.2	12.8	13.8	12.8	12.3	10.1	8.3
		MCDB	9.0	7.6	7.7	8.5	11.1	13.9	15.2	14.8	14.6	12.3	10.2	9.1
	2%	WB	6.0	5.7	5.7	6.1	8.8	10.8	11.4	12.4	11.9	10.1	7.0	6.3
		MCDB	7.2	7.3	6.6	7.3	9.4	12.1	13.1	14.0	13.5	10.4	7.8	7.1
	5%	WB	4.6	4.3	4.5	5.2	7.1	9.5	10.5	11.0	10.8	8.7	6.0	5.1
		MCDB	5.5	5.6	5.6	6.5	8.5	10.6	11.9	12.3	11.9	9.3	6.7	6.0
	10%	WB	3.2	3.1	3.1	4.5	5.9	8.5	9.7	10.0	9.7	7.7	5.2	4.1
		MCDB	4.1	4.2	3.8	5.6	7.0	9.5	10.8	10.9	10.8	8.3	5.7	4.9
Mean Daily Temperature Range	5% DB	MDBR	3.8	3.5	3.5	3.7	3.4	3.1	3.0	3.1	3.4	3.1	3.3	3.7
		MCDBR	5.4	5.4	5.2	5.4	5.4	5.3	5.8	5.5	5.0	4.0	4.3	4.6
		MCWBR	5.0	4.8	4.6	4.5	4.1	4.0	3.9	4.0	4.0	3.6	4.1	4.3
	5% WB	MCDBR	5.2	5.1	5.1	5.3	5.3	4.7	5.0	5.0	4.9	3.8	4.0	4.3
		MCWBR	5.0	4.5	4.6	4.6	4.3	3.9	3.6	4.3	4.3	3.6	3.8	4.0
Clear-Sky Solar Irradiance	taub	0.380	0.294	0.318	0.341	0.352	0.332	0.349	0.339	0.334	0.286	0.361	0.377	
	taud	2.537	2.168	2.311	2.336	2.386	2.501	2.479	2.523	2.432	2.265	2.640	2.626	
	Ebn at Noon	185	544	741	820	848	879	849	822	726	553	208	45	
	Edh at Noon	20	52	75	94	100	91	91	79	68	46	18	8	
All-Sky Solar Radiation	RadAvg	0.05	0.33	1.17	2.64	4.03	4.87	4.23	3.19	1.71	0.55	0.10	0.01	
	RadStd	0.00	0.06	0.13	0.27	0.48	0.57	0.41	0.31	0.13	0.07	0.01	0.00	