

AKUREYRI 2, Iceland

WMO: 041370

Lat: 65.6961N

Lon: 18.1113W

Elev: 102

StdP: 14.64

Time Zone: 0.00 (E00)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	12.1	15.4	4.1	6.8	14.8	7.4	8.1	18.4	35.1	32.8	32.0	33.8	5.7	160	0.743

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	65.6	54.5	62.6	52.9	60.2	51.5	56.2	63.2	54.3	60.4	52.8	58.5	9.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
52.6	59.1	58.2	50.9	55.5	56.4	49.5	52.6	54.8	24.0	63.7	22.9	60.4	21.9	58.5	61.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.5	22.8	19.9	5.1	71.2	3.5	2.9	2.6	73.3	0.5	74.9	-1.5	76.6	-4.1	78.6		
(5)			4.5	58.6	3.2	1.7	2.2	59.8	0.3	60.8	-1.5	61.7	-3.8	62.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.0	31.9	31.7	32.7	37.3	43.2	49.0	51.9	50.7	46.9	39.0	33.7	30.8		
	DBStd	10.18	7.54	8.05	7.00	7.01	6.27	5.07	4.61	4.57	6.22	6.93	6.95	8.21		
	HDD50	3932	560	513	537	384	225	77	29	44	133	345	490	595		
	HDD65	9143	1025	933	1002	831	675	479	406	445	542	806	939	1060		
	CDD50	263	0	0	0	3	14	48	88	64	41	4	1	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	8.3	8.7	8.3	9.1	8.4	8.8	8.3	7.6	7.5	7.9	7.9	7.8	9.3		
	PrecAvg	20.4	2.2	1.7	1.8	1.1	0.9	0.9	1.3	1.5	1.8	2.5	2.5	2.3		
(15) Precipitation	PrecMax	29.3	5.1	5.0	5.0	2.6	2.4	2.8	2.9	4.3	5.6	6.9	5.6	6.2		
	PrecMin	12.6	0.0	0.0	0.3	0.2	0.0	0.1	0.4	0.2	0.2	0.2	0.6	0.5		
	PrecStd	3.8	1.1	1.1	0.9	0.5	0.6	0.6	0.6	0.8	1.1	1.3	1.2	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.6	51.4	53.2	58.1	62.9	67.2	70.2	68.1	67.3	58.2	54.5	52.1		
		MCWB	44.6	43.2	45.4	47.5	50.3	53.5	58.0	56.3	54.4	49.0	46.9	44.5		
	2%	DB	48.6	48.5	48.9	55.0	59.1	62.8	66.0	63.7	61.8	54.8	49.3	48.1		
		MCWB	42.1	41.7	41.8	45.4	48.4	51.0	55.4	54.5	52.6	47.1	42.8	42.0		
	5%	DB	45.9	45.9	45.9	51.2	55.8	59.6	62.3	60.9	59.2	52.3	46.2	45.2		
		MCWB	40.1	39.7	39.6	43.4	46.7	50.3	53.8	52.5	51.1	45.3	41.0	39.6		
	10%	DB	42.4	43.2	42.8	48.2	52.8	57.1	59.4	58.1	56.5	49.4	43.5	42.2		
		MCWB	37.4	37.9	37.0	41.3	44.9	49.8	52.3	51.3	49.2	43.7	38.8	37.3		
	0.4%	WB	45.3	44.0	45.8	48.1	51.3	55.1	59.2	57.5	56.0	49.9	47.2	45.4		
		MCDB	51.8	49.9	52.8	57.4	60.6	63.3	67.6	65.2	64.9	57.0	54.2	51.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.3	41.7	42.1	45.9	49.0	53.1	56.9	55.4	53.2	47.5	43.5	42.3		
		MCDB	48.4	47.9	48.3	54.3	57.6	59.1	63.8	61.7	60.7	53.5	48.3	47.7		
	5%	WB	40.3	40.0	39.7	43.8	47.2	51.8	54.9	53.7	51.6	46.0	41.5	40.1		
		MCDB	45.6	45.7	45.4	50.9	54.5	57.5	60.3	59.6	58.2	51.2	45.7	44.7		
	10%	WB	37.8	38.0	37.5	41.5	45.7	50.5	53.0	52.0	50.0	44.4	39.4	37.8		
		MCDB	42.0	42.9	42.2	47.5	51.9	55.8	57.9	57.3	55.4	48.5	42.9	41.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.8	9.9	10.5	10.2	9.8	9.1	9.5	10.2	9.4	9.0	10.0		
		MCDBR	13.3	11.4	14.3	14.3	15.3	14.8	14.3	13.9	14.1	12.6	12.2	12.3		
		MCWBR	9.9	8.7	10.2	8.4	8.2	7.5	7.5	7.3	8.2	8.9	9.3	9.1		
	5% WB	MCDBR	13.1	11.3	14.1	14.5	14.0	11.2	12.6	11.8	13.0	11.6	11.4	12.4		
		MCWBR	9.8	8.8	10.3	8.9	8.2	6.4	7.3	6.8	7.8	8.5	8.9	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.255	0.306	0.329	0.364	0.372	0.381	0.367	0.351	0.333	0.294	N/A	0.248		
	taud		1.882	2.009	2.078	2.042	2.116	2.257	2.370	2.416	2.366	2.149	N/A	1.857		
	Ebn at Noon		53	164	226	248	260	262	263	256	231	171	N/A	6		
	Edh at Noon		7	20	30	40	42	37	32	28	23	17	N/A	2		
(44) All-Sky Solar Radiation	RadAvg		29	162	539	1126	1570	1792	1479	1129	639	248	54	6		
	RadStd		2	16	44	91	89	161	116	86	36	20	3	0		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.58	N/A	+1.64	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page