

AKUREYRI 2, Iceland

WMO: 041370

Lat: 65.6961N

Lon: 18.1113W

Elev: 31

StdP: 100.95

Time Zone: 0.00 (E00)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-11.1	-9.2	-15.5	1.0	-9.6	-13.7	1.2	-7.6	15.7	0.4	14.3	1.0	2.6	160	0.743

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.1	18.7	12.5	17.0	11.6	15.7	10.9	13.4	17.3	12.4	15.8	11.6	14.7	4.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.5	8.4	14.5	10.5	7.9	13.6	9.7	7.5	12.7	37.9	17.6	35.3	15.8	33.1	14.7	16.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.8	10.2	8.9	DB	-14.9	21.8	2.0	1.6	-16.3	22.9	-17.5	23.9	-18.6	24.8	-20.0	25.9	(4)
(5)			WB	-15.3	14.8	1.8	0.9	-16.5	15.5	-17.6	16.0	-18.6	16.5	-19.9	17.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.4	0.0	-0.2	0.4	2.9	6.2	9.5	11.1	10.4	8.3	3.9	0.9	-0.7		
	DBStd	5.66	4.19	4.47	3.89	3.90	3.48	2.82	2.56	2.54	3.45	3.85	3.86	4.56		
	HDD10.0	2184	311	285	298	213	125	43	16	24	74	192	272	331		
	HDD18.3	5079	569	518	557	462	375	266	226	247	301	448	522	589		
	CDD10.0	146	0	0	0	2	8	27	49	36	23	2	1	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	3.7	3.9	3.7	4.1	3.7	3.9	3.7	3.4	3.3	3.5	3.5	3.5	4.1		
(15) Precipitation	PrecAvg	517	56	44	46	28	22	23	34	37	45	64	64	59		
	PrecMax	743	130	128	127	66	62	72	73	109	141	176	141	158		
	PrecMin	320	1	1	7	5	1	2	9	5	4	4	14	13		
	PrecStd	96	29	27	22	13	15	15	15	21	27	34	30	31		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	10.8	11.8	14.5	17.2	19.6	21.2	20.0	19.6	14.6	12.5	11.1		
		MCWB	7.0	6.2	7.4	8.6	10.2	12.0	14.5	13.5	12.5	9.5	8.3	7.0		
	2%	DB	9.2	9.2	9.4	12.8	15.1	17.1	18.9	17.6	16.6	12.7	9.6	8.9		
		MCWB	5.6	5.4	5.4	7.4	9.1	10.5	13.0	12.5	11.4	8.4	6.0	5.5		
	5%	DB	7.7	7.7	7.7	10.7	13.2	15.4	16.8	16.0	15.1	11.3	7.9	7.3		
		MCWB	4.5	4.3	4.2	6.3	8.2	10.2	12.1	11.4	10.6	7.4	5.0	4.2		
	10%	DB	5.8	6.2	6.0	9.0	11.6	13.9	15.2	14.5	13.6	9.7	6.4	5.7		
		MCWB	3.0	3.3	2.8	5.2	7.2	9.9	11.3	10.7	9.6	6.5	3.8	2.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	6.6	7.7	8.9	10.7	12.9	15.1	14.2	13.3	9.9	8.5	7.5		
		MCDB	11.0	10.0	11.5	14.1	15.9	17.4	19.8	18.5	18.3	13.9	12.3	10.8		
	2%	WB	5.7	5.4	5.6	7.7	9.4	11.7	13.9	13.0	11.8	8.6	6.4	5.7		
		MCDB	9.1	8.8	9.0	12.4	14.2	15.1	17.7	16.5	16.0	11.9	9.1	8.7		
	5%	WB	4.6	4.5	4.3	6.6	8.4	11.0	12.7	12.0	10.9	7.8	5.3	4.5		
		MCDB	7.6	7.6	7.5	10.5	12.5	14.1	15.7	15.3	14.6	10.7	7.6	7.0		
	10%	WB	3.2	3.3	3.0	5.3	7.6	10.3	11.7	11.1	10.0	6.9	4.1	3.2		
		MCDB	5.6	6.0	5.7	8.6	11.0	13.2	14.4	14.0	13.0	9.2	6.1	5.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.4	5.5	5.8	5.7	5.4	5.1	5.3	5.7	5.2	5.0	5.5		
		MCDBR	7.4	6.3	7.9	8.0	8.5	8.2	8.0	7.7	7.8	7.0	6.8	6.8		
		MCWBR	5.5	4.9	5.7	4.7	4.5	4.2	4.2	4.1	4.5	4.9	5.2	5.1		
		MCWBR	7.3	6.3	7.8	8.1	7.8	6.2	7.0	6.5	7.2	6.4	6.4	6.9		
(40) Clear-Sky Solar Irradiance	taub	taub	0.255	0.306	0.329	0.364	0.372	0.381	0.367	0.351	0.333	0.294	N/A	0.248		
		taud	1.882	2.009	2.078	2.042	2.116	2.257	2.370	2.416	2.366	2.149	N/A	1.857		
		Ebn at Noon	168	516	711	782	821	825	830	808	729	539	N/A	18		
		Edh at Noon	23	64	96	127	131	117	102	88	73	53	N/A	6		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.09	0.51	1.70	3.55	4.95	5.65	4.66	3.56	2.01	0.78	0.17	0.02		
		RadStd	0.01	0.05	0.14	0.29	0.28	0.51	0.36	0.27	0.11	0.06	0.01	0.00		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (8 neighbors)		+0.32	N/A	+0.91	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page