

VESTMANNAEYJABAER, Iceland

WMO: 041460

Lat: 63.4359N

Lon: 20.2758W

Elev: 40

StdP: 100.85

Time Zone: 0.00 (E00)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-4.5	-3.4	-12.7	1.3	-2.4	-10.8	1.5	-1.8	18.3	4.0	16.6	3.7	4.1	0	0.769

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.2	15.2	11.1	14.1	11.0	13.4	10.9	12.5	13.7	12.0	13.1	11.6	12.7	3.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	8.7	12.9	11.3	8.4	12.5	10.8	8.1	12.3	35.5	13.8	34.3	13.2	33.3	12.8	16.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	13.9	12.0	DB	-6.8	17.8	1.9	1.9	-8.2	19.1	-9.3	20.2	-10.4	21.2	-11.8	22.6	(4)
(5)			WB	-8.4	13.7	1.8	1.3	-9.8	14.6	-10.8	15.4	-11.9	16.1	-13.2	17.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.2	2.6	2.9	2.8	4.9	6.9	9.7	11.5	11.3	9.3	6.1	4.0	2.5
	DBStd	4.02	2.78	2.84	2.50	2.09	1.89	1.31	1.40	1.17	1.75	2.47	2.75	3.08
	HDD10.0	1489	229	199	222	152	95	21	3	2	33	122	179	232
	HDD18.3	4414	487	433	481	402	353	259	211	217	272	379	429	491
	CDD10.0	117	0	0	0	0	0	11	50	44	11	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.0	5.7	5.9	5.6	5.7	4.9	4.1	4.0	4.0	4.8	5.1	5.2	5.1
Precipitation	PrecAvg	1572	151	138	140	110	99	100	97	134	140	155	146	148
	PrecMax	2035	268	301	302	215	247	193	206	270	293	281	329	236
	PrecMin	1199	45	26	9	39	11	12	39	4	44	51	27	55
	PrecStd	201	56	59	59	38	50	47	38	67	56	53	63	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	8.8	8.6	9.5	11.9	14.6	17.3	16.3	13.7	11.5	9.7	9.2
		MCWB	8.0	7.9	7.5	7.3	8.1	10.0	12.2	11.5	10.9	9.1	8.5	8.3
	2%	DB	8.2	8.1	7.9	8.7	10.7	13.3	15.6	14.7	12.9	10.7	9.1	8.6
		MCWB	7.5	7.3	7.0	7.1	7.5	9.8	11.4	10.9	11.2	9.1	8.2	7.7
	5%	DB	7.5	7.6	7.3	8.2	9.9	12.4	14.6	13.8	12.3	10.2	8.6	7.9
		MCWB	6.7	6.6	6.3	6.8	7.7	9.7	11.2	10.9	10.6	9.0	7.6	7.0
	10%	DB	6.7	6.9	6.6	7.8	9.3	11.7	13.7	13.2	11.7	9.6	7.9	7.1
		MCWB	5.7	5.7	5.3	6.4	7.4	9.5	11.2	10.7	10.1	8.4	6.8	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	8.3	8.0	8.3	9.2	11.7	13.6	13.3	12.4	10.2	9.1	8.7
		MCDB	8.9	8.4	8.2	8.6	10.4	12.7	15.3	14.4	12.7	10.6	9.4	9.0
	2%	WB	7.6	7.4	7.2	7.8	8.7	11.0	12.6	12.5	11.8	9.7	8.5	8.1
		MCDB	8.1	7.9	7.7	8.3	9.7	12.1	14.3	13.6	12.4	10.3	8.9	8.6
	5%	WB	6.8	6.7	6.5	7.4	8.4	10.3	12.1	11.8	11.3	9.2	7.9	7.2
		MCDB	7.4	7.4	7.2	8.0	9.4	11.7	13.3	13.0	11.9	10.0	8.6	7.8
	10%	WB	5.8	5.9	5.4	6.7	8.0	9.8	11.7	11.4	10.7	8.6	7.1	6.3
		MCDB	6.6	6.7	6.4	7.6	9.0	11.3	13.0	12.7	11.5	9.6	7.9	7.1
Mean Daily Temperature Range	5% DB	MDBR	3.7	3.6	3.7	3.5	3.4	3.1	3.2	3.3	3.1	3.1	3.3	3.6
		MCDBR	4.0	3.4	3.7	3.4	4.1	4.4	4.9	4.3	3.3	3.0	2.8	3.3
		MCWBR	4.6	3.9	4.0	3.1	2.7	2.8	2.8	2.6	2.7	3.0	3.3	3.7
	5% WB	MCDBR	4.0	3.3	3.6	2.8	3.0	3.3	3.4	3.0	2.3	2.7	2.6	3.3
		MCWBR	4.7	4.0	4.3	3.1	2.4	2.5	2.3	2.3	2.5	3.2	3.2	3.8
Clear-Sky Solar Irradiance	taub	0.411	0.316	0.335	0.366	0.364	0.357	0.360	0.345	0.347	0.309	0.375	0.374	
	taud	2.631	2.218	2.321	2.279	2.365	2.447	2.471	2.518	2.435	2.320	2.747	2.567	
	Ebn at Noon	321	601	758	809	849	864	851	834	745	608	369	179	
	Edh at Noon	31	61	81	105	105	99	94	82	74	54	27	18	
All-Sky Solar Radiation	RadAvg	0.14	0.57	1.57	3.25	4.75	5.01	4.60	3.67	2.13	0.91	0.22	0.07	
	RadStd	0.02	0.10	0.22	0.39	0.47	0.61	0.38	0.26	0.21	0.09	0.04	0.00	

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+0.51	+1.04	+1.32	+0.64	N/A	N/A	-160	-193	+37	N/A	

Nomenclature: See separate page