

GRIMSEY AP, Iceland

WMO: 041650

Lat: 66.544N

Lon: 18.017W

Elev: 17

StdP: 101.12

Time Zone: 0.00 (E00)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-7.2	-5.8	-14.7	1.1	-4.7	-12.4	1.3	-4.1	18.6	-0.3	17.2	-0.8	7.6	30	0.908

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.4	14.8	11.5	13.5	10.7	12.4	10.0	12.0	14.3	11.2	13.0	10.4	11.9	4.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.6	8.0	12.9	10.0	7.6	12.0	9.4	7.4	11.3	34.3	14.5	32.2	13.1	30.3	12.0	16.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.6	13.0	DB	-8.6	17.9	1.6	1.5	-9.8	19.0	-10.7	19.9	-11.6	20.8	-12.8	21.9	(4)
(5)			WB	-9.9	13.5	1.5	1.4	-11.0	14.5	-11.8	15.3	-12.7	16.1	-13.7	17.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.9	0.9	0.5	0.3	1.8	4.0	7.1	8.9	8.9	7.4	4.2	1.9	1.0
	DBStd	4.19	2.66	2.81	2.87	2.96	2.74	2.46	2.14	1.97	2.69	2.83	2.92	3.06
	HDD10.0	2252	282	266	301	245	187	91	48	44	86	180	243	279
	HDD18.3	5253	541	499	559	494	445	336	292	291	328	438	493	538
	CDD10.0	39	0	0	0	0	1	5	14	12	8	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.6	7.5	7.6	7.6	6.4	5.7	4.7	5.0	5.3	6.2	7.2	7.7	8.2
Precipitation	PrecAvg	672	63	59	62	39	32	39	44	51	65	77	73	64
	PrecMax	1000	139	138	172	103	83	100	75	114	171	146	182	120
	PrecMin	413	10	0	5	5	1	12	19	7	11	14	25	8
	PrecStd	133	35	32	38	19	19	20	17	27	32	36	31	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.1	7.5	8.0	11.6	13.3	15.5	17.2	16.1	15.6	11.7	9.7	8.7
		MCWB	5.8	5.1	5.3	7.1	8.6	10.9	13.5	12.5	11.7	8.6	7.5	6.2
	2%	DB	6.6	6.3	6.1	8.9	11.1	13.5	14.9	14.1	13.4	10.2	7.6	7.2
		MCWB	4.4	4.1	4.1	6.1	7.8	10.1	12.0	11.7	10.6	7.7	5.8	5.3
	5%	DB	5.5	5.4	5.0	7.2	9.5	11.9	13.3	12.7	12.1	9.1	6.7	6.1
		MCWB	3.7	3.5	3.4	4.9	6.9	9.5	10.9	10.5	9.7	7.0	5.2	4.4
	10%	DB	4.4	4.5	3.9	6.0	8.0	10.7	12.0	11.7	11.1	8.1	6.0	5.3
		MCWB	3.0	2.9	2.4	3.8	6.0	8.6	10.2	9.7	9.0	6.5	4.7	3.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	5.5	5.5	7.7	8.9	11.9	14.0	13.0	12.2	8.9	7.6	6.6
		MCDB	7.9	7.1	7.5	10.9	12.2	14.0	17.0	15.2	15.2	10.7	9.3	8.1
	2%	WB	4.7	4.5	4.2	6.4	7.8	10.9	12.2	11.8	10.9	8.1	6.3	5.6
		MCDB	6.3	5.9	5.9	9.0	10.3	13.0	14.5	13.8	13.1	9.6	7.2	6.9
	5%	WB	3.9	3.8	3.5	5.1	7.0	9.8	11.2	10.8	10.0	7.4	5.5	4.8
		MCDB	5.2	5.1	4.9	7.1	9.1	11.7	12.9	12.4	11.7	8.7	6.4	5.9
	10%	WB	3.2	3.0	2.6	4.2	6.1	9.0	10.4	10.1	9.3	6.7	4.8	3.9
		MCDB	4.2	4.3	3.7	5.7	7.8	10.5	11.7	11.3	10.8	7.9	5.8	5.2
Mean Daily Temperature Range	5% DB	MDBR	3.2	3.2	3.4	3.6	3.7	3.7	3.5	3.4	3.5	3.1	3.3	3.3
		MCDBR	4.3	4.1	4.8	5.4	6.0	5.4	5.7	4.8	4.9	4.0	4.0	4.3
		MCWBR	3.6	3.4	4.0	3.7	3.5	3.5	3.5	3.1	3.2	3.1	3.6	3.8
	5% WB	MCDBR	3.9	3.9	4.7	5.5	5.5	4.7	5.3	4.5	4.6	3.7	3.6	4.0
		MCWBR	3.4	3.4	4.0	3.8	3.4	3.3	3.4	3.0	3.2	3.0	3.4	3.7
Clear-Sky Solar Irradiance	taub	0.369	0.296	0.318	0.347	0.350	0.343	0.345	0.340	0.329	0.299	0.361	0.374	
	taud	2.547	2.216	2.391	2.372	2.435	2.491	2.523	2.542	2.492	2.252	2.558	2.554	
	Ebn at Noon	188	546	748	813	851	867	854	821	736	527	179	32	
	Edh at Noon	19	50	70	91	95	92	87	77	64	46	17	7	
All-Sky Solar Radiation	RadAvg	0.05	0.35	1.20	2.73	4.08	4.96	4.18	3.12	1.74	0.57	0.10	0.00	
	RadStd	0.00	0.04	0.17	0.27	0.39	0.48	0.41	0.28	0.12	0.07	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		+0.36	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page