

KARAHNJUKAR, Iceland

WMO: 041760

Lat: 64.928N

Lon: 15.777W

Elev: 2096

StdP: 13.62

Time Zone: 0.00 (E00)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.6	4.9	-5.8	4.4	1.7	-1.0	5.6	5.4	53.1	29.4	48.8	33.3	8.4	230	0.986

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	60.1	50.7	57.2	49.2	54.4	47.7	52.1	58.1	50.2	55.6	48.6	53.2	12.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
48.8	55.2	53.5	47.1	51.7	51.8	45.6	48.7	50.2	22.1	58.4	21.1	55.7	20.1	53.5	58.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 43.5	37.8	32.3	-9.0	65.1	3.2	2.4	-11.3	66.8	-13.1	68.2	-14.9	69.6	-17.2	71.3		
(5)			-9.1	55.6	4.8	2.2	-12.6	57.2	-15.3	58.5	-18.0	59.7	-21.5	61.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	32.2	24.0	22.8	22.9	26.9	34.4	42.4	46.5	44.3	40.5	32.2	26.7	22.5
	DBStd	11.15	8.12	8.84	7.34	7.42	6.58	5.78	4.58	4.16	5.50	6.78	6.96	8.82
	HDD50	6522	807	762	839	692	485	235	129	183	285	553	699	853
	HDD65	11963	1272	1182	1304	1142	949	678	575	642	734	1018	1149	1318
	CDD50	35	0	0	0	0	0	8	19	6	2	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	14.3	16.9	16.0	16.6	14.3	13.1	10.4	10.7	11.5	14.7	14.8	15.5	16.6
Precipitation	PrecAvg	48.3	5.2	4.3	4.1	3.0	2.1	2.4	3.1	3.9	4.7	5.6	5.1	5.1
	PrecMax	82.4	12.5	9.9	7.0	9.1	3.8	5.7	7.4	7.9	10.5	10.7	18.6	9.3
	PrecMin	33.1	1.0	0.6	1.4	0.5	0.2	0.3	0.7	1.1	1.3	1.3	1.3	1.8
	PrecStd	8.9	2.4	1.9	1.6	1.8	0.8	1.1	1.8	1.7	2.0	2.4	3.5	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.4	41.4	41.3	45.5	56.2	61.8	64.8	61.6	57.0	48.5	43.9	42.6
		MCWB	38.5	36.2	38.0	41.2	47.1	50.5	53.0	51.5	48.2	44.5	40.4	38.1
	2%	DB	39.6	39.1	38.7	41.5	51.2	58.5	61.1	57.5	53.1	46.2	40.8	40.1
		MCWB	36.3	36.1	35.9	38.7	44.7	49.4	52.1	49.5	47.4	42.3	38.1	37.1
	5%	DB	37.5	37.0	36.7	39.0	47.3	55.6	58.0	54.0	50.5	44.0	38.7	37.8
		MCWB	34.8	34.8	34.2	36.4	42.5	47.8	50.0	47.7	45.9	41.0	36.5	35.5
	10%	DB	35.6	35.4	34.3	37.1	43.6	52.4	54.7	51.3	48.4	42.1	36.6	34.9
		MCWB	33.6	33.3	32.2	34.9	39.9	45.9	48.1	46.3	44.5	39.7	34.8	33.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.9	37.9	38.3	41.9	48.2	52.8	55.7	52.3	50.0	45.5	40.9	38.9
		MCDB	42.1	40.4	40.5	45.0	54.0	59.5	61.5	58.9	54.3	48.3	43.2	41.7
	2%	WB	36.7	36.5	36.3	39.1	45.1	50.2	53.2	50.4	48.1	43.2	38.9	37.4
		MCDB	39.3	38.6	38.4	41.3	50.4	56.9	58.7	55.9	51.9	45.4	40.7	39.9
	5%	WB	35.1	35.0	34.5	36.8	42.8	48.3	51.2	48.6	46.6	41.7	36.8	35.5
		MCDB	37.1	37.0	36.6	38.6	46.7	54.3	56.7	53.1	49.9	43.8	38.3	37.5
	10%	WB	33.7	33.4	32.3	35.0	40.3	46.4	49.2	46.9	45.1	39.9	35.2	33.3
		MCDB	35.6	35.5	34.2	36.7	43.7	51.9	53.8	50.4	48.0	42.1	36.7	34.8
Mean Daily Temperature Range	5% DB	MDBR	10.6	10.8	10.8	11.0	9.3	11.5	11.6	10.6	9.0	8.0	8.9	11.3
		MCDBR	11.1	11.3	13.8	11.9	14.2	17.2	17.5	15.5	12.2	10.6	10.8	13.6
		MCWBR	10.2	10.3	12.3	9.8	9.4	10.1	10.7	9.5	8.9	9.6	10.0	12.4
	5% WB	MCDBR	10.1	11.3	13.7	10.8	13.8	16.0	15.3	14.0	10.9	10.4	10.3	13.3
		MCWBR	9.5	10.7	12.4	9.2	9.7	9.9	10.4	9.3	8.4	9.3	9.8	12.4
Clear-Sky Solar Irradiance	taub	0.221	0.270	0.301	0.330	0.334	0.328	0.332	0.321	0.309	0.282	0.206	0.213	
	taud	1.814	2.033	2.076	2.054	2.176	2.328	2.351	2.386	2.322	2.100	1.860	1.820	
	Ebn at Noon	77	190	241	262	275	280	275	268	242	180	82	17	
	Edh at Noon	9	20	31	40	39	35	33	29	24	18	8	3	
All-Sky Solar Radiation	RadAvg	37	188	600	1181	1615	1743	1494	1145	660	270	64	12	
	RadStd	3	25	43	99	111	142	101	81	46	23	5	1	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)	+0.77	+1.87	+2.03	N/A	N/A	N/A	-212	N/A	N/A	N/A

Nomenclature: See separate page