

KARAHNJUKAR, Iceland

WMO: 041760

Lat: 64.928N

Lon: 15.777W

Elev: 639

StdP: 93.88

Time Zone: 0.00 (E00)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-17.5	-15.1	-21.0	0.6	-16.8	-18.3	0.8	-14.8	23.7	-1.5	21.8	0.7	3.7	230	0.986

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.5	15.6	10.4	14.0	9.6	12.5	8.7	11.2	14.5	10.1	13.1	9.2	11.8	5.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.3	7.9	12.0	8.4	7.4	11.0	7.5	7.0	10.1	33.6	14.7	31.1	13.1	28.9	11.9	14.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.4	16.9	14.4	DB	-22.8	18.4	1.8	1.3	-24.0	19.3	-25.1	20.1	-26.1	20.9	-27.3	21.8	(4)
(5)			WB	-22.8	13.1	2.6	1.2	-24.8	14.0	-26.3	14.7	-27.8	15.4	-29.7	16.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.1	-4.5	-5.1	-5.0	-2.8	1.3	5.8	8.0	6.8	4.7	0.1	-2.9	-5.3	(6)	
	DBStd	6.19	4.51	4.91	4.08	4.12	3.66	3.21	2.54	2.31	3.05	3.77	3.87	4.90	(7)	
	HDD10.0	3623	448	423	466	384	269	131	72	102	158	307	388	474	(8)	
	HDD18.3	6646	707	657	724	634	527	377	319	357	408	566	638	732	(9)	
	CDD10.0	19	0	0	0	0	0	4	11	3	1	0	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.4	7.6	7.1	7.4	6.4	5.8	4.7	4.8	5.1	6.6	6.6	6.9	7.4	(14)	
(15) Precipitation	PrecAvg	1227	132	108	103	75	54	62	80	98	119	142	130	129	(15)	
	PrecMax	2094	317	251	177	231	96	144	187	200	267	273	472	235	(16)	
	PrecMin	841	25	16	36	13	4	7	17	27	32	34	32	46	(17)	
	PrecStd	225	60	47	40	46	21	29	45	43	50	60	88	52	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.8	5.2	5.2	7.5	13.4	16.5	18.2	16.5	13.9	9.2	6.6	5.9	(19)	
		MCWB	3.6	2.3	3.3	5.1	8.4	10.3	11.7	10.8	9.0	7.0	4.7	3.4	(20)	
	2%	DB	4.2	3.9	3.7	5.3	10.7	14.7	16.2	14.2	11.7	7.9	4.9	4.5	(21)	
		MCWB	2.4	2.3	2.2	3.7	7.0	9.7	11.2	9.7	8.6	5.7	3.4	2.9	(22)	
	5%	DB	3.1	2.8	2.6	3.9	8.5	13.1	14.4	12.2	10.3	6.7	3.7	3.2	(23)	
		MCWB	1.6	1.5	1.2	2.5	5.8	8.8	10.0	8.7	7.7	5.0	2.5	2.0	(24)	
	10%	DB	2.0	1.9	1.3	2.8	6.4	11.3	12.6	10.7	9.1	5.6	2.6	1.6	(25)	
		MCWB	0.9	0.7	0.1	1.6	4.4	7.7	8.9	7.9	6.9	4.3	1.5	0.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	3.3	3.5	5.5	9.0	11.6	13.2	11.3	10.0	7.5	4.9	3.8	(27)	
		MCDB	5.6	4.7	4.7	7.2	12.2	15.3	16.4	14.9	12.4	9.0	6.2	5.4	(28)	
	2%	WB	2.6	2.5	2.4	4.0	7.3	10.1	11.8	10.2	9.0	6.2	3.9	3.0	(29)	
		MCDB	4.0	3.7	3.6	5.2	10.2	13.8	14.8	13.3	11.0	7.4	4.9	4.4	(30)	
	5%	WB	1.7	1.7	1.4	2.7	6.0	9.0	10.7	9.2	8.1	5.4	2.7	1.9	(31)	
		MCDB	2.8	2.8	2.5	3.7	8.1	12.4	13.7	11.7	9.9	6.5	3.5	3.1	(32)	
	10%	WB	1.0	0.8	0.2	1.7	4.6	8.0	9.6	8.3	7.3	4.4	1.8	0.7	(33)	
		MCDB	2.0	1.9	1.2	2.6	6.5	11.0	12.1	10.2	8.9	5.6	2.6	1.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.9	6.0	6.0	6.1	5.2	6.4	6.5	5.9	5.0	4.4	4.9	6.3	(35)	
		MCDBR	6.2	6.3	7.7	6.6	7.9	9.6	9.7	8.6	6.8	5.9	6.0	7.5	(36)	
		MCWBR	5.7	5.7	6.8	5.4	5.2	5.6	5.9	5.3	4.9	5.3	5.6	6.9	(37)	
	5% WB	MCDBR	5.6	6.3	7.6	6.0	7.6	8.9	8.5	7.8	6.0	5.8	5.7	7.4	(38)	
		MCWBR	5.3	6.0	6.9	5.1	5.4	5.5	5.8	5.1	4.7	5.2	5.5	6.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.221	0.270	0.301	0.330	0.334	0.328	0.332	0.321	0.309	0.282	0.206	0.213	(40)	
	taud		1.814	2.033	2.076	2.054	2.176	2.328	2.351	2.386	2.322	2.100	1.860	1.820	(41)	
	Ebn at Noon		242	598	759	826	867	884	868	844	763	569	257	54	(42)	
	Edh at Noon		27	64	97	126	123	109	104	91	77	58	24	9	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.12	0.59	1.89	3.72	5.09	5.50	4.71	3.61	2.08	0.85	0.20	0.04	(44)	
	RadStd		0.01	0.08	0.14	0.31	0.35	0.45	0.32	0.26	0.15	0.07	0.02	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (9 neighbors)	+0.43	+1.04	+1.13	N/A	N/A	N/A	-118	N/A	N/A	N/A	(47)

Nomenclature: See separate page