

HALL LAND, Greenland

WMO: 042070

Lat: 81.683N

Lon: 59.933W

Elev: 344

StdP: 14.51

Time Zone: -3.00 (GRL)

Period: 83-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-50.2	-48.1	-53.1	0.2	-49.6	-51.1	0.3	-47.8	40.1	-6.4	33.3	-12.8	3.8	350	1.203

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	53.6	46.1	50.8	44.1	48.2	42.7	46.6	51.5	44.6	50.6	42.6	47.8	10.7	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
42.9	41.3	50.1	39.6	36.3	46.2	37.8	33.8	43.8	18.6	51.5	17.5	50.9	16.5	48.1	60.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.9	25.6	22.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	-53.5	49.1	4.5	2.6	-56.7	51.0	-59.3	52.5	-61.8	54.0	-65.1	55.9	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.0	-31.5	-33.0	-29.9	-13.4	11.1	33.2	41.3	35.9	14.8	-8.8	-18.3	-27.5	
	DBStd	28.78	9.45	9.72	11.34	13.03	9.46	6.43	5.09	6.53	11.88	10.51	13.90	10.04	
	HDD50	18982	2526	2325	2476	1901	1206	504	274	438	1056	1822	2050	2404	
	HDD65	24451	2991	2745	2941	2351	1671	954	734	902	1506	2287	2500	2869	
	CDD50	6	0	0	0	0	0	0	4	2	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	8.9	7.6	7.2	6.8	8.0	10.7	12.3	12.5	10.8	8.3	7.3	7.4	7.6	
Precipitation	PrecAvg	5.4	0.3	0.3	0.3	0.4	0.3	0.4	0.9	0.9	0.6	0.4	0.4	0.4	
	PrecMax	8.0	0.6	0.7	0.7	1.2	0.9	0.9	2.2	2.1	1.5	0.8	0.8	1.2	
	PrecMin	3.2	0.1	0.0	0.1	0.0	0.1	0.0	0.2	0.2	0.2	0.0	0.0	0.2	
	PrecStd	1.1	0.1	0.2	0.2	0.3	0.2	0.2	0.5	0.5	0.3	0.2	0.2	0.2	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.8	-0.1	14.3	45.5	32.9	53.2	57.1	56.5	46.9	20.5	44.5	7.6	
		MCWB	-2.0	-0.5	12.8	43.3	30.3	45.2	47.4	48.2	45.6	20.2	42.7	7.1	
	2%	DB	-7.6	-6.5	2.0	25.4	29.0	49.8	54.2	51.8	40.0	13.8	26.7	-1.5	
		MCWB	-8.0	-6.8	1.3	23.7	27.6	42.7	46.0	45.0	37.4	13.1	24.9	-2.0	
	5%	DB	-12.8	-14.4	-6.9	10.3	26.4	46.5	51.9	48.8	35.1	10.0	14.5	-7.2	
		MCWB	-13.1	-14.7	-7.2	9.7	25.0	41.2	44.6	43.9	33.1	9.5	13.6	-7.6	
	10%	DB	-17.6	-19.2	-13.4	3.2	23.8	42.1	49.7	44.8	30.1	6.8	1.3	-12.7	
		MCWB	-17.7	-19.3	-13.8	2.8	22.5	38.5	43.3	40.2	28.5	6.4	0.6	-12.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-2.2	-0.8	13.1	43.4	30.6	45.7	49.1	50.8	46.1	19.9	40.3	6.8
			MCDB	-1.8	-0.6	14.7	45.6	32.7	52.7	54.8	54.7	46.5	20.1	42.3	7.5
2%		WB	-7.9	-6.8	1.4	23.8	27.6	43.2	46.7	46.7	37.4	13.1	24.2	-2.0	
		MCDB	-7.6	-6.6	2.1	25.3	28.7	49.4	53.0	50.8	39.9	13.6	25.8	-1.6	
5%		WB	-13.1	-14.6	-7.3	9.6	25.1	41.0	44.9	43.3	32.7	9.5	13.3	-7.7	
		MCDB	-12.8	-14.5	-7.0	10.2	26.2	46.4	51.2	49.3	35.1	9.9	14.1	-7.2	
10%		WB	-17.8	-19.4	-13.7	2.8	22.5	38.7	43.4	40.4	28.6	6.4	0.5	-12.9	
		MCDB	-17.6	-19.2	-13.3	3.2	23.6	42.1	49.0	44.5	29.7	6.8	1.0	-12.7	
Mean Daily Temperature Range		5% DB	MDBR	10.1	9.9	10.7	11.7	8.9	6.3	6.9	7.2	10.1	11.8	11.5	10.4
			MCDBR	14.2	14.6	15.4	18.3	10.8	11.4	9.9	10.8	9.8	13.7	24.5	16.8
	MCWBR		14.2	14.6	15.1	18.0	9.6	8.1	6.0	6.7	7.4	13.6	19.9	16.5	
	5% WB	MCDBR	14.3	15.1	15.3	18.4	10.8	10.2	9.6	10.6	8.2	13.5	20.6	16.8	
		MCWBR	14.2	15.1	14.9	18.1	9.9	7.3	6.3	6.8	7.2	13.4	19.9	16.4	
Clear-Sky Solar Irradiance	taub	N/A	N/A	0.185	0.259	0.277	0.309	0.308	0.301	0.216	N/A	N/A	N/A	N/A	
	taud	N/A	N/A	1.995	2.099	2.170	2.226	2.360	2.310	2.081	N/A	N/A	N/A	N/A	
	Ebn at Noon	0	0	167	234	259	255	250	221	154	0	0	0	0	
	Edh at Noon	0	0	11	25	30	30	25	21	11	0	0	0	0	
All-Sky Solar Radiation	RadAvg	0	0	195	1114	2097	2364	1979	1148	344	0	0	0	0	
	RadStd	0	0	17	51	102	92	130	100	19	0	0	0	0	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page