

KITSISSORSUIT EDDERFUGLEOER, Greenland

WMO: 042080

Lat: 74.033N

Lon: 57.817W

Elev: 131

StdP: 14.63

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-29.8	-25.9	-34.4	0.8	-29.5	-29.6	1.0	-25.2	46.5	12.9	36.8	5.8	3.8	330	1.087

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	50.0	45.8	48.3	44.9	46.8	44.1	47.1	48.7	45.6	47.3	44.4	46.2	10.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
46.0	46.0	47.4	44.5	43.6	46.0	43.2	41.4	44.9	18.7	48.9	18.0	47.5	17.4	46.3	52.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 37.5	31.7	27.5	DB	-27.0	53.3	5.6	2.2	-31.0	54.8	-34.3	56.1	-37.4	57.3	-41.5	58.9	(4)
(5)			WB	-29.0	47.6	7.5	2.4	-34.4	49.3	-38.8	50.7	-43.1	52.0	-48.5	53.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	-1.0	-5.7	-5.9	6.8	23.9	34.3	41.5	41.9	35.2	27.3	19.0	9.2	
	DBStd	19.07	12.10	12.61	12.33	10.33	6.89	4.82	4.49	3.44	4.13	4.79	7.21	11.19	
	HDD50	11308	1582	1561	1731	1297	808	471	264	250	444	703	931	1266	
	HDD65	16783	2047	1981	2196	1747	1273	921	729	715	894	1168	1381	1731	
	CDD50	1	0	0	0	0	0	0	1	0	0	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	12.2	8.8	8.2	9.3	12.0	11.7	12.1	11.9	12.2	14.4	16.4	16.8	12.8	
Precipitation	PrecAvg	12.4	0.7	0.5	0.4	0.4	0.5	0.9	1.4	1.9	1.5	1.8	1.4	1.0	
	PrecMax	19.7	2.0	1.3	1.6	1.1	1.4	2.6	2.8	3.9	2.4	5.5	5.0	2.7	
	PrecMin	7.5	0.1	0.1	0.1	0.0	0.2	0.2	0.6	0.7	0.7	0.5	0.3	0.3	
	PrecStd	3.3	0.5	0.3	0.3	0.3	0.3	0.5	0.6	0.8	0.5	1.1	0.9	0.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	31.0	31.3	34.4	41.0	50.3	52.8	51.7	49.0	39.9	37.4	34.1	
		MCWB	31.5	28.9	30.2	32.2	37.6	43.3	47.5	47.1	46.2	36.1	35.4	31.6	
	2%	DB	28.0	24.7	24.9	31.0	36.8	46.3	50.4	49.5	45.1	37.6	33.3	30.9	
		MCWB	25.5	23.2	23.7	29.7	34.6	42.5	46.3	45.7	42.6	35.0	30.9	29.0	
	5%	DB	22.8	17.7	17.9	26.8	34.1	43.5	48.7	47.9	42.0	35.6	30.6	28.0	
		MCWB	21.1	17.1	16.7	25.6	32.7	40.9	45.1	44.9	39.2	33.6	29.0	26.2	
	10%	DB	15.6	11.1	10.5	22.0	32.1	40.9	47.3	46.5	40.5	33.3	28.6	24.1	
		MCWB	14.2	10.3	9.8	21.1	31.0	38.9	44.4	43.9	38.1	31.3	27.1	22.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.1	29.2	30.6	33.0	37.8	44.6	49.8	48.6	47.0	37.2	35.6	32.4
			MCDB	32.0	31.1	31.7	34.0	40.0	47.7	51.0	50.1	49.3	38.9	37.1	34.0
2%		WB	25.3	23.3	24.6	29.9	34.8	42.9	47.5	46.9	42.9	35.3	31.3	29.4	
		MCDB	27.5	24.8	25.9	31.0	36.4	45.6	49.1	48.4	44.3	37.1	32.6	30.6	
5%		WB	20.6	17.1	18.0	25.8	32.9	41.2	45.9	45.5	40.0	33.7	29.2	26.3	
		MCDB	22.4	17.8	19.1	26.9	34.1	43.6	47.6	47.1	41.4	35.6	30.5	27.8	
10%		WB	14.1	10.4	10.4	21.4	31.2	39.1	44.8	44.3	38.3	31.8	27.1	22.6	
		MCDB	15.3	11.2	11.1	22.4	32.0	40.7	46.6	45.9	40.0	33.3	28.6	24.3	
Mean Daily Temperature Range	5% DB	MDBR	8.8	9.0	10.4	10.6	6.4	5.3	5.2	4.1	3.4	3.5	4.7	7.0	
		MCDBR	13.9	18.2	16.3	13.2	9.2	9.1	7.3	6.0	4.3	4.9	6.2	9.6	
		MCWBR	12.9	17.0	15.2	12.0	7.3	5.8	4.4	4.0	3.7	4.3	5.8	8.8	
	5% WB	MCDBR	14.5	18.1	16.0	12.6	8.4	8.2	6.3	5.1	3.9	4.7	6.2	9.6	
		MCWBR	13.6	16.9	15.3	11.6	6.9	5.7	4.5	4.1	3.8	4.4	6.0	9.1	
Clear-Sky Solar Irradiance	taub	N/A	0.145	0.223	0.277	0.313	0.312	0.311	0.303	0.267	0.345	N/A	N/A		
	taud	N/A	1.877	2.150	2.078	2.127	2.423	2.564	2.567	2.498	2.880	N/A	N/A		
	Ebn at Noon	0	130	233	258	265	274	271	257	225	109	0	0		
	Edh at Noon	0	7	19	32	36	29	24	21	15	6	0	0		
All-Sky Solar Radiation	RadAvg	0	49	484	1298	1892	1991	1682	1026	475	90	0	0		
	RadStd	0	4	25	80	100	168	165	136	30	9	0	0		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page