

KITSISSORSUIT EDDERFUGLEOER, Greenland

WMO: 042080

Lat: 74.033N

Lon: 57.817W

Elev: 40

StdP: 100.85

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-34.3	-32.1	-36.9	0.1	-34.2	-34.2	0.1	-31.8	20.8	-10.6	16.4	-14.6	1.7	330	1.087

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.3	10.0	7.7	9.1	7.2	8.2	6.7	8.4	9.3	7.6	8.5	6.9	7.9	4.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.8	6.6	8.6	7.0	6.2	7.8	6.2	5.9	7.2	25.7	9.4	24.0	8.6	22.6	8.0	11.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.2	12.3	-32.8	11.8	3.1	1.2	-35.0	12.7	-36.8	13.4	-38.6	14.1	-40.8	15.0		
(5)			-33.9	8.7	4.2	1.3	-36.9	9.6	-39.4	10.4	-41.7	11.1	-44.7	12.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-7.2	-18.4	-21.0	-21.0	-14.0	-4.5	1.3	5.3	5.5	1.8	-2.6	-7.2	-12.7	(6)
(7)		DBStd	10.60	6.72	7.01	6.85	5.74	3.83	2.68	2.49	1.91	2.30	2.66	4.00	6.22	(7)
(8)		HDD10.0	6282	879	867	962	721	449	262	147	139	247	391	517	703	(8)
(9)		HDD18.3	9324	1137	1101	1220	971	707	512	405	397	497	649	767	962	(9)
(10)		CDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.5	3.9	3.7	4.2	5.4	5.2	5.4	5.3	5.5	6.4	7.3	7.5	5.7	(14)
(15)	Precipitation	PrecAvg	316	19	13	10	11	13	23	35	49	37	46	35	25	(15)
(16)		PrecMax	501	50	34	40	29	36	65	71	100	60	139	126	69	(16)
(17)		PrecMin	191	3	3	2	1	4	6	14	17	17	12	8	7	(17)
(18)		PrecStd	84	12	8	8	7	8	12	15	21	13	28	24	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.0	-0.6	-0.4	1.3	5.0	10.2	11.5	11.0	9.4	4.4	3.0	1.2	(19)
(20)			MCWB	-0.3	-1.7	-1.0	0.1	3.1	6.3	8.6	8.4	7.9	2.3	1.9	-0.2	(20)
(21)		2%	DB	-2.2	-4.0	-4.0	-0.5	2.6	8.0	10.2	9.7	7.3	3.1	0.7	-0.6	(21)
(22)			MCWB	-3.6	-4.9	-4.6	-1.3	1.4	5.8	7.9	7.6	5.9	1.6	-0.6	-1.6	(22)
(23)		5%	DB	-5.1	-8.0	-7.8	-2.9	1.2	6.4	9.3	8.8	5.5	2.0	-0.8	-2.2	(23)
(24)			MCWB	-6.1	-8.3	-8.5	-3.6	0.4	5.0	7.3	7.2	4.0	0.9	-1.7	-3.2	(24)
(25)		10%	DB	-9.1	-11.6	-12.0	-5.6	0.0	4.9	8.5	8.0	4.7	0.7	-1.9	-4.4	(25)
(26)			MCWB	-9.9	-12.1	-12.4	-6.1	-0.6	3.9	6.9	6.6	3.4	-0.4	-2.7	-5.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.5	-1.5	-0.8	0.6	3.2	7.0	9.9	9.2	8.3	2.9	2.0	0.2	(27)
(28)			MCDWB	0.0	-0.5	-0.1	1.1	4.5	8.7	10.6	10.1	9.6	3.8	2.8	1.1	(28)
(29)		2%	WB	-3.7	-4.9	-4.1	-1.2	1.6	6.1	8.6	8.3	6.0	1.8	-0.4	-1.4	(29)
(30)			MCDWB	-2.5	-4.0	-3.4	-0.6	2.4	7.5	9.5	9.1	6.8	2.8	0.3	-0.8	(30)
(31)		5%	WB	-6.4	-8.3	-7.8	-3.5	0.5	5.1	7.7	7.5	4.4	0.9	-1.6	-3.2	(31)
(32)			MCDWB	-5.3	-7.9	-7.2	-2.8	1.1	6.4	8.7	8.4	5.2	2.0	-0.8	-2.3	(32)
(33)		10%	WB	-9.9	-12.0	-12.0	-5.9	-0.4	3.9	7.1	6.8	3.5	-0.1	-2.7	-5.2	(33)
(34)			MCDWB	-9.3	-11.6	-11.6	-5.4	0.0	4.8	8.1	7.7	4.5	0.7	-1.9	-4.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	5.0	5.8	5.9	3.6	2.9	2.9	2.3	1.9	1.9	2.6	3.9	(35)
(36)			MCDBR	7.7	10.1	9.1	7.3	5.1	5.0	4.0	3.4	2.4	2.7	3.4	5.3	(36)
(37)			MCWBR	7.2	9.4	8.4	6.7	4.0	3.2	2.5	2.2	2.1	2.4	3.2	4.9	(37)
(38)		5% WB	MCDWB	8.0	10.0	8.9	7.0	4.7	4.6	3.5	2.8	2.2	2.6	3.4	5.3	(38)
(39)			MCWBR	7.6	9.4	8.5	6.5	3.8	3.2	2.5	2.3	2.1	2.4	3.3	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.145	0.223	0.277	0.313	0.312	0.311	0.303	0.267	0.345	N/A	N/A	(40)	
(41)		taud	N/A	1.877	2.150	2.078	2.127	2.423	2.564	2.567	2.498	2.880	N/A	N/A	(41)	
(42)		Ebn at Noon	0	410	734	812	835	863	855	810	708	345	0	0	(42)	
(43)		Edh at Noon	0	22	60	101	114	90	75	65	46	19	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.15	1.52	4.09	5.97	6.28	5.30	3.23	1.50	0.28	0.00	0.00	(44)	
(45)		RadStd	0.00	0.01	0.08	0.25	0.32	0.53	0.52	0.43	0.10	0.03	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page