

AASIAAT EGEDESMINDE, GreenlandWMO: **042200**Lat: **68.7081N**Lon: **52.8517W**Elev: **135**StdP: **14.62**Time Zone: **-3.00 (GRL)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-18.3	-14.3	-24.3	1.4	-17.8	-19.8	1.9	-13.6	36.1	17.2	30.4	15.6	5.5	190	0.910

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	53.8	46.9	51.9	46.3	50.2	45.6	48.4	51.5	47.2	50.5	46.1	49.4	7.0	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
46.8	47.5	48.6	45.2	44.8	47.6	43.8	42.4	46.8	19.4	51.6	18.8	50.7	18.2	49.6	56.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.0	24.6	21.0	-17.1	60.1	7.9	3.8	-22.7	62.8	-27.3	65.0	-31.8	67.1	-37.5	69.9		
(5)			-17.5	50.8	7.7	2.2	-23.0	52.4	-27.5	53.7	-31.8	55.0	-37.4	56.6	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.3	12.4	7.3	7.0	19.0	31.2	40.0	44.7	43.7	37.8	29.4	23.3	18.6	(6)
(7)		DBStd	15.10	10.24	12.17	12.20	9.19	5.45	4.87	4.52	3.34	3.69	5.26	6.32	7.38	(7)
(8)		HDD50	8653	1167	1196	1333	929	584	301	173	195	365	638	800	972	(8)
(9)		HDD65	14118	1632	1616	1798	1379	1049	750	630	659	815	1103	1250	1437	(9)
(10)		CDD50	10	0	0	0	0	0	1	8	1	0	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	9.2	11.5	10.1	9.3	8.8	7.8	7.4	6.9	6.8	8.6	10.1	11.2	12.0	(14)
(15)	Precipitation	PrecAvg	11.6	0.9	0.6	0.7	0.7	0.6	0.8	0.9	1.5	1.3	1.2	1.3	1.1	(15)
(16)		PrecMax	17.8	2.5	2.6	3.9	1.9	2.0	3.1	2.3	5.2	5.1	3.6	3.8	2.8	(16)
(17)		PrecMin	5.7	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.2	(17)
(18)		PrecStd	2.8	0.6	0.6	0.6	0.5	0.5	0.7	0.6	1.0	1.1	0.8	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	37.0	34.8	39.8	47.4	54.8	58.0	54.6	48.9	45.3	40.4	39.4	(19)
(20)			MCWB	32.1	31.0	32.7	34.8	40.5	45.6	48.6	47.5	42.7	38.6	35.5	33.1	(20)
(21)		2%	DB	32.0	31.5	30.6	36.1	43.2	51.3	54.9	51.7	45.6	40.2	37.2	35.1	(21)
(22)			MCWB	29.3	28.6	28.5	32.7	38.8	44.9	47.6	46.3	41.4	37.0	33.3	31.7	(22)
(23)		5%	DB	29.1	27.9	27.8	33.3	40.4	49.3	53.0	50.1	43.9	37.7	34.6	31.7	(23)
(24)			MCWB	26.6	25.5	26.0	31.2	36.9	43.9	46.8	45.8	40.6	35.2	32.1	29.1	(24)
(25)		10%	DB	26.1	23.7	24.1	31.1	37.9	47.2	51.3	48.6	42.6	36.0	32.3	28.6	(25)
(26)			MCWB	24.0	21.6	22.3	29.4	35.2	42.8	46.4	45.1	39.9	33.7	30.3	26.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	33.2	32.4	33.0	35.7	41.5	47.5	50.8	49.4	44.2	40.0	36.9	34.7	(27)
(28)			MDCB	35.1	35.5	34.5	38.9	46.3	51.6	53.9	51.2	46.6	42.6	39.9	38.2	(28)
(29)		2%	WB	29.4	28.7	28.8	33.2	39.1	45.7	49.2	47.6	42.6	37.4	34.1	31.8	(29)
(30)			MDCB	31.5	31.4	30.3	35.2	42.7	50.0	52.4	49.9	44.3	39.8	36.1	34.9	(30)
(31)		5%	WB	26.7	25.5	25.9	31.4	37.2	44.4	47.9	46.5	41.4	35.7	32.2	29.3	(31)
(32)			MDCB	28.8	27.9	27.6	33.3	39.6	48.5	51.4	49.0	43.1	37.4	34.2	31.5	(32)
(33)		10%	WB	24.0	21.5	22.3	29.3	35.6	43.0	46.9	45.6	40.3	34.0	30.4	26.5	(33)
(34)			MDCB	26.1	23.6	24.1	31.1	37.6	46.9	50.6	48.0	42.2	35.7	32.5	28.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.0	9.0	8.9	8.6	6.8	7.7	7.9	6.3	5.0	5.1	6.2	6.9	(35)
(36)			MCDBR	10.2	12.8	11.3	11.2	9.6	11.0	10.5	8.7	6.6	7.0	8.8	8.9	(36)
(37)			MCWBR	8.7	11.2	10.5	9.2	6.3	6.2	5.8	5.3	4.7	5.9	7.7	7.5	(37)
(38)		5% WB	MCDBR	9.9	12.7	11.3	10.4	8.9	10.4	9.4	8.0	5.9	6.6	8.4	8.9	(38)
(39)			MCWBR	8.8	11.4	10.6	8.9	6.3	6.5	6.1	5.5	4.8	6.0	7.8	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.214	0.256	0.308	0.327	0.328	0.329	0.327	0.288	0.238	0.353	N/A	(40)	
(41)		taud	N/A	2.126	2.271	2.230	2.407	2.512	2.534	2.526	2.557	2.236	2.858	N/A	(41)	
(42)		Ebn at Noon	N/A	189	251	264	274	278	273	260	244	174	44	0	(42)	
(43)		Edh at Noon	N/A	13	22	31	30	28	27	24	17	11	3	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6	124	580	1214	1670	1855	1685	1135	626	204	21	0	(44)	
(45)		RadStd	1	20	56	130	120	161	166	86	54	17	2	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.73	+5.71	N/A	+0.99	+0.70	+1.49	-531	-547	N/A	N/A
(47) Regional (3 neighbors)		+1.80	+5.92	N/A	+1.26	N/A	N/A	-531	-547	N/A	N/A

Nomenclature: See separate page