

KITSISSUT ATTU, Greenland

WMO: 042280

Lat: 67.784N

Lon: 53.965W

Elev: 12

StdP: 101.18

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-23.9	-22.1	-26.2	0.3	-23.8	-24.0	0.4	-21.9	18.5	-7.6	15.4	-9.1	5.2	340	1.015

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.3	9.0	7.2	8.0	6.7	7.2	6.1	7.6	8.6	6.9	7.7	6.3	7.0	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
6.9	6.2	7.9	6.3	5.9	7.2	5.7	5.7	6.6	24.1	8.7	22.5	7.8	21.3	7.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.0	14.1	12.3	-23.7	12.0	2.9	1.5	-25.7	13.1	-27.4	14.0	-29.0	14.8	-31.1	15.9		
(5)			-23.7	8.9	2.7	1.3	-25.7	9.8	-27.3	10.5	-28.8	11.2	-30.7	12.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.9	-9.9	-12.0	-11.6	-6.6	-1.1	2.0	4.6	5.5	3.6	-0.1	-3.5	-6.6	(6)	
	DBStd	7.09	5.36	6.03	5.84	4.49	2.35	1.86	1.94	1.47	1.64	2.49	3.01	3.91	(7)	
	HDD10.0	4722	617	617	669	499	344	241	167	141	193	313	405	516	(8)	
	HDD18.3	7764	876	851	927	749	603	491	426	399	443	572	655	774	(9)	
	CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.8	6.2	5.7	5.9	6.1	5.2	5.0	4.8	5.0	5.7	6.2	7.1	6.9	(14)	
(15) Precipitation	PrecAvg	555	50	29	28	31	28	30	39	58	64	61	70	67	(15)	
	PrecMax	787	162	62	72	86	67	76	78	130	149	128	151	162	(16)	
	PrecMin	310	2	7	2	5	3	6	12	22	20	14	17	21	(17)	
	PrecStd	115	34	16	19	20	17	18	18	28	26	28	35	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.2	2.9	2.5	4.1	5.1	9.3	11.0	10.5	7.9	6.6	5.0	3.0	(19)	
		MCWB	0.4	0.7	1.0	1.4	3.0	7.4	7.9	8.3	5.7	4.3	3.2	1.8	(20)	
	2%	DB	0.8	0.6	0.7	1.6	3.3	6.5	9.0	9.1	6.7	5.0	2.9	1.5	(21)	
		MCWB	-0.5	-0.9	-0.6	0.5	2.2	4.8	7.1	7.5	5.5	3.8	1.6	0.5	(22)	
	5%	DB	-1.4	-1.2	-0.9	0.5	2.3	5.2	8.0	8.2	6.2	4.0	1.9	0.1	(23)	
		MCWB	-2.4	-2.0	-1.9	-0.4	1.4	4.1	6.6	6.9	5.0	2.8	0.9	-0.9	(24)	
	10%	DB	-3.1	-3.7	-3.0	-0.7	1.7	4.4	7.1	7.4	5.6	3.1	0.7	-1.4	(25)	
		MCWB	-4.0	-4.6	-3.8	-1.4	0.9	3.5	6.0	6.4	4.5	2.0	-0.2	-2.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.4	1.0	1.3	2.0	3.3	7.4	8.6	8.8	6.6	4.9	3.7	2.3	(27)	
		MCDB	2.0	2.7	2.2	3.2	4.7	9.1	10.0	9.7	7.1	5.6	4.8	2.9	(28)	
	2%	WB	-0.6	-0.7	-0.6	0.7	2.4	5.0	7.5	7.9	5.8	3.8	1.8	0.8	(29)	
		MCDB	0.6	0.4	0.4	1.4	3.2	5.9	8.7	8.6	6.4	4.8	2.5	1.5	(30)	
	5%	WB	-2.2	-2.1	-1.8	-0.3	1.6	4.2	6.7	7.2	5.2	3.0	0.9	-0.8	(31)	
		MCDB	-1.3	-1.1	-0.8	0.4	2.2	5.0	7.7	7.9	5.8	3.9	1.8	0.0	(32)	
	10%	WB	-3.9	-4.6	-3.9	-1.4	1.1	3.6	6.2	6.6	4.7	2.1	-0.1	-2.2	(33)	
		MCDB	-3.3	-3.8	-3.1	-0.7	1.5	4.3	6.9	7.2	5.4	2.9	0.7	-1.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	4.4	4.0	3.6	2.6	2.6	2.8	2.3	2.0	2.2	2.8	3.4	(35)	
		MCDBR	4.9	7.0	4.8	4.4	3.5	3.9	4.1	3.6	2.5	2.9	4.1	4.5	(36)	
		MCWBR	4.4	5.9	4.2	3.8	2.6	2.7	2.7	2.3	2.0	2.6	3.8	4.2	(37)	
	5% WB	MCDBR	4.7	6.6	4.7	4.4	3.2	3.6	3.8	3.2	2.3	2.8	4.1	4.2	(38)	
		MCWBR	4.4	5.7	4.2	3.9	2.6	2.6	2.6	2.3	2.0	2.4	4.0	3.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.168	0.216	0.251	0.309	0.328	0.329	0.326	0.330	0.296	0.253	0.352	N/A	(40)	
	taud		1.927	2.168	2.297	2.233	2.408	2.505	2.547	2.541	2.548	2.252	2.841	N/A	(41)	
	Ebn at Noon		154	634	816	840	868	877	869	825	770	558	193	0	(42)	
	Edh at Noon		9	43	70	101	95	89	83	75	58	40	14	0	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.03	0.46	1.93	3.81	4.99	5.49	5.03	3.40	1.95	0.65	0.08	0.00	(44)	
	RadStd		0.00	0.07	0.18	0.42	0.37	0.53	0.54	0.27	0.19	0.06	0.01	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+0.91	N/A	N/A	+0.82	N/A	N/A	N/A	N/A	+8	N/A

Nomenclature: See separate page