

SIORALIK, Greenland

WMO: 042420

Lat: 65.013N

Lon: 52.529W

Elev: 46

StdP: 14.67

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.0	1.8	-9.3	3.3	-0.9	-5.7	4.1	3.0	47.3	29.9	40.9	23.3	15.5	60	0.973

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	52.9	48.0	50.9	47.2	49.2	46.3	49.3	51.6	47.8	49.9	46.6	48.6	10.6	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
47.7	49.0	50.1	46.4	46.7	48.8	45.2	44.6	47.6	19.9	51.9	19.2	50.1	18.5	48.8	56.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.3	31.8	27.8	-3.3	60.3	7.4	4.7	-8.6	63.6	-13.0	66.4	-17.1	69.0	-22.5	72.4		
(5)			-4.4	52.2	6.6	2.6	-9.1	54.1	-12.9	55.6	-16.6	57.1	-21.4	59.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.0	20.5	18.2	18.7	26.8	34.1	39.0	43.5	44.2	40.8	33.7	28.0	23.9	
	DBStd	11.19	8.53	9.53	9.79	6.65	4.20	4.06	3.62	3.19	3.59	5.11	6.75	7.41	
	HDD50	6934	914	890	970	697	494	330	204	184	278	504	659	810	
	HDD65	12401	1379	1310	1435	1147	959	779	666	646	727	969	1109	1275	
	CDD50	8	0	0	0	0	0	1	3	3	1	0	0	0	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	13.9	17.1	16.5	15.9	14.0	11.7	10.8	10.3	10.8	13.5	13.8	16.1	16.0	
Precipitation	PrecAvg	23.2	2.2	1.4	1.4	1.4	1.3	1.4	1.9	2.6	2.6	2.2	2.5	2.4	
	PrecMax	32.4	6.2	3.4	3.6	3.2	2.3	3.0	3.6	4.3	5.6	4.6	5.3	5.0	
	PrecMin	15.4	0.2	0.6	0.1	0.5	0.3	0.5	0.7	0.9	0.7	0.6	0.9	1.0	
	PrecStd	4.2	1.4	0.7	0.8	0.7	0.6	0.6	0.8	0.9	1.0	0.9	1.1	1.0	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.6	40.9	40.1	42.9	47.2	53.6	56.8	56.4	53.2	48.6	46.3	42.5	
		MCWB	37.2	35.5	36.3	36.8	42.0	46.9	49.9	51.1	46.1	41.9	42.2	38.3	
	2%	DB	37.2	37.4	36.9	39.0	43.6	49.6	52.5	52.7	49.9	44.1	42.5	38.6	
		MCWB	33.7	34.0	33.5	35.5	40.0	44.7	47.9	49.0	46.4	40.0	38.8	35.8	
	5%	DB	34.8	34.0	34.4	37.0	41.4	46.8	50.6	50.7	47.5	41.9	39.5	36.2	
		MCWB	31.9	31.1	31.8	34.2	38.6	43.9	47.1	47.9	44.2	38.5	36.3	33.7	
	10%	DB	32.0	31.2	32.1	35.3	39.5	44.5	48.9	49.0	45.3	39.8	36.8	33.7	
		MCWB	29.5	29.1	30.1	33.2	37.3	42.3	46.3	46.7	42.4	37.0	34.0	31.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.0	37.1	36.9	38.4	43.2	47.7	50.8	52.1	48.7	43.8	43.1	39.0
			MCDB	39.7	39.7	39.4	40.8	45.6	51.9	54.6	55.0	50.6	47.0	45.7	41.5
2%		WB	34.7	34.1	33.9	36.2	40.6	45.5	48.7	49.8	46.7	40.9	39.8	36.5	
		MCDB	36.5	36.9	35.7	38.4	42.7	48.5	51.3	51.8	49.0	43.5	42.1	38.2	
5%		WB	32.0	31.4	32.2	34.8	39.0	43.9	47.5	48.5	44.6	38.9	36.7	34.1	
		MCDB	34.2	33.8	34.2	36.6	40.8	46.6	49.8	50.2	47.0	40.9	38.8	35.8	
10%		WB	29.6	29.1	30.2	33.4	37.6	42.4	46.4	47.0	43.0	37.5	34.3	31.7	
		MCDB	32.2	31.1	32.2	34.9	39.2	44.5	48.6	48.5	44.7	39.6	36.5	33.5	
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.4	6.5	5.9	5.5	5.6	5.7	5.0	4.5	4.3	4.7	5.2	
		MCDBR	8.7	10.0	7.4	7.6	9.1	9.9	9.1	8.2	7.2	6.7	7.2	6.9	
		MCWBR	7.4	8.3	6.1	5.7	6.0	6.2	5.5	5.3	4.6	5.0	5.8	5.9	
	5% WB	MCDBR	9.2	9.6	7.4	7.1	8.6	9.1	8.0	6.9	6.2	6.2	6.6	6.2	
		MCWBR	8.3	8.7	6.3	5.7	6.1	6.2	5.5	5.0	4.4	5.1	6.1	5.9	
Clear-Sky Solar Irradiance	taub	N/A	0.244	0.276	0.324	0.338	0.346	0.346	0.348	0.308	0.265	0.353	0.350		
	taud	N/A	2.280	2.355	2.286	2.350	2.441	2.483	2.484	2.525	2.351	2.816	2.891		
	Ebn at Noon	N/A	217	260	268	275	275	272	260	249	203	108	62		
	Edh at Noon	N/A	16	23	32	33	31	29	26	20	15	7	4		
All-Sky Solar Radiation	RadAvg	29	173	573	1113	1560	1716	1570	1143	696	301	59	10		
	RadStd	3	21	63	102	108	157	168	89	85	30	12	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+0.88	+2.93	N/A	+2.02	N/A	N/A	N/A	N/A	+20	N/A

Nomenclature: See separate page