

NARSARSUAQ, Greenland

WMO: 042700

Lat: 61.1581N

Lon: 45.4405W

Elev: 34

StdP: 100.92

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.2	-19.1	-29.6	0.2	-19.1	-27.5	0.3	-17.4	25.2	2.0	23.3	2.8	1.6	60	0.831

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	18.6	9.8	17.2	9.4	16.1	8.8	11.2	16.1	10.5	15.1	9.8	14.1	7.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	7.2	11.2	8.2	6.8	10.6	7.5	6.4	10.2	32.3	16.4	30.5	15.1	28.9	14.2	18.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	17.5	13.9	DB	-22.8	21.5	3.9	1.4	-25.6	22.5	-27.9	23.3	-30.2	24.2	-33.0	25.2	(4)
(5)			WB	-23.3	12.8	3.7	1.4	-26.0	13.8	-28.1	14.6	-30.2	15.4	-32.9	16.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	1.9	-5.4	-6.2	-4.6	1.7	6.1	9.7	11.2	10.0	6.2	1.6	-2.8	-5.3	(6)	
	DBStd	8.06	7.01	7.28	6.59	4.40	3.39	2.68	2.20	2.08	2.80	4.22	5.74	6.74	(7)	
	HDD10.0	3073	478	453	452	249	128	36	12	24	118	263	386	474	(8)	
	HDD18.3	5996	736	686	711	498	378	258	222	258	363	519	635	732	(9)	
	CDD10.0	118	0	0	0	1	8	29	48	25	5	2	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	WSAvg	4.2	5.2	5.2	4.5	4.5	4.6	4.3	3.6	3.2	3.4	3.6	3.9	4.5	(14)	
(15) Precipitation	PrecAvg	615	38	33	37	42	37	52	65	70	68	51	60	61	(15)	
	PrecMax	1050	155	174	110	124	161	134	228	219	227	159	168	328	(16)	
	PrecMin	259	0	1	0	2	3	1	8	0	4	0	4	8	(17)	
	PrecStd	172	35	35	35	36	37	33	47	54	53	41	50	67	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	11.3	11.9	13.9	18.9	19.9	20.2	20.1	16.6	15.3	12.3	11.9	(19)	
		MCWB	4.1	4.3	4.8	6.6	9.5	9.7	10.2	10.9	8.8	7.2	5.1	5.4	(20)	
	2%	DB	9.0	8.2	9.0	11.5	15.6	17.9	18.6	17.3	14.1	12.3	9.7	9.1	(21)	
		MCWB	2.7	2.3	2.9	4.8	7.4	9.1	9.9	9.8	6.7	5.2	3.2	2.6	(22)	
	5%	DB	6.6	5.8	6.7	9.8	13.5	16.5	17.4	16.0	12.4	10.0	7.9	6.9	(23)	
		MCWB	1.0	0.7	1.3	3.5	6.0	8.6	9.7	9.1	5.9	3.8	2.3	1.2	(24)	
	10%	DB	4.1	4.0	4.4	8.1	11.9	15.0	16.2	14.5	10.9	7.9	5.6	4.5	(25)	
		MCWB	-0.7	-0.7	-0.1	2.6	5.1	8.0	9.2	8.5	5.5	2.7	1.3	-0.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	4.6	5.4	7.3	10.2	11.5	12.4	12.2	10.5	8.2	6.6	5.6	(27)	
		MCDB	9.8	8.7	10.0	12.3	17.4	17.1	17.0	17.2	13.6	12.5	9.4	11.0	(28)	
	2%	WB	2.9	3.1	3.5	5.6	8.3	10.3	11.3	11.1	8.5	6.1	4.2	3.2	(29)	
		MCDB	8.5	7.5	8.2	10.1	13.6	15.7	16.3	15.4	11.3	10.7	8.3	8.2	(30)	
	5%	WB	1.2	1.3	1.8	4.1	6.9	9.5	10.6	10.2	7.5	4.6	2.9	1.6	(31)	
		MCDB	5.4	5.0	5.6	8.5	11.4	14.6	15.5	13.8	10.1	8.2	6.6	5.9	(32)	
	10%	WB	-0.2	-0.2	0.4	3.1	5.8	8.7	10.0	9.5	6.6	3.5	1.6	0.2	(33)	
		MCDB	3.2	3.2	3.7	7.1	10.2	13.4	14.5	13.0	9.2	6.9	4.8	3.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	6.8	6.9	6.3	7.0	7.5	7.7	7.2	6.3	5.7	6.0	6.5	(35)	
		MCDBR	8.8	7.6	8.0	7.9	9.1	9.9	10.1	9.8	8.3	7.7	8.4	7.9	(36)	
	5% WB	MCWBR	5.2	4.7	4.6	4.1	4.4	4.7	5.1	5.0	3.9	4.1	4.8	4.6	(37)	
		MCWBR	8.6	7.5	7.8	7.6	8.0	9.3	9.0	8.4	6.7	6.5	7.5	7.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.255	0.265	0.299	0.340	0.353	0.364	0.360	0.353	0.323	0.276	0.232	0.201	(40)	
		taud	1.924	2.123	2.099	2.025	2.094	2.182	2.227	2.263	2.255	2.194	2.009	1.865	(41)	
	Ebn at Noon		418	711	808	839	861	859	853	826	781	685	463	320	(42)	
		Edh at Noon	46	71	104	137	139	131	122	108	90	65	40	28	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.33	1.18	2.90	5.06	6.47	6.88	6.39	4.86	3.06	1.64	0.53	0.18	(44)	
	RadStd		0.02	0.07	0.16	0.19	0.21	0.34	0.36	0.34	0.20	0.11	0.04	0.01	(45)	

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.87	+2.90	N/A	+0.61	N/A	-0.63	-272	-258	N/A	N/A	(46)
(47)	Regional (5 neighbors)	+0.87	+2.90	N/A	+0.61	N/A	-0.63	-272	-258	N/A	N/A	(47)

Nomenclature: See separate page