

QAQORTOQ JULIANEHAAB, Greenland

WMO: 042720

Lat: 60.716N

Lon: 46.043W

Elev: 34

StdP: 100.92

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-16.7	-15.1	-23.0	0.5	-14.7	-21.2	0.6	-13.7	25.9	2.2	23.3	2.0	2.7	270	0.829

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	15.4	9.5	14.0	9.0	12.7	8.6	11.2	13.3	10.2	12.3	9.4	11.5	5.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.1	7.7	11.9	9.0	7.2	10.7	8.2	6.8	9.9	32.3	13.4	29.9	12.4	27.9	11.7	15.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	15.5	12.1	DB	-17.9	18.1	2.9	1.2	-20.0	19.0	-21.7	19.7	-23.3	20.4	-25.4	21.3	(4)
(5)			WB	-18.3	13.1	2.6	1.0	-20.2	13.9	-21.8	14.4	-23.3	15.0	-25.2	15.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.5	-4.3	-5.0	-3.9	0.6	3.7	6.3	8.0	8.3	6.2	2.3	-1.2	-3.3
	DBStd	6.21	5.48	5.89	5.33	3.71	2.66	2.66	2.39	2.15	2.37	3.38	4.16	4.97
	HDD10.0	3123	442	421	431	281	196	116	72	63	117	238	335	411
	HDD18.3	6136	701	654	689	531	453	362	321	312	363	496	585	669
	CDD10.0	28	0	0	0	0	1	4	10	9	3	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	3.1	4.2	4.2	3.2	3.2	2.5	2.6	1.8	1.9	2.6	2.9	3.7	4.0
Precipitation	PrecAvg	976	72	78	61	64	56	71	74	106	117	91	108	68
	PrecMax	1482	203	248	199	173	128	146	197	254	233	211	284	183
	PrecMin	395	13	6	2	5	8	3	4	14	9	10	2	4
	PrecStd	238	55	60	49	41	28	45	48	53	60	65	77	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.1	10.1	8.9	11.0	14.6	16.2	17.5	17.1	14.6	13.3	10.6	10.3
		MCWB	3.8	4.6	4.1	7.1	8.3	9.0	11.0	11.3	9.3	6.7	5.0	5.5
	2%	DB	7.4	7.0	6.7	9.3	11.6	14.1	15.5	14.6	12.8	11.2	9.3	7.7
		MCWB	2.8	3.3	2.7	4.6	6.2	8.3	9.8	9.7	8.1	5.9	4.5	3.3
	5%	DB	5.3	5.2	5.1	7.7	9.8	12.5	13.9	13.2	11.1	8.9	7.1	5.9
		MCWB	1.7	1.8	1.7	3.4	5.5	7.6	9.4	9.6	7.3	4.3	3.4	2.1
	10%	DB	3.2	3.3	3.4	6.1	8.1	11.0	12.2	11.8	9.7	7.2	4.8	4.0
		MCWB	0.2	0.1	0.5	2.6	4.6	7.2	9.2	9.1	6.7	3.9	2.7	1.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	5.3	5.2	8.1	9.1	10.7	13.0	13.0	10.9	8.5	6.9	6.1
		MCDB	7.6	7.8	7.1	10.4	12.9	13.4	15.8	14.8	12.6	11.7	8.0	9.6
	2%	WB	3.4	3.8	3.5	5.3	7.4	9.3	11.3	11.3	9.3	6.5	5.1	3.9
		MCDB	6.4	7.2	6.3	7.8	10.3	12.5	13.5	13.1	11.0	9.7	7.8	6.3
	5%	WB	2.0	2.1	2.0	3.9	6.1	8.4	10.1	10.2	8.3	5.5	4.0	2.7
		MCDB	5.3	4.5	4.5	6.6	8.5	11.3	12.5	12.1	10.0	8.0	7.0	5.4
	10%	WB	0.5	0.3	0.7	3.1	5.2	7.6	9.2	9.4	7.3	4.4	2.6	1.3
		MCDB	2.9	2.7	3.0	5.5	7.6	10.2	11.5	11.1	9.0	6.6	4.7	3.7
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.0	5.2	5.2	5.6	6.0	5.8	4.8	4.4	4.0	4.2	4.4
		MCDBR	6.1	5.6	6.0	6.8	8.2	8.5	8.0	6.8	5.9	5.6	6.5	5.6
		MCWBR	3.9	3.9	4.1	4.2	4.8	4.6	4.5	3.8	3.4	3.2	4.5	3.6
	5% WB	MCDBR	6.6	5.6	5.8	6.1	7.2	7.5	7.2	5.9	4.9	4.9	5.9	5.4
		MCWBR	4.8	4.5	4.5	4.4	5.0	4.9	4.9	4.0	3.5	3.4	5.0	4.1
Clear-Sky Solar Irradiance	taub		0.254	0.274	0.296	0.336	0.340	0.348	0.356	0.352	0.322	0.289	0.236	0.201
	taud		2.026	2.240	2.277	2.200	2.315	2.376	2.388	2.417	2.442	2.340	2.125	1.948
	Ebn at Noon		463	723	832	855	883	880	862	837	801	697	503	372
	Edh at Noon		44	66	89	116	113	108	105	94	76	59	38	28
All-Sky Solar Radiation	RadAvg		0.29	1.00	2.52	4.38	5.61	5.96	5.56	4.20	2.73	1.48	0.47	0.17
	RadStd		0.02	0.10	0.21	0.30	0.32	0.47	0.44	0.39	0.26	0.12	0.06	0.01

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)		+0.87	+2.90	N/A	+0.61	N/A	-0.63	-272	-258	N/A	N/A

Nomenclature: See separate page