

ANGISOQ, Greenland

WMO: 042850

Lat: 59.991N

Lon: 45.146W

Elev: 52

StdP: 14.67

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.9	15.4	0.1	5.5	15.6	2.8	6.4	17.0	60.8	19.2	56.3	22.6	31.6	310	1.035

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	53.9	46.9	50.6	44.9	48.3	43.7	47.1	50.2	45.6	48.3	44.3	46.7	19.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.2	44.6	47.6	43.8	42.3	46.2	42.6	40.2	44.8	18.8	50.4	18.0	48.6	17.3	46.9	53.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 51.2	45.6	40.5	DB	11.4	56.7	2.5	2.7	9.6	58.6	8.1	60.2	6.7	61.7	4.9	63.6	(4)
(5)			WB	9.2	50.2	2.4	1.7	7.5	51.4	6.1	52.4	4.7	53.4	2.9	54.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	34.3	27.9	27.2	28.1	32.3	35.3	37.9	40.3	41.8	40.4	36.7	33.0	30.1	(6)	
	DBStd	7.04	5.91	6.98	6.84	5.26	3.75	3.49	3.62	3.72	3.12	4.73	4.52	5.46	(7)	
	HDD50	5741	686	638	680	533	457	362	301	254	288	413	511	618	(8)	
	HDD65	11210	1151	1058	1143	981	922	812	766	718	738	877	961	1083	(9)	
	CDD50	7	0	0	2	2	0	0	1	1	0	1	0	0	(10)	
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH74	1	0	0	1	0	0	0	0	0	0	0	0	0	(12)	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	17.0	20.8	21.5	19.2	17.2	14.7	13.5	12.6	13.9	15.9	17.0	18.6	19.1	(14)	
(15) Precipitation	PrecAvg	51.6	5.6	4.7	3.9	3.3	3.1	3.6	3.5	4.4	4.8	4.4	5.3	4.8	(15)	
	PrecMax	68.3	10.0	9.3	7.4	5.2	7.7	5.9	5.6	7.8	8.0	8.3	8.5	12.5	(16)	
	PrecMin	38.7	2.1	1.3	0.8	1.4	1.5	1.0	1.6	0.9	2.0	1.9	2.2	1.9	(17)	
	PrecStd	7.1	2.0	1.9	1.4	0.9	1.3	1.1	1.0	1.6	1.5	1.5	2.1	2.0	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.6	50.0	65.9	64.3	49.4	52.3	54.6	55.2	52.0	53.5	49.2	46.5	(19)	
		MCWB	38.6	41.1	42.2	48.2	42.5	44.3	47.6	47.4	46.0	46.4	42.3	39.5	(20)	
	2%	DB	41.3	42.9	43.5	51.4	46.1	48.5	50.8	52.0	48.8	47.8	44.9	42.5	(21)	
		MCWB	36.8	38.6	38.0	42.0	40.8	42.8	45.0	46.3	44.1	42.2	40.5	37.4	(22)	
	5%	DB	38.6	40.2	40.1	43.4	43.5	45.9	48.0	49.3	46.8	44.9	41.3	39.8	(23)	
		MCWB	34.4	36.2	36.2	38.0	38.9	41.5	43.9	45.3	42.8	40.2	38.0	35.7	(24)	
	10%	DB	36.0	37.3	37.3	39.5	41.2	43.8	46.0	47.3	45.0	42.5	39.1	37.2	(25)	
		MCWB	32.6	33.8	33.7	35.9	37.5	40.4	42.9	44.4	42.1	38.8	36.1	33.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.5	40.7	40.1	40.8	43.2	45.7	48.8	49.5	47.5	47.0	44.0	41.1	(27)	
		MCDB	42.1	43.3	42.8	44.6	47.4	50.6	52.7	52.6	49.9	51.4	47.2	43.8	(28)	
	2%	WB	36.8	38.4	38.0	38.5	41.3	43.5	45.9	47.6	45.5	43.3	41.1	38.0	(29)	
		MCDB	40.4	41.0	41.0	41.9	45.1	47.2	49.0	50.4	47.4	46.5	43.7	41.6	(30)	
	5%	WB	34.7	36.0	35.9	36.7	39.5	42.0	44.3	46.0	43.9	41.0	38.7	36.2	(31)	
		MCDB	37.6	38.9	38.7	39.5	42.7	45.2	46.9	48.6	45.8	43.7	41.3	38.8	(32)	
	10%	WB	32.9	33.3	33.8	35.1	37.9	40.6	43.1	44.6	42.6	39.4	36.5	34.5	(33)	
		MCDB	35.1	35.9	36.3	37.4	40.6	43.2	45.5	46.8	44.5	41.8	38.5	36.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.3	6.3	6.1	6.9	7.8	8.0	6.9	5.6	5.3	5.0	5.3	(35)	
		MCDBR	9.7	9.8	10.7	11.3	11.2	11.6	11.4	9.9	8.3	9.3	8.9	8.5	(36)	
	5% WB	MCWBR	6.1	7.0	5.9	6.3	6.8	7.4	7.2	5.9	5.3	5.4	6.2	5.4	(37)	
		MCWBR	9.0	8.7	8.5	8.5	10.1	10.5	10.2	8.6	7.4	7.9	8.1	7.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.269	0.286	0.300	0.343	0.351	0.354	0.359	0.351	0.332	0.294	0.252	0.220	(40)	
		taud	2.102	2.334	2.398	2.298	2.363	2.412	2.450	2.476	2.485	2.448	2.214	2.016	(41)	
	Ebn at Noon		154	232	267	272	278	278	274	267	253	228	167	126	(42)	
		Edh at Noon	14	20	26	34	34	33	31	29	24	18	12	10	(43)	
(44) All-Sky Solar Radiation	RadAvg		88	275	699	1217	1601	1662	1558	1195	806	443	139	56	(44)	
	RadStd		9	34	74	89	118	151	131	116	88	42	16	5	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)			+1.57	+5.22	N/A	+1.10	N/A	-1.13	-490	-464	N/A

Nomenclature: See separate page