

ANGISOQ, Greenland

WMO: 042850

Lat: 59.991N

Lon: 45.146W

Elev: 16

StdP: 101.13

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.6	-9.2	-17.7	0.8	-9.1	-16.2	0.9	-8.4	27.2	-7.1	25.2	-5.2	14.1	310	1.035

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.8	12.2	8.3	10.3	7.2	9.0	6.5	8.4	10.1	7.5	9.1	6.8	8.2	8.7	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
7.3	6.4	8.7	6.6	6.0	7.9	5.9	5.7	7.1	25.9	10.2	23.9	9.2	22.4	8.3	12.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.9	20.4	18.1	-11.4	13.7	1.4	1.5	-12.4	14.8	-13.3	15.7	-14.0	16.5	-15.1	17.6		
(5)			-12.7	10.1	1.3	0.9	-13.6	10.8	-14.4	11.3	-15.2	11.9	-16.1	12.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	1.3	-2.3	-2.7	-2.2	0.2	1.8	3.3	4.6	5.5	4.7	2.6	0.5	-1.1
	DBStd	3.91	3.29	3.88	3.80	2.92	2.08	1.94	2.01	2.07	1.74	2.63	2.51	3.03
	HDD10.0	3189	381	354	378	296	254	201	167	141	160	229	284	343
	HDD18.3	6228	639	588	635	545	512	451	426	399	410	487	534	602
	CDD10.0	4	0	0	1	1	0	0	1	1	0	1	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	1	0	0	1	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.6	9.3	9.6	8.6	7.7	6.6	6.0	5.6	6.2	7.1	7.6	8.3	8.5
Precipitation	PrecAvg	1310	142	119	98	85	79	91	89	112	123	112	135	123
	PrecMax	1736	255	235	187	132	195	151	141	198	204	210	217	318
	PrecMin	982	53	32	21	35	39	26	40	22	52	49	56	49
	PrecStd	180	52	49	36	24	33	29	25	40	38	38	54	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	10.0	18.9	17.9	9.7	11.3	12.6	12.9	11.1	11.9	9.6	8.1
		MCWB	3.6	5.1	5.7	9.0	5.8	6.8	8.7	8.6	7.8	8.0	5.7	4.2
	2%	DB	5.2	6.1	6.4	10.8	7.8	9.2	10.4	11.1	9.3	8.8	7.2	5.8
		MCWB	2.7	3.7	3.3	5.6	4.9	6.0	7.2	7.9	6.7	5.7	4.7	3.0
	5%	DB	3.7	4.6	4.5	6.3	6.4	7.7	8.9	9.6	8.2	7.2	5.2	4.3
		MCWB	1.3	2.3	2.3	3.3	3.8	5.3	6.6	7.4	6.0	4.5	3.3	2.0
	10%	DB	2.2	2.9	2.9	4.2	5.1	6.6	7.8	8.5	7.2	5.8	4.0	2.9
		MCWB	0.3	1.0	0.9	2.2	3.1	4.7	6.1	6.9	5.6	3.8	2.3	1.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.2	4.8	4.5	4.9	6.2	7.6	9.4	9.7	8.6	8.3	6.7	5.0
		MCDB	5.6	6.3	6.0	7.0	8.6	10.3	11.5	11.5	10.0	10.8	8.5	6.5
	2%	WB	2.7	3.6	3.4	3.6	5.2	6.4	7.7	8.7	7.5	6.3	5.1	3.3
		MCDB	4.7	5.0	5.0	5.5	7.3	8.4	9.4	10.2	8.6	8.0	6.5	5.3
	5%	WB	1.5	2.2	2.2	2.6	4.1	5.6	6.8	7.8	6.6	5.0	3.7	2.3
		MCDB	3.1	3.9	3.7	4.2	6.0	7.3	8.3	9.2	7.7	6.5	5.2	3.8
	10%	WB	0.5	0.7	1.0	1.7	3.3	4.8	6.2	7.0	5.9	4.1	2.5	1.4
		MCDB	1.7	2.2	2.4	3.0	4.8	6.2	7.5	8.2	6.9	5.5	3.6	2.7
Mean Daily Temperature Range	5% DB	MDBR	3.4	3.5	3.5	3.4	3.9	4.3	4.5	3.8	3.1	3.0	2.8	2.9
		MCDBR	5.4	5.4	5.9	6.3	6.2	6.5	6.3	5.5	4.6	5.1	4.9	4.7
		MCWBR	3.4	3.9	3.3	3.5	3.8	4.1	4.0	3.3	3.0	3.0	3.5	3.0
	5% WB	MCDBR	5.0	4.8	4.7	4.7	5.6	5.8	5.7	4.8	4.1	4.4	4.5	4.1
		MCWBR	3.7	4.1	3.6	3.5	3.8	4.1	3.9	3.3	3.2	3.1	3.8	3.0
Clear-Sky Solar Irradiance	taub	0.269	0.286	0.300	0.343	0.351	0.354	0.359	0.351	0.332	0.294	0.252	0.220	
	taud	2.102	2.334	2.398	2.298	2.363	2.412	2.450	2.476	2.485	2.448	2.214	2.016	
	Ebn at Noon	486	731	842	856	876	877	864	843	799	718	526	396	
	Edh at Noon	45	63	81	107	108	105	99	90	75	56	38	30	
All-Sky Solar Radiation	RadAvg	0.28	0.87	2.20	3.83	5.05	5.24	4.91	3.77	2.54	1.40	0.44	0.17	
	RadStd	0.03	0.11	0.23	0.28	0.37	0.47	0.41	0.37	0.28	0.13	0.05	0.01	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	+0.87	+2.90	N/A	+0.61	N/A	-0.63	-272	-258	N/A	N/A

Nomenclature: See separate page