

KAP MORRIS JESUP, Greenland

WMO: 043010

Lat: 83.656N

Lon: 33.374W

Elev: 13

StdP: 14.69

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-43.3	-40.7	-46.9	0.4	-42.6	-43.9	0.4	-40.0	42.6	-7.1	37.1	-11.8	5.4	260	1.214

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	45.2	41.1	42.7	39.5	40.5	37.9	41.4	44.6	39.6	42.3	38.1	40.4	8.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
38.9	34.8	41.5	36.8	32.0	40.4	35.3	30.2	39.0	15.9	44.9	15.0	42.6	14.4	40.6	49.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.9	33.0	28.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-40.2	42.9	6.6	2.0	-45.0	44.4	-48.9	45.5	-52.6	46.7	-57.4	48.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.0	-21.7	-20.4	-22.6	-8.5	13.9	32.1	35.9	32.8	17.0	1.5	-10.1	-16.0		
	DBStd	23.50	10.29	13.49	10.68	9.11	8.20	4.48	3.47	4.70	8.69	9.94	10.52	11.36		
	HDD50	17165	2222	1971	2250	1755	1118	538	437	533	990	1503	1803	2045		
	HDD65	22640	2687	2391	2715	2205	1583	988	902	998	1440	1968	2253	2510		
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	10.2	9.9	10.6	8.9	9.7	10.8	11.6	9.8	10.4	9.4	9.4	10.3	11.3		
	PrecAvg	9.8	0.9	0.6	0.6	0.6	0.6	0.6	0.9	1.0	1.3	1.0	0.9	0.9		
(15) Precipitation	PrecMax	20.2	2.3	1.5	1.7	2.1	4.6	1.3	2.3	1.9	3.2	1.9	2.4	6.8		
	PrecMin	5.8	0.2	0.2	0.0	0.0	0.0	0.1	0.2	0.4	0.3	0.3	0.1	0.1		
	PrecStd	2.8	0.6	0.4	0.4	0.4	0.8	0.3	0.4	0.4	0.7	0.4	0.5	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.9	35.1	25.6	19.2	34.0	46.6	48.6	47.4	36.3	27.0	29.0	23.7		
		MCWB	18.0	27.9	23.0	18.0	30.8	43.9	43.2	41.9	33.0	23.9	25.4	22.6		
	2%	DB	2.2	21.6	7.1	13.0	30.5	43.0	45.8	44.0	32.2	21.6	14.4	13.6		
		MCWB	1.4	18.5	6.3	11.7	28.7	39.8	41.1	40.3	30.0	20.3	13.3	12.5		
	5%	DB	-3.0	1.9	-2.0	8.5	27.9	39.9	43.4	41.2	29.8	18.5	7.5	5.0		
		MCWB	-3.6	1.0	-2.8	7.6	26.6	37.2	39.9	38.5	28.2	17.4	6.7	4.2		
	10%	DB	-7.4	-4.7	-7.4	4.5	25.8	37.8	41.3	39.2	27.7	15.0	3.7	-0.2		
		MCWB	-7.8	-5.3	-8.0	3.7	24.8	35.6	38.7	36.9	26.4	14.0	2.9	-0.8		
	0.4%	WB	17.9	28.7	22.7	18.3	31.6	45.9	43.8	43.1	33.2	24.4	25.5	23.0		
		MCDB	20.4	35.0	25.7	19.1	33.8	46.1	46.2	45.8	35.2	26.6	28.6	23.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	1.8	18.7	6.8	11.7	28.9	39.6	41.8	40.4	30.3	20.7	13.2	12.6		
		MCDB	2.5	22.6	7.4	12.9	30.3	42.5	44.9	43.5	31.8	21.7	14.3	14.0		
	5%	WB	-3.3	1.3	-2.5	7.5	26.8	37.3	40.2	38.7	28.4	17.3	6.7	4.3		
		MCDB	-2.8	2.1	-1.9	8.3	27.9	39.7	43.1	41.1	29.7	18.3	7.2	5.0		
	10%	WB	-7.4	-5.2	-7.8	3.7	24.8	35.7	38.7	37.0	26.5	14.1	3.0	-0.8		
		MCDB	-7.1	-4.8	-7.2	4.4	25.8	37.5	41.3	39.1	27.6	14.9	3.7	-0.2		
	5% DB	MDBR	10.4	11.6	9.5	9.0	6.6	5.3	5.3	5.5	7.7	10.0	10.4	10.6		
		MCDBR	15.9	25.8	16.4	13.5	8.1	9.2	9.4	9.3	8.6	13.9	17.8	21.9		
		MCWBR	15.5	23.0	15.6	13.1	7.1	7.0	6.4	6.4	7.2	12.8	16.7	20.8		
		MCWBR	15.9	25.7	16.7	13.0	7.6	8.9	9.1	8.8	8.5	13.4	17.8	21.9		
(40) Clear-Sky Solar Irradiance	taub		N/A	N/A	0.166	0.247	0.277	0.301	0.297	0.279	0.185	N/A	N/A	N/A		
		taud	N/A	N/A	1.902	2.082	2.098	2.110	2.252	2.253	1.977	N/A	N/A	N/A		
	Ebn at Noon		0	0	139	228	251	250	246	218	133	0	0	0		
		Edh at Noon	0	0	9	23	30	32	26	20	9	0	0	0		
(44) All-Sky Solar Radiation	RadAvg		0	0	146	1135	2173	2493	2216	1262	321	0	0	0		
	RadStd		0	0	11	49	73	114	122	101	23	0	0	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page