

STATION NORD, Greenland

WMO: 043120

Lat: 81.600N

Lon: 16.650W

Elev: 36

StdP: 100.89

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-40.8	-38.9	-43.7	0.1	-40.1	-41.9	0.1	-38.6	17.9	-15.1	14.7	-18.3	2.0	210	1.124

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	12.5	7.6	10.9	6.7	9.3	5.8	7.9	12.1	6.9	10.6	5.9	9.0	5.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
4.6	5.3	9.2	3.6	4.9	8.5	2.7	4.6	7.5	24.6	12.3	22.6	10.7	20.5	9.2	14.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.3	12.8	10.1	-41.9	14.7	2.4	1.7	-43.6	15.9	-45.0	16.9	-46.3	17.8	-48.1	19.1		
(5)			-42.3	9.7	2.6	1.7	-44.1	11.0	-45.6	11.9	-47.1	12.9	-48.9	14.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-14.7	-27.4	-27.9	-28.8	-21.6	-9.2	0.7	4.5	2.7	-6.5	-16.3	-22.3	-25.7		
	DBStd	13.22	6.46	7.17	5.33	5.30	4.92	3.05	3.46	3.36	4.24	5.38	5.59	6.35		
	HDD10.0	9034	1159	1062	1203	949	594	279	173	228	495	817	968	1106		
	HDD18.3	12072	1417	1296	1462	1199	852	529	428	486	745	1075	1218	1364		
	CDD10.0	4	0	0	0	0	0	0	3	1	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	3.7	3.4	3.6	3.1	3.4	3.6	3.9	3.9	4.2	4.0	3.5	4.0	3.5		
(15) Precipitation	PrecAvg	262	24	23	26	28	14	8	23	22	35	27	29	27		
	PrecMax	436	63	100	100	116	62	38	103	65	93	88	81	105		
	PrecMin	141	2	1	3	5	0	0	0	1	0	3	3	1		
	PrecStd	75	16	22	25	26	16	9	24	16	29	21	24	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-3.7	-1.9	-3.8	-3.4	3.2	10.2	15.3	13.0	4.6	0.2	-1.9	-2.1		
		MCWB	-4.1	-2.6	-4.3	-3.8	0.9	6.0	8.9	7.6	2.4	-1.8	-2.5	-2.8		
	2%	DB	-11.0	-6.4	-14.4	-8.8	1.3	7.9	13.4	11.2	2.0	-5.5	-7.3	-7.2		
		MCWB	-11.4	-7.5	-14.8	-9.5	-0.5	4.4	8.0	6.9	0.3	-6.5	-8.2	-7.9		
	5%	DB	-15.5	-12.1	-18.8	-11.8	-0.3	6.6	12.1	9.7	0.2	-7.4	-12.1	-14.0		
		MCWB	-16.0	-12.9	-19.2	-12.5	-1.7	3.6	7.5	6.0	-0.8	-8.1	-12.7	-14.4		
	10%	DB	-18.4	-19.6	-21.4	-14.0	-2.1	5.2	10.7	8.3	-0.8	-9.3	-14.6	-17.6		
		MCWB	-18.8	-19.9	-21.7	-14.7	-3.2	2.8	6.6	5.2	-1.7	-9.8	-15.0	-18.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.1	-2.3	-4.2	-4.0	1.2	6.6	9.3	8.3	2.4	-1.3	-2.4	-2.7		
		MCDB	-3.6	-1.8	-3.7	-3.3	3.0	9.5	13.9	12.2	3.9	0.3	-1.9	-2.2		
	2%	WB	-11.4	-7.5	-14.8	-9.5	-0.3	4.8	8.4	7.1	0.4	-6.3	-8.1	-7.9		
		MCDB	-11.1	-6.5	-14.4	-8.8	1.1	7.7	12.8	10.7	1.3	-5.7	-7.3	-7.0		
	5%	WB	-15.9	-12.8	-19.2	-12.4	-1.7	3.7	7.6	6.3	-0.6	-8.0	-12.6	-14.5		
		MCDB	-15.5	-12.1	-18.9	-11.8	-0.5	6.2	11.8	9.4	0.1	-7.4	-12.1	-14.1		
	10%	WB	-18.8	-19.9	-21.6	-14.6	-3.1	2.8	6.7	5.4	-1.7	-9.7	-15.0	-18.0		
		MCDB	-18.4	-19.6	-21.4	-14.1	-2.1	5.2	10.4	8.1	-0.9	-9.3	-14.6	-17.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.2	6.1	6.3	5.4	4.6	5.4	5.0	4.3	5.0	5.7	6.2		
		MCDBR	9.7	10.8	8.7	7.7	7.2	7.4	7.9	7.6	6.0	6.3	7.6	10.9		
		MCWBR	9.4	10.4	8.6	7.2	5.9	5.2	4.9	5.3	5.2	5.9	7.4	10.4		
		MCDBR	9.6	10.8	8.6	7.6	6.5	7.3	8.0	7.5	5.8	6.1	7.6	10.9		
	5% WB	MCWBR	9.3	10.3	8.5	7.2	5.4	5.3	5.2	5.5	5.4	5.7	7.4	10.5		
(40) Clear-Sky Solar Irradiance	taub		N/A	N/A	0.183	0.261	0.282	0.293	0.290	0.282	0.205	N/A	N/A	N/A		
	taud		N/A	N/A	1.989	2.071	2.099	2.143	2.273	2.266	2.065	N/A	N/A	N/A		
	Ebn at Noon		0	0	535	731	807	820	806	719	506	0	0	0		
	Edh at Noon		0	0	36	80	100	103	85	67	34	0	0	0		
(44) All-Sky Solar Radiation	RadAvg		0.00	0.00	0.57	3.31	6.00	7.35	6.18	3.65	1.08	0.00	0.00	0.00		
	RadStd		0.00	0.00	0.06	0.28	0.52	0.60	0.42	0.24	0.10	0.00	0.00	0.00		

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page