

DANMARKSHAVN, Greenland

WMO: 043200

Lat: 76.769N

Lon: 18.668W

Elev: 39

StdP: 14.68

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-30.8	-27.2	-38.3	0.6	-28.9	-34.6	0.8	-25.2	57.8	6.6	50.4	7.3	2.4	300	1.083

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	51.4	42.9	49.3	41.6	46.9	40.2	43.3	50.1	42.0	48.3	40.6	46.0	11.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
38.2	33.9	43.0	36.9	32.2	42.0	35.9	30.9	41.1	16.8	50.6	16.2	48.5	15.5	46.3	47.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 42.7	32.5	26.5	DB	-35.9	53.2	5.4	0.6	-39.7	53.7	-42.9	54.1	-45.9	54.4	-49.8	54.9	(4)
(5)			WB	-36.0	44.8	5.2	1.3	-39.8	45.7	-42.9	46.4	-45.8	47.2	-49.6	48.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.3	-6.3	-8.0	-8.0	2.3	20.1	34.4	39.5	37.7	27.2	11.3	0.6	-4.7
	DBStd	19.94	11.80	12.54	10.00	9.95	7.77	5.09	4.52	4.44	5.77	8.55	8.88	10.64
	HDD50	13757	1744	1625	1798	1430	928	467	324	381	684	1200	1481	1695
	HDD65	19232	2209	2045	2263	1880	1393	917	789	846	1134	1665	1931	2160
	CDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	9.4	11.2	10.6	10.4	7.8	7.6	7.1	7.1	7.5	9.2	11.3	11.8	11.8
Precipitation	PrecAvg	6.4	0.7	0.7	0.7	0.5	0.2	0.2	0.6	0.7	0.5	0.6	0.7	0.7
	PrecMax	15.0	3.7	2.9	2.3	1.9	1.4	0.9	2.0	2.5	1.8	2.2	2.2	2.4
	PrecMin	2.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.6	0.7	0.6	0.6	0.5	0.3	0.2	0.5	0.6	0.4	0.5	0.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.9	31.2	26.8	32.0	39.4	51.7	53.3	52.7	40.4	34.5	27.6	28.7
		MCWB	27.9	30.6	26.3	31.1	33.4	43.1	43.7	43.4	34.7	32.6	26.4	27.8
	2%	DB	22.8	25.9	16.8	26.2	34.8	48.6	52.1	50.2	37.9	30.1	22.1	22.5
		MCWB	22.0	25.1	15.8	24.6	31.2	41.0	43.3	42.1	33.7	28.0	20.6	20.9
	5%	DB	16.1	17.2	10.4	20.7	32.8	45.8	50.4	47.5	36.1	26.0	18.0	16.9
		MCWB	14.9	16.1	9.3	18.8	30.1	39.4	42.3	40.2	32.7	23.8	16.7	15.6
	10%	DB	10.7	10.0	6.1	16.4	30.8	42.8	48.3	45.0	34.6	22.9	14.3	10.8
		MCWB	9.6	8.9	5.0	14.5	28.6	37.8	41.2	39.0	31.5	21.0	12.9	9.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.9	30.7	26.6	31.3	33.9	43.6	45.1	44.5	36.6	32.9	26.3	28.2
		MCDB	28.5	31.2	26.9	32.1	37.6	50.9	51.7	51.4	39.0	33.9	27.2	28.6
	2%	WB	21.9	25.4	15.6	24.6	32.1	41.4	43.9	42.6	34.8	28.0	20.7	21.1
		MCDB	22.7	26.3	16.5	26.2	34.3	47.9	50.8	48.8	36.7	29.9	22.0	22.3
	5%	WB	15.1	16.5	9.5	18.9	30.4	39.6	42.7	41.0	33.4	24.1	16.7	15.7
		MCDB	16.2	17.4	10.4	20.6	32.8	45.2	49.4	46.2	35.5	25.8	17.9	17.0
	10%	WB	9.6	9.3	5.1	14.7	28.5	37.8	41.4	39.6	32.1	21.0	12.9	9.5
		MCDB	10.6	10.3	6.1	16.3	30.8	42.4	47.3	44.0	34.3	22.8	14.3	10.8
Mean Daily Temperature Range	5% DB	MDBR	12.0	12.5	11.9	12.3	8.8	8.0	9.1	8.0	6.3	7.5	9.6	11.5
		MCDBR	15.0	15.6	14.8	13.5	8.6	12.6	13.4	11.8	7.2	8.9	11.9	14.4
		MCWBR	14.3	15.4	14.3	12.2	6.5	7.7	7.6	6.6	4.9	7.9	11.3	13.8
	5% WB	MCDBR	14.5	15.4	14.7	12.6	8.1	12.1	12.8	10.8	6.6	8.3	11.5	14.2
		MCWBR	14.0	15.4	14.3	11.7	6.3	7.8	7.9	6.6	4.9	7.7	11.1	13.7
Clear-Sky Solar Irradiance	taub	N/A	0.164	0.219	0.271	0.305	0.304	0.300	0.284	0.239	0.167	N/A	N/A	
	taud	N/A	1.854	2.089	2.084	2.051	2.163	2.327	2.401	2.295	1.867	N/A	N/A	
	Ebn at Noon	0	43	209	250	260	268	265	252	209	30	0	0	
	Edh at Noon	0	3	17	30	37	35	28	22	14	2	0	0	
All-Sky Solar Radiation	RadAvg	0	16	343	1174	1820	2235	1878	1133	430	63	0	0	
	RadStd	0	2	32	97	159	215	150	111	67	9	0	0	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.92	N/A	-2.16	+1.96	+1.22	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page