

ITTOQQORTOORMIT SCORESBYSUND, Greenland

WMO: 043390

Lat: 70.4844N

Lon: 21.9511W

Elev: 226

StdP: 14.58

Time Zone: -1.00 (AZR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.5	-11.7	-24.2	1.4	-11.4	-20.0	1.8	-8.4	60.2	18.3	51.8	19.7	3.2	30	0.967

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	54.7	44.8	51.8	43.8	49.3	42.7	46.1	52.1	44.8	49.9	43.6	48.2	5.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
43.1	41.4	45.9	41.6	39.0	44.9	40.2	36.9	44.3	18.3	52.2	17.6	50.1	17.0	48.5	51.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 45.8	35.6	28.7	-20.2	60.4	6.9	2.8	-25.2	62.4	-29.3	64.1	-33.2	65.7	-38.3	67.7		
(5)			-19.9	48.7	6.3	1.6	-24.4	49.9	-28.1	50.8	-31.6	51.7	-36.2	52.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	9.0	7.4	8.2	16.4	27.9	37.1	42.8	42.4	35.2	23.7	15.2	10.2	(6)
(7)		DBStd	15.16	10.81	10.82	9.35	8.69	5.26	4.60	4.36	4.09	4.23	6.66	7.59	9.57	(7)
(8)		HDD50	9839	1270	1193	1297	1007	684	387	226	239	444	816	1043	1233	(8)
(9)		HDD65	15307	1735	1613	1762	1457	1149	837	687	701	894	1281	1493	1698	(9)
(10)		CDD50	7	0	0	0	0	0	0	4	3	0	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	8.7	10.6	9.9	9.3	8.0	8.1	5.4	6.1	7.1	8.8	10.4	9.7	10.7	(14)
(15)	Precipitation	PrecAvg	16.2	1.6	1.5	1.5	1.1	0.9	0.7	1.1	1.7	1.7	1.7	1.5	1.5	(15)
(16)		PrecMax	29.1	5.0	4.7	5.0	4.6	3.7	2.5	4.1	5.3	4.6	7.0	6.1	4.1	(16)
(17)		PrecMin	7.4	0.2	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	(17)
(18)		PrecStd	5.2	1.2	0.9	1.1	0.9	0.8	0.7	0.9	1.3	1.2	1.4	1.2	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	33.4	33.0	39.1	42.3	55.3	59.4	58.6	47.7	39.6	35.0	34.5	(19)
(20)			MCWB	31.7	31.4	29.6	34.9	36.8	44.5	46.3	46.9	40.1	36.1	31.6	31.8	(20)
(21)		2%	DB	29.4	29.9	28.4	34.6	38.9	50.1	55.4	54.2	44.8	36.1	31.6	30.6	(21)
(22)			MCWB	27.3	28.4	26.5	32.0	34.8	41.8	45.3	44.5	39.4	33.3	30.0	28.2	(22)
(23)		5%	DB	26.7	26.5	25.2	31.4	36.7	47.1	52.5	51.2	43.2	34.1	28.5	27.4	(23)
(24)			MCWB	24.8	25.0	23.6	29.4	33.2	40.4	44.1	43.7	38.8	31.8	26.7	25.4	(24)
(25)		10%	DB	23.5	23.2	22.0	27.9	34.9	44.5	50.2	48.7	41.5	32.3	25.9	23.6	(25)
(26)			MCWB	21.7	21.7	20.4	25.8	32.2	39.4	43.2	42.7	37.7	30.3	24.1	21.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.0	32.0	30.7	35.5	37.8	45.2	48.1	48.1	43.7	37.7	32.9	33.0	(27)
(28)			MCDB	34.6	33.1	32.3	37.5	40.8	53.0	54.7	55.9	45.3	38.8	34.2	34.0	(28)
(29)		2%	WB	27.9	28.8	26.6	32.3	35.5	42.7	46.5	46.1	41.5	34.4	30.0	28.8	(29)
(30)			MCDB	28.9	29.8	28.0	34.2	38.0	48.4	52.7	51.7	43.2	35.3	31.4	30.1	(30)
(31)		5%	WB	25.0	25.2	23.8	29.5	33.9	41.1	45.1	44.8	39.8	32.2	27.0	25.5	(31)
(32)			MCDB	26.3	26.2	25.1	31.4	36.0	46.1	50.8	49.3	41.9	33.4	28.2	27.1	(32)
(33)		10%	WB	21.7	21.7	20.4	26.1	32.5	39.6	43.9	43.6	38.3	30.5	24.1	21.7	(33)
(34)			MCDB	23.4	23.0	21.9	27.6	34.5	44.1	49.1	47.6	40.5	32.1	25.7	23.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.3	10.4	10.6	11.1	8.4	9.5	10.0	8.7	6.6	6.5	8.0	9.8	(35)
(36)			MCDBR	13.2	12.2	11.6	12.3	10.5	14.3	14.0	12.6	9.0	8.1	10.7	12.3	(36)
(37)			MCWBR	11.7	11.3	10.1	10.1	7.6	8.4	7.7	7.0	6.2	6.4	9.3	10.8	(37)
(38)		5% WB	MCDBR	12.8	12.2	11.0	11.5	9.9	13.4	12.5	10.7	7.7	7.0	10.3	12.0	(38)
(39)			MCWBR	11.8	11.8	10.0	9.8	7.3	8.4	7.7	6.8	6.0	5.9	9.4	11.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.207	0.252	0.294	0.309	0.312	0.320	0.310	0.283	0.220	N/A	N/A	(40)	
(41)		taud	N/A	1.996	2.175	2.104	2.130	2.261	2.402	2.443	2.407	2.044	N/A	N/A	(41)	
(42)		Ebn at Noon	0	159	240	262	273	278	272	261	233	145	0	0	(42)	
(43)		Edh at Noon	0	12	23	34	38	35	29	25	19	11	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0	91	562	1323	1990	2230	1669	1118	529	155	0	0	(44)	
(45)		RadStd	0	15	34	73	79	166	147	169	80	29	0	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page