

NERLERIT INAAAT CONSTABLE PT, Greenland

WMO: 043410

Lat: 70.750N

Lon: 22.650W

Elev: 33

StdP: 14.68

Time Zone: -1.00 (AZR)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-20.6	-16.8	-28.3	1.1	-17.6	-24.8	1.4	-14.6	43.9	15.0	40.6	15.0	3.0	170	1.006

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	56.2	46.7	52.7	45.3	50.1	44.3	47.8	54.3	46.1	51.3	44.7	49.2	10.5	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
43.8	42.2	49.3	42.4	40.0	47.8	40.9	37.6	46.5	19.1	54.2	18.2	51.7	17.5	49.6	56.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
40.0	33.7	29.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-24.4	50.6	3.6	1.5	-27.0	51.6	-29.1	52.5	-31.1	53.3	-33.7	54.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.4	6.7	4.4	2.5	11.2	27.0	37.5	43.8	43.6	35.9	23.9	11.4	7.6
	DBStd	17.33	11.73	13.17	10.38	9.10	6.22	4.60	4.37	4.01	4.43	7.41	8.89	9.89
	HDD50	10447	1342	1277	1473	1163	712	375	197	203	424	809	1158	1314
	HDD65	15910	1807	1697	1938	1613	1177	824	656	663	874	1274	1608	1779
	CDD50	11	0	0	0	0	0	1	6	4	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	10.1	12.9	10.8	9.7	8.6	9.0	8.2	9.6	9.4	9.8	10.2	10.3	12.1
	PrecAvg	23.5	3.0	2.5	2.0	1.4	1.1	0.8	1.2	1.9	2.4	2.2	2.3	2.6
(15) Precipitation	PrecMax	38.9	10.3	8.0	4.3	5.3	3.5	2.8	4.1	4.2	7.2	5.2	5.2	8.0
	PrecMin	14.8	0.8	0.4	0.5	0.3	0.1	0.2	0.4	0.4	0.6	0.6	0.2	0.2
	PrecStd	6.9	2.1	1.7	1.0	1.1	0.9	0.6	0.7	1.0	1.5	1.3	1.2	1.9
	PrecStd	6.9	2.1	1.7	1.0	1.1	0.9	0.6	0.7	1.0	1.5	1.3	1.2	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	33.4	35.5	29.9	40.1	44.7	55.6	62.3	60.6	48.6	38.6	34.9	39.2	
	0.4% MCWB	30.7	32.8	26.1	34.6	36.3	46.6	49.8	47.7	40.5	35.2	32.3	33.3	
	2% DB	28.7	32.2	25.2	35.2	38.8	50.0	57.0	55.8	46.0	36.9	31.0	29.8	
	2% MCWB	26.6	30.4	23.2	31.8	34.2	43.7	47.3	46.3	39.4	33.8	28.5	27.5	
	5% DB	26.4	28.8	21.5	29.3	35.9	46.8	53.5	52.7	43.7	35.3	28.0	25.7	
	5% MCWB	24.6	27.3	19.7	26.8	32.6	41.3	46.2	44.7	38.4	32.2	25.8	23.7	
	10% DB	23.3	23.6	17.9	24.0	34.2	44.2	50.7	50.1	41.8	33.4	24.8	21.4	
	10% MCWB	21.7	21.8	16.0	21.4	31.5	39.7	45.1	43.8	37.3	30.5	22.7	19.5	
	0.4% WB	30.5	33.3	26.7	35.2	37.1	46.9	51.1	49.6	43.8	36.2	32.5	32.9	
	0.4% MCDB	32.3	34.9	28.7	39.4	42.5	54.7	58.5	57.7	46.1	38.1	34.3	41.1	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	26.9	30.8	23.5	32.1	34.6	43.9	48.5	47.4	41.1	34.5	28.8	27.5	
	2% MCDB	28.5	32.8	25.8	34.7	38.2	49.1	55.1	53.4	43.9	36.4	30.6	29.4	
	5% WB	24.9	27.6	19.8	26.7	33.2	41.8	46.7	45.9	39.4	32.6	25.7	24.0	
	5% MCDB	26.4	29.3	21.5	29.9	35.6	46.1	52.2	50.8	42.7	34.7	27.7	25.8	
	10% WB	21.7	22.4	16.3	21.7	32.1	40.0	45.3	44.5	37.8	30.9	22.7	19.4	
	10% MCDB	23.4	23.9	18.0	24.0	34.0	43.6	50.2	48.8	40.9	33.1	24.9	21.5	
(35) Mean Daily Temperature Range	MDBR	11.5	12.0	12.6	13.4	9.4	9.6	10.3	9.9	7.6	6.5	9.4	10.8	
	5% DB	12.6	9.1	11.0	15.8	12.0	14.0	15.6	14.7	11.0	7.1	10.8	12.5	
	5% MCWBR	11.6	8.6	9.7	12.8	8.4	8.9	9.0	8.6	7.3	5.4	9.5	11.0	
	5% WB	12.5	9.0	11.1	14.5	10.7	13.3	14.2	12.9	9.2	5.0	10.1	13.3	
	5% MCWBR	11.5	8.4	9.7	11.8	7.7	8.9	8.7	8.2	6.9	4.5	9.2	11.2	
	5% WB	12.5	9.0	11.1	14.5	10.7	13.3	14.2	12.9	9.2	5.0	10.1	13.3	
(40) Clear-Sky Solar Irradiance	taub	N/A	0.201	0.250	0.291	0.309	0.311	0.313	0.301	0.269	0.209	N/A	N/A	
	taud	N/A	1.979	2.149	2.081	2.089	2.206	2.336	2.373	2.343	2.003	N/A	N/A	
	Ebn at Noon	0	158	239	262	272	277	273	262	235	145	0	0	
	Edh at Noon	0	12	23	35	39	36	31	26	19	11	0	0	
(44) All-Sky Solar Radiation	RadAvg	0	89	561	1331	2012	2237	1689	1124	528	153	0	0	
	RadStd	0	13	33	73	78	156	148	167	81	30	0	0	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page