

NERLERIT INAAAT CONSTABLE PT, Greenland

WMO: 043410

Lat: 70.750N

Lon: 22.650W

Elev: 10

StdP: 101.20

Time Zone: -1.00 (AZR)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-29.2	-27.1	-33.5	0.2	-27.6	-31.5	0.2	-25.9	19.6	-9.5	18.2	-9.5	1.4	170	1.006

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.7	13.4	8.2	11.5	7.4	10.1	6.8	8.8	12.4	7.9	10.7	7.0	9.6	4.7	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.6	6.0	9.6	5.8	5.7	8.8	4.9	5.4	8.1	26.5	12.4	24.5	11.0	22.8	9.8	13.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.1	13.0	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	-31.3	10.3	2.0	0.8	-32.8	10.9	-33.9	11.4	-35.0	11.8	-36.5	12.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-5.9	-14.0	-15.3	-16.4	-11.5	-2.8	3.1	6.6	6.4	2.1	-4.5	-11.4	-13.5		
	DBStd	9.63	6.52	7.32	5.76	5.05	3.46	2.56	2.43	2.23	2.46	4.12	4.94	5.50		
	HDD10.0	5804	746	709	818	646	396	208	109	113	236	449	643	730		
	HDD18.3	8839	1004	943	1077	896	654	458	364	368	486	708	893	988		
	CDD10.0	6	0	0	0	0	0	1	3	2	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	4.5	5.8	4.8	4.3	3.9	4.0	3.7	4.3	4.2	4.4	4.6	4.6	5.4		
	PrecAvg	598	76	63	52	36	29	20	30	48	61	57	58	67		
(15) Precipitation	PrecMax	987	262	203	108	134	88	71	104	106	182	133	132	202		
	PrecMin	376	21	11	13	8	2	5	9	9	14	14	5	6		
	PrecStd	174	54	43	25	27	23	16	18	26	38	34	31	48		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.8	2.0	-1.2	4.5	7.0	13.1	16.8	15.9	9.2	3.7	1.6	4.0		
		MCWB	-0.7	0.5	-3.3	1.4	2.4	8.1	9.9	8.7	4.7	1.8	0.2	0.7		
	2%	DB	-1.9	0.1	-3.8	1.8	3.8	10.0	13.9	13.2	7.8	2.7	-0.6	-1.2		
		MCWB	-3.0	-0.9	-4.9	-0.1	1.2	6.5	8.5	8.0	4.1	1.0	-2.0	-2.5		
	5%	DB	-3.1	-1.8	-5.8	-1.5	2.2	8.2	12.0	11.5	6.5	1.9	-2.2	-3.5		
		MCWB	-4.1	-2.6	-6.8	-2.9	0.3	5.2	7.9	7.0	3.5	0.1	-3.5	-4.6		
	10%	DB	-4.8	-4.6	-7.8	-4.4	1.2	6.8	10.4	10.1	5.4	0.8	-4.0	-5.9		
		MCWB	-5.7	-5.7	-8.9	-5.9	-0.3	4.3	7.3	6.6	2.9	-0.8	-5.2	-6.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.8	0.7	-2.9	1.8	2.8	8.3	10.6	9.8	6.5	2.3	0.3	0.5		
		MCDB	0.2	1.6	-1.9	4.1	5.8	12.6	14.7	14.3	7.8	3.4	1.3	5.1		
	2%	WB	-2.8	-0.7	-4.7	0.0	1.5	6.6	9.2	8.5	5.1	1.4	-1.8	-2.5		
		MCDB	-1.9	0.4	-3.5	1.5	3.4	9.5	12.8	11.9	6.6	2.4	-0.8	-1.4		
	5%	WB	-3.9	-2.4	-6.8	-2.9	0.7	5.5	8.2	7.7	4.1	0.4	-3.5	-4.4		
		MCDB	-3.1	-1.5	-5.8	-1.1	2.0	7.8	11.2	10.4	5.9	1.5	-2.4	-3.4		
	10%	WB	-5.7	-5.4	-8.7	-5.7	0.1	4.5	7.4	6.9	3.2	-0.6	-5.2	-7.0		
		MCDB	-4.8	-4.5	-7.8	-4.4	1.1	6.4	10.1	9.3	4.9	0.6	-4.0	-5.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	6.7	7.0	7.4	5.2	5.3	5.7	5.5	4.2	3.6	5.2	6.0		
		MCDBR	7.0	5.1	6.1	8.8	6.7	7.8	8.7	8.2	6.1	4.0	6.0	7.0		
		MCWBR	6.4	4.8	5.4	7.1	4.7	4.9	5.0	4.8	4.0	3.0	5.3	6.1		
		MCDBR	6.9	5.0	6.2	8.1	6.0	7.4	7.9	7.1	5.1	2.8	5.6	7.4		
	5% WB	MCWBR	6.4	4.7	5.4	6.5	4.3	5.0	4.8	4.6	3.8	2.5	5.1	6.2		
(40) Clear-Sky Solar Irradiance	taub		N/A	0.201	0.250	0.291	0.309	0.311	0.313	0.301	0.269	0.209	N/A	N/A		
	taud		N/A	1.979	2.149	2.081	2.089	2.206	2.336	2.373	2.343	2.003	N/A	N/A		
	Ebn at Noon		0	498	753	827	859	873	860	826	741	456	0	0		
	Edh at Noon		0	37	72	109	124	115	98	82	60	34	0	0		
(44) All-Sky Solar Radiation	RadAvg		0.00	0.28	1.77	4.20	6.34	7.05	5.33	3.54	1.66	0.48	0.00	0.00		
	RadStd		0.00	0.04	0.10	0.23	0.25	0.49	0.47	0.53	0.26	0.09	0.00	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page