

TASIILAQ AMMASSALIK, Greenland

WMO: 043600

Lat: 65.6111N

Lon: 37.6367W

Elev: 52

StdP: 100.70

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-17.1	-15.3	-23.7	0.4	-15.6	-21.6	0.5	-13.4	18.0	-7.6	14.9	-7.1	4.4	280	0.811

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	13.7	8.2	12.2	7.9	11.0	7.5	9.4	12.0	8.6	11.1	8.0	10.3	3.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.0	6.7	9.7	7.2	6.3	9.1	6.5	6.0	8.5	28.1	12.1	26.3	11.2	25.0	10.4	14.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	9.7	7.3	DB	-19.0	17.5	2.7	2.8	-20.9	19.5	-22.5	21.1	-24.0	22.7	-25.9	24.7	(4)
(5)			WB	-19.3	11.0	2.4	1.5	-21.1	12.0	-22.5	12.9	-23.8	13.8	-25.6	14.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.1	-5.9	-5.9	-5.8	-2.0	1.4	4.8	7.3	7.1	4.5	0.0	-2.6	-4.7	(6)	
	DBStd	5.98	4.92	4.62	4.35	3.48	2.33	2.47	2.32	1.95	2.22	3.24	3.47	4.53	(7)	
	HDD10.0	3702	494	444	489	361	268	156	89	91	166	309	378	457	(8)	
	HDD18.3	6736	752	678	747	611	526	405	343	347	416	567	628	715	(9)	
	CDD10.0	7	0	0	0	0	0	1	4	2	0	0	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	2.3	2.6	2.9	2.7	2.4	1.9	2.0	1.8	1.7	2.1	2.2	2.9	2.9	(14)	
(15) Precipitation	PrecAvg	910	100	96	95	68	61	42	42	62	83	76	93	98	(15)	
	PrecMax	1380	276	244	288	174	166	113	132	191	234	264	213	263	(16)	
	PrecMin	566	23	22	13	0	6	0	0	5	4	10	9	14	(17)	
	PrecStd	179	61	53	61	42	42	30	34	42	55	43	44	58	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	4.2	5.2	8.1	10.4	14.8	17.5	15.1	11.5	8.8	7.7	6.7	(19)	
		MCWB	2.6	1.7	2.9	4.1	5.0	7.9	9.5	9.4	7.4	5.4	4.3	4.1	(20)	
	2%	DB	3.6	2.9	3.3	5.4	7.6	12.0	14.2	12.9	9.8	7.2	4.9	4.6	(21)	
		MCWB	2.1	1.2	1.9	3.1	4.4	7.2	8.5	8.3	6.1	4.8	2.9	2.6	(22)	
	5%	DB	2.2	1.8	1.8	4.2	6.0	10.2	12.6	11.7	8.8	5.9	3.4	3.1	(23)	
		MCWB	0.8	0.2	0.5	2.2	3.5	6.6	8.3	7.9	5.9	4.0	1.6	1.5	(24)	
	10%	DB	0.7	0.5	0.2	3.0	4.8	8.9	11.2	10.5	7.8	4.6	2.1	1.4	(25)	
		MCWB	-0.6	-0.9	-1.0	1.3	2.6	6.0	7.8	7.5	5.2	2.8	0.5	0.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	2.9	3.3	4.8	6.2	9.2	11.0	10.3	8.8	6.7	4.8	5.0	(27)	
		MCDB	4.1	3.6	4.5	7.2	8.2	12.2	15.1	12.8	10.3	8.0	7.5	5.9	(28)	
	2%	WB	2.3	1.6	2.2	3.6	4.9	8.0	9.6	9.2	7.5	5.3	3.2	3.0	(29)	
		MCDB	3.2	2.5	3.2	5.1	7.0	10.8	12.4	11.5	9.1	6.7	4.6	4.4	(30)	
	5%	WB	1.0	0.4	0.6	2.5	3.8	7.1	8.8	8.6	6.6	4.4	2.0	1.7	(31)	
		MCDB	2.0	1.4	1.5	3.8	5.5	9.6	11.6	10.7	8.0	5.6	3.1	2.9	(32)	
	10%	WB	-0.3	-0.8	-0.8	1.5	3.0	6.3	8.1	8.0	5.8	3.0	0.8	0.1	(33)	
		MCDB	0.5	0.4	0.1	2.7	4.5	8.5	10.8	10.0	7.2	4.2	1.7	1.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	4.9	5.4	5.4	5.1	6.0	6.2	5.3	4.3	3.7	3.9	4.1	(35)	
		MCDBR	5.3	5.0	5.5	5.7	6.8	8.2	8.4	7.0	5.5	4.6	4.9	5.0	(36)	
	5% WB	MCWBR	4.1	4.0	4.3	4.1	4.4	4.9	4.6	3.8	3.4	3.1	3.7	3.8	(37)	
		MCDDBR	5.1	4.7	5.4	5.3	6.0	7.2	7.2	5.8	4.6	3.9	4.7	4.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.213	0.263	0.271	0.306	0.322	0.322	0.325	0.318	0.300	0.265	0.368	N/A	(40)	
		taud	1.870	2.083	2.240	2.145	2.158	2.290	2.381	2.419	2.412	2.218	2.764	N/A	(41)	
	Edn at Noon	Edn at Noon	225	599	808	855	875	887	874	846	777	599	281	N/A	(42)	
		Edh at Noon	22	58	80	113	124	112	100	87	69	49	21	N/A	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.08	0.54	1.97	4.05	5.75	6.16	5.36	3.93	2.01	0.80	0.15	0.02	(44)	
	RadStd	RadStd	0.01	0.14	0.26	0.46	0.75	0.81	0.37	0.26	0.32	0.11	0.02	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+1.17	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)		+1.17	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page