

KULUSUK, Greenland

WMO: 043610

Lat: 65.5745N

Lon: 37.1325W

Elev: 121

StdP: 14.63

Time Zone: -3.00 (GRL)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	3.0	6.5	-11.4	3.0	6.7	-6.9	3.8	9.6	56.5	28.7	50.8	28.1	7.5	320	0.933

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	54.2	45.6	52.0	44.7	50.1	44.2	47.5	51.4	46.1	49.9	45.0	48.7	9.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
45.0	44.4	47.7	43.7	42.2	46.9	42.4	40.1	46.0	19.0	51.4	18.3	50.2	17.7	49.0	53.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
47.4	40.9	34.2	DB	1.3	61.2	4.8	3.4	-2.2	63.6	-5.1	65.6	-7.8	67.5	-11.3	70.0
			WB	0.2	51.0	4.2	1.9	-2.8	52.4	-5.2	53.5	-7.6	54.5	-10.6	55.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.9	23.4	22.5	22.3	27.6	33.2	39.3	44.0	44.3	39.9	32.7	28.3	24.2
	DBStd	9.79	7.92	8.29	7.01	5.77	3.64	4.05	3.74	3.31	3.39	5.04	5.47	7.12
	HDD50	6631	826	771	857	673	521	320	189	180	304	538	651	801
	HDD65	12101	1291	1191	1322	1123	986	770	651	643	754	1003	1101	1266
	CDD50	5	0	0	0	0	0	0	3	2	0	0	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	11.6	15.8	14.6	13.6	13.3	10.4	8.6	7.7	7.6	10.2	10.6	13.4	13.3
Precipitation	PrecAvg	34.7	3.7	3.5	4.1	2.3	2.5	2.2	1.7	2.2	3.3	2.9	3.5	3.5
	PrecMax	47.4	9.9	6.9	10.8	6.5	12.9	22.2	7.2	5.0	9.0	10.1	8.1	8.9
	PrecMin	24.0	1.7	0.8	0.6	0.2	0.4	0.1	0.0	0.3	0.4	0.5	0.4	0.9
	PrecStd	6.2	2.1	1.7	2.2	1.7	2.5	4.1	1.7	1.3	2.2	1.9	2.0	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.8	40.6	43.0	42.9	45.8	54.2	59.3	57.1	50.4	46.3	43.9	40.8
		MCWB	34.2	34.3	33.9	38.2	38.7	44.3	47.4	46.5	44.7	40.5	36.6	36.8
	2%	DB	37.3	36.7	37.7	39.5	42.6	50.3	55.3	53.8	48.2	43.1	39.1	38.5
		MCWB	34.4	33.9	34.7	36.3	37.8	43.2	46.2	45.2	42.5	39.0	35.3	34.8
	5%	DB	35.3	34.6	35.5	37.7	40.6	48.1	52.8	51.7	46.4	41.4	37.3	35.7
		MCWB	32.5	31.9	33.2	34.6	36.5	42.6	45.3	44.4	41.2	38.1	34.0	33.3
	10%	DB	32.7	32.4	32.1	35.8	38.8	46.1	50.3	49.9	44.9	39.5	35.4	33.6
		MCWB	30.0	30.1	29.9	33.0	35.2	41.2	44.4	44.3	40.7	36.2	32.5	31.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.7	37.2	36.9	38.8	41.0	46.8	50.4	48.6	48.1	41.9	37.6	39.1
		MCDB	37.5	37.7	38.5	41.3	44.2	50.9	55.4	52.4	48.8	43.7	41.1	39.6
	2%	WB	34.7	34.2	35.0	37.0	38.7	44.6	47.8	47.3	43.9	40.2	35.9	35.4
		MCDB	36.3	36.1	37.3	39.3	41.0	48.4	52.5	50.8	46.2	42.3	38.3	37.0
	5%	WB	32.6	32.3	32.9	35.1	36.9	43.0	46.3	46.1	42.7	38.8	34.3	33.5
		MCDB	34.7	34.2	35.5	37.0	39.4	46.7	50.6	49.4	45.0	41.1	36.4	35.3
	10%	WB	30.8	30.5	30.1	33.4	35.4	41.7	45.1	45.0	41.5	36.7	32.7	31.5
		MCDB	32.4	32.2	31.4	35.3	38.0	45.1	49.4	48.5	44.0	39.0	34.6	33.3
Mean Daily Temperature Range	5% DB	MDBR	8.0	8.5	9.0	7.8	7.4	9.5	10.4	9.1	6.6	5.7	6.2	7.0
		MCDBR	10.0	10.7	13.5	8.4	9.5	12.8	14.0	11.4	8.1	6.9	7.4	8.4
		MCWBR	7.8	9.0	10.2	6.2	6.4	8.1	8.2	6.6	5.7	5.4	5.6	6.9
	5% WB	MCDBR	9.0	10.8	12.8	7.9	8.5	11.0	12.4	9.8	6.6	6.0	6.7	6.9
		MCWBR	7.6	9.2	9.8	6.0	6.3	7.7	8.1	6.6	5.2	5.2	5.5	6.3
Clear-Sky Solar Irradiance	taub	N/A	0.266	0.281	0.314	0.329	0.325	0.329	0.326	0.307	0.268	0.366	0.367	
	taud	N/A	2.091	2.223	2.134	2.157	2.301	2.397	2.425	2.418	2.241	2.744	2.768	
	Ebn at Noon	N/A	189	252	268	276	280	276	266	244	190	88	37	
	Edh at Noon	N/A	18	26	36	40	35	31	28	22	15	6	4	
All-Sky Solar Radiation	RadAvg	26	168	605	1253	1772	1887	1644	1213	616	243	46	6	
	RadStd	3	43	87	154	260	268	119	86	103	34	5	1	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		+2.11	N/A	N/A	N/A	+0.99	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page