

KULUSUK, Greenland

WMO: 043610

Lat: 65.5745N

Lon: 37.1325W

Elev: 37

StdP: 100.88

Time Zone: -3.00 (GRL)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	-16.1	-14.2	-24.1	0.4	-14.1	-21.6	0.5	-12.5	25.3	-1.9	22.7	-2.2	3.4	320	0.933

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.0	12.3	7.5	11.1	7.1	10.0	6.8	8.6	10.8	7.9	10.0	7.2	9.3	4.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.2	6.3	8.7	6.5	6.0	8.3	5.8	5.7	7.8	26.2	10.8	24.6	10.1	23.3	9.4	11.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.2	18.3	15.3	DB	-17.1	16.2	2.7	1.9	-19.0	17.6	-20.6	18.7	-22.1	19.7	-24.0	21.1	(4)
(5)			WB	-17.7	10.6	2.3	1.0	-19.3	11.3	-20.7	11.9	-22.0	12.5	-23.7	13.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.1	-4.8	-5.3	-5.4	-2.5	0.7	4.1	6.7	6.8	4.4	0.4	-2.1	-4.4	(6)
(7)		DBStd	5.44	4.40	4.61	3.89	3.20	2.02	2.25	2.08	1.84	1.88	2.80	3.04	3.96	(7)
(8)		HDD10.0	3684	459	428	476	374	289	178	105	100	169	299	362	445	(8)
(9)		HDD18.3	6723	717	662	734	624	548	428	362	357	419	557	612	703	(9)
(10)		CDD10.0	3	0	0	0	0	0	0	2	1	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.2	7.1	6.5	6.1	5.9	4.6	3.9	3.4	3.4	4.6	4.7	6.0	5.9	(14)
(15)	Precipitation	PrecAvg	882	95	90	103	59	63	57	44	57	85	73	88	89	(15)
(16)		PrecMax	1205	252	174	274	165	327	565	183	128	229	257	206	225	(16)
(17)		PrecMin	610	42	21	14	5	10	3	1	8	11	12	11	22	(17)
(18)		PrecStd	158	53	43	55	42	63	105	42	32	57	48	50	57	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	4.8	6.1	6.1	7.7	12.4	15.2	13.9	10.2	8.0	6.6	4.9	(19)
(20)			MCWB	1.2	1.3	1.1	3.5	3.7	6.8	8.5	8.1	7.1	4.7	2.6	2.6	(20)
(21)		2%	DB	3.0	2.6	3.1	4.2	5.9	10.2	13.0	12.1	9.0	6.2	3.9	3.6	(21)
(22)			MCWB	1.3	1.0	1.5	2.4	3.2	6.2	7.9	7.4	5.8	3.9	1.8	1.5	(22)
(23)		5%	DB	1.9	1.4	2.0	3.1	4.8	9.0	11.5	11.0	8.0	5.2	2.9	2.1	(23)
(24)			MCWB	0.3	0.0	0.7	1.4	2.5	5.9	7.4	6.9	5.1	3.4	1.1	0.7	(24)
(25)		10%	DB	0.4	0.2	0.0	2.1	3.8	7.8	10.2	10.0	7.2	4.2	1.9	0.9	(25)
(26)			MCWB	-1.1	-1.1	-1.1	0.5	1.8	5.1	6.9	6.9	4.8	2.3	0.3	-0.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.6	2.9	2.7	3.8	5.0	8.2	10.2	9.2	9.0	5.5	3.1	4.0	(27)
(28)			MCDWB	3.1	3.2	3.6	5.1	6.8	10.5	13.0	11.3	9.3	6.5	5.1	4.2	(28)
(29)		2%	WB	1.5	1.2	1.7	2.8	3.7	7.0	8.8	8.5	6.6	4.5	2.2	1.9	(29)
(30)			MCDWB	2.4	2.3	3.0	4.0	5.0	9.1	11.4	10.4	7.9	5.7	3.5	2.8	(30)
(31)		5%	WB	0.3	0.2	0.5	1.7	2.7	6.1	8.0	7.8	5.9	3.8	1.3	0.8	(31)
(32)			MCDWB	1.5	1.2	1.9	2.8	4.1	8.1	10.3	9.7	7.2	5.0	2.4	1.8	(32)
(33)		10%	WB	-0.7	-0.9	-1.0	0.8	1.9	5.4	7.3	7.2	5.3	2.6	0.4	-0.3	(33)
(34)			MCDWB	0.2	0.1	-0.3	1.8	3.3	7.3	9.7	9.2	6.6	3.9	1.5	0.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	4.7	5.0	4.4	4.1	5.3	5.8	5.0	3.7	3.1	3.4	3.9	(35)
(36)			MCDBR	5.5	6.0	7.5	4.7	5.3	7.1	7.8	6.3	4.5	3.8	4.1	4.7	(36)
(37)			MCWBR	4.3	5.0	5.7	3.4	3.5	4.5	4.6	3.7	3.1	3.0	3.1	3.8	(37)
(38)		5% WB	MCDBR	5.0	6.0	7.1	4.4	4.7	6.1	6.9	5.4	3.7	3.4	3.7	3.8	(38)
(39)			MCWBR	4.2	5.1	5.4	3.3	3.5	4.3	4.5	3.6	2.9	2.9	3.0	3.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.266	0.281	0.314	0.329	0.325	0.329	0.326	0.307	0.268	0.366	0.367	(40)	
(41)		taud	N/A	2.091	2.223	2.134	2.157	2.301	2.397	2.425	2.418	2.241	2.744	2.768	(41)	
(42)		Ebn at Noon	N/A	596	793	844	869	884	871	837	768	600	278	116	(42)	
(43)		Edh at Noon	N/A	58	82	115	125	111	98	87	69	48	20	12	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.08	0.53	1.91	3.95	5.59	5.95	5.18	3.82	1.94	0.77	0.15	0.02	(44)	
(45)		RadStd	0.01	0.14	0.28	0.48	0.82	0.84	0.38	0.27	0.32	0.11	0.02	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (2 neighbors)		+1.17	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page