

IKERMIT, Greenland

WMO: 043730

Lat: 64.782N

Lon: 40.302W

Elev: 80

StdP: 100.37

Time Zone: -3.00 (GRL)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.2	-13.9	-21.4	0.6	-13.2	-20.0	0.6	-12.5	34.0	-9.1	31.0	-10.7	18.0	310	1.004

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	12.4	6.9	11.0	6.2	9.9	5.7	7.9	10.6	7.0	9.8	6.3	8.8	4.3	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.9	6.2	7.5	5.6	5.7	6.7	4.7	5.3	6.1	24.9	10.5	22.8	9.8	21.3	9.0	13.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.5	24.6	20.4	DB	-17.1	15.2	2.1	1.2	-18.7	16.1	-19.9	16.8	-21.1	17.4	-22.7	18.3	(4)
(5)			WB	-17.6	9.3	2.0	1.5	-19.0	10.4	-20.1	11.3	-21.3	12.1	-22.7	13.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.8	-5.7	-6.5	-6.3	-2.7	0.5	3.8	6.3	6.0	2.9	-0.8	-3.2	-4.9
	DBStd	5.41	3.86	3.82	3.61	3.07	2.17	2.57	2.42	2.11	2.06	2.71	2.85	3.43
	HDD10.0	3961	488	461	505	382	293	186	116	125	213	336	395	462
	HDD18.3	6999	747	694	763	632	551	436	372	382	463	594	645	720
	CDD10.0	4	0	0	0	0	0	1	2	1	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	6.9	9.1	9.1	8.2	6.9	4.6	3.3	3.2	3.8	6.5	8.4	9.8	9.7
Precipitation	PrecAvg	1366	140	132	124	109	83	81	63	94	124	119	161	138
	PrecMax	2074	335	314	235	254	167	167	180	159	242	301	332	353
	PrecMin	763	27	19	28	6	21	17	3	24	13	19	36	14
	PrecStd	334	74	75	58	54	39	43	43	34	56	69	82	83
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.6	1.4	3.1	8.0	10.1	13.7	14.5	13.7	9.1	6.9	6.0	5.5
		MCWB	-0.1	-0.2	0.8	4.1	5.0	7.4	8.7	7.4	3.9	2.3	2.0	1.2
	2%	DB	1.2	0.2	0.9	4.3	7.0	11.0	12.5	12.0	7.7	4.7	2.0	2.0
		MCWB	-0.4	-0.4	0.1	1.4	2.9	5.8	7.2	6.3	3.5	1.7	0.2	0.1
	5%	DB	0.1	-0.4	0.0	2.3	5.2	9.3	11.1	10.7	6.8	3.7	1.1	0.2
		MCWB	-0.7	-0.9	-0.5	0.6	2.3	5.3	6.6	5.6	3.1	1.3	-0.4	-0.6
	10%	DB	-0.8	-1.3	-1.0	1.0	3.8	7.7	10.1	9.3	5.8	2.7	0.2	-0.5
		MCWB	-1.5	-1.8	-1.7	-0.2	1.4	4.8	6.2	5.0	2.6	0.8	-0.8	-1.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.0	0.7	1.9	4.8	5.6	8.5	10.4	7.7	6.8	4.1	3.1	2.1
		MCDB	1.4	0.7	2.6	6.2	8.5	11.0	11.8	11.8	7.1	5.2	5.7	4.0
	2%	WB	0.1	0.0	0.4	2.1	4.1	7.0	8.8	6.9	4.9	3.1	1.1	0.7
		MCDB	0.7	0.1	0.6	3.1	6.2	9.8	10.6	10.2	5.9	3.8	1.7	1.8
	5%	WB	-0.5	-0.8	-0.3	1.0	2.8	6.0	7.5	6.3	4.2	2.2	0.2	-0.2
		MCDB	0.1	-0.5	-0.1	2.0	4.2	8.4	10.0	9.1	5.3	3.0	0.5	0.2
	10%	WB	-1.4	-1.6	-1.5	0.2	1.9	5.2	6.6	5.7	3.6	1.2	-0.4	-1.1
		MCDB	-0.8	-1.3	-1.1	0.8	3.2	7.3	9.3	8.2	4.8	2.3	0.0	-0.6
Mean Daily Temperature Range	5% DB	MDBR	3.5	3.7	4.1	4.3	4.3	4.7	4.8	4.5	3.5	2.9	2.9	3.2
		MCDBR	3.8	3.9	4.0	5.8	7.1	7.3	6.2	6.4	4.7	4.2	3.8	3.6
		MCWBR	3.3	3.7	3.4	4.2	4.4	4.0	3.4	3.3	2.8	3.0	3.0	3.2
	5% WB	MCDBR	3.8	3.4	3.5	5.1	6.0	6.0	5.7	5.3	3.7	3.7	3.3	3.3
		MCWBR	3.6	3.5	3.5	3.9	4.3	4.1	3.8	3.2	2.9	3.0	3.1	3.2
Clear-Sky Solar Irradiance	taub	0.201	0.264	0.275	0.313	0.325	0.331	0.329	0.317	0.296	0.270	0.188	N/A	
	taud	1.881	2.077	2.201	2.095	2.119	2.247	2.358	2.413	2.412	2.221	1.939	N/A	
	Ebn at Noon	303	619	810	850	875	879	873	851	790	615	323	N/A	
	Edh at Noon	26	61	85	121	130	118	103	88	70	52	22	N/A	
All-Sky Solar Radiation	RadAvg	0.14	0.84	2.59	4.93	7.04	7.53	6.85	5.14	2.93	1.29	0.28	0.05	
	RadStd	0.01	0.07	0.11	0.24	0.29	0.48	0.24	0.19	0.18	0.11	0.01	0.00	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+1.17	N/A	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page