

VAGAR AP, Faroe Islands

WMO: 060100

Lat: 62.066N

Lon: 7.285W

Elev: 280

StdP: 14.55

Time Zone: 0.00 (EUW)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.8	26.8	16.7	12.9	27.6	19.2	14.6	29.3	44.3	35.9	40.7	38.3	14.7	330	0.841

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	59.2	55.1	57.1	53.7	55.5	52.5	56.0	58.4	54.6	56.5	53.6	55.1	12.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
55.2	65.4	57.3	53.7	62.0	55.1	52.2	58.7	53.6	23.9	58.2	22.9	56.6	22.3	54.8	65.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
38.8	33.3	29.4	DB	20.3	65.5	4.2	3.7	17.3	68.1	14.8	70.3	12.4	72.3	9.4	75.0
			WB	18.9	59.7	3.5	2.9	16.3	61.8	14.3	63.5	12.3	65.2	9.7	67.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.9	38.6	38.3	38.5	40.6	44.4	48.1	51.4	51.6	49.5	45.6	41.3	38.7
	DBStd	6.54	4.73	5.00	4.80	4.89	3.97	3.12	2.98	2.72	3.21	3.97	4.78	5.47
	HDD50	2389	352	328	356	281	176	70	16	14	46	140	261	349
	HDD65	7691	817	748	821	731	638	507	422	416	466	601	710	814
	CDD50	172	0	0	0	0	3	13	59	63	30	4	0	0
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
	WSAvg	14.0	15.9	16.3	14.9	13.9	12.6	11.6	11.0	11.3	13.9	14.7	15.4	16.1
	PrecAvg	90.9	11.0	8.7	8.6	6.5	4.7	3.6	3.7	4.9	8.1	10.0	10.9	10.0
(15) Precipitation	PrecMax	108.9	18.6	16.2	14.9	10.7	8.8	7.2	6.0	8.2	13.4	17.1	15.9	15.8
	PrecMin	69.9	6.7	4.3	4.8	2.3	1.5	1.1	0.6	2.8	3.4	5.7	5.7	4.7
	PrecStd	9.5	2.8	3.0	2.8	2.2	1.9	1.6	1.3	1.5	3.2	3.2	2.9	3.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	48.5	48.5	52.1	57.4	57.6	64.8	63.2	58.9	53.8	51.6	49.3
		MCWB	47.5	47.4	47.1	47.8	51.5	52.1	58.2	58.1	54.7	51.2	49.6	48.2
	2%	DB	47.7	47.6	46.8	50.0	53.5	55.4	60.4	58.6	55.7	52.2	50.2	48.4
		MCWB	46.9	46.8	45.9	47.0	49.0	50.8	56.6	54.9	53.0	50.2	49.2	47.7
	5%	DB	46.4	46.4	46.4	48.2	51.4	53.7	57.3	56.8	54.0	51.7	48.9	47.8
		MCWB	45.5	45.4	45.5	46.4	48.0	49.9	54.2	53.6	52.0	49.9	48.0	47.1
	10%	DB	44.9	44.9	45.0	46.6	49.8	52.1	55.5	55.4	53.6	50.4	48.2	46.4
		MCWB	43.7	43.7	43.7	45.2	47.3	49.3	52.9	52.6	51.7	49.0	47.2	45.3
	0.4%	WB	48.1	47.8	47.5	49.1	53.0	54.0	60.3	58.1	55.5	52.2	50.4	48.6
		MCDB	48.2	48.0	47.6	50.5	55.6	56.5	63.9	61.6	57.8	52.8	51.0	48.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.6	46.6	46.4	47.5	50.2	52.2	57.0	55.6	53.9	51.3	49.2	47.9
		MCDB	47.0	47.0	46.6	48.6	51.7	54.0	59.5	57.8	55.4	51.9	49.6	48.1
	5%	WB	45.3	45.3	45.4	46.5	48.7	51.3	55.0	54.4	53.1	50.3	48.2	46.6
		MCDB	45.9	45.9	45.8	47.5	50.1	52.8	57.0	56.1	54.3	51.0	48.5	47.0
	10%	WB	43.8	43.9	43.9	45.5	47.5	50.3	53.6	53.5	52.2	49.6	47.1	45.1
		MCDB	44.6	44.8	44.7	46.4	49.0	51.6	55.3	54.9	53.4	50.3	47.8	45.9
	5% DB	MDBR	6.3	6.6	7.1	7.3	7.5	6.9	6.6	6.5	5.7	5.8	6.2	6.7
		MCDBR	6.5	7.2	6.8	7.4	9.5	8.5	9.6	8.4	6.3	5.4	5.5	7.2
		MCWBR	7.4	8.0	7.1	6.0	6.4	6.1	6.7	6.0	5.1	5.4	6.4	8.3
		MCWBR	6.4	6.8	6.5	6.5	7.5	7.2	9.2	7.1	5.8	5.3	5.6	7.1
(35) Mean Daily Temperature Range	5% WB	MCWBR	7.5	7.7	7.3	6.2	5.9	5.8	6.8	5.7	5.1	5.9	6.9	8.3
(40) Clear-Sky Solar Irradiance	taub		0.306	0.343	0.354	0.377	0.368	0.360	0.365	0.356	0.359	0.336	0.295	0.378
	taud		2.047	2.194	2.306	2.287	2.389	2.456	2.468	2.494	2.409	2.299	2.088	2.391
	Ebn at Noon		106	187	237	256	270	274	270	263	236	190	109	63
	Edh at Noon		12	22	27	34	33	31	30	27	25	19	11	8
(44) All-Sky Solar Radiation	RadAvg		54	191	514	972	1387	1502	1351	1080	653	281	78	31
	RadStd		5	23	46	76	109	146	85	102	45	24	8	1

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+0.92	+2.05	N/A	N/A	N/A	N/A	N/A	N/A	+54	N/A

Nomenclature: See separate page