

VAGAR AP, Faroe Islands

WMO: 060100

Lat: 62.066N

Lon: 7.285W

Elev: 85

StdP: 100.30

Time Zone: 0.00 (EUW)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-4.0	-2.9	-8.5	1.8	-2.4	-7.1	2.1	-1.5	19.8	2.2	18.2	3.5	6.6	330	0.841

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.6	15.1	12.8	14.0	12.1	13.1	11.4	13.4	14.6	12.5	13.6	12.0	12.8	5.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.9	9.3	14.0	12.1	8.9	12.8	11.2	8.4	12.0	37.7	14.6	35.3	13.6	34.1	12.6	18.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.3	14.9	13.2	DB	-6.5	18.6	2.3	2.0	-8.2	20.1	-9.6	21.3	-10.9	22.4	-12.6	23.9	(4)
(5)			WB	-7.3	15.4	2.0	1.6	-8.7	16.6	-9.9	17.5	-11.0	18.4	-12.4	19.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.6	3.7	3.5	3.6	4.8	6.9	8.9	10.8	10.9	9.7	7.6	5.2	3.7	(6)	
	DBStd	3.64	2.63	2.78	2.67	2.72	2.20	1.73	1.66	1.51	1.78	2.21	2.65	3.04	(7)	
	HDD10.0	1327	196	182	198	156	98	39	9	8	26	78	145	194	(8)	
	HDD18.3	4273	454	416	456	406	354	282	234	231	259	334	394	452	(9)	
	CDD10.0	96	0	0	0	0	2	7	33	35	17	2	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	6.2	7.1	7.3	6.7	6.2	5.6	5.2	4.9	5.1	6.2	6.6	6.9	7.2	(14)	
(15) Precipitation	PrecAvg	2309	279	222	219	165	119	92	93	125	205	254	276	255	(15)	
	PrecMax	2766	473	412	379	272	223	183	153	209	341	434	405	401	(16)	
	PrecMin	1775	169	108	121	59	37	28	15	71	87	144	146	120	(17)	
	PrecStd	242	71	77	71	55	49	40	33	38	82	82	73	89	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	9.2	9.2	11.2	14.1	14.2	18.2	17.3	15.0	12.1	10.9	9.6	(19)	
		MCWB	8.6	8.6	8.4	8.8	10.8	11.1	14.5	14.5	12.6	10.7	9.8	9.0	(20)	
	2%	DB	8.7	8.7	8.2	10.0	12.0	13.0	15.8	14.8	13.2	11.2	10.1	9.1	(21)	
		MCWB	8.3	8.2	7.7	8.3	9.5	10.5	13.7	12.7	11.7	10.1	9.6	8.7	(22)	
	5%	DB	8.0	8.0	8.0	9.0	10.8	12.0	14.1	13.8	12.2	11.0	9.4	8.8	(23)	
		MCWB	7.5	7.4	7.5	8.0	8.9	10.0	12.3	12.0	11.1	9.9	8.9	8.4	(24)	
	10%	DB	7.2	7.2	7.2	8.1	9.9	11.2	13.1	13.0	12.0	10.2	9.0	8.0	(25)	
		MCWB	6.5	6.5	6.5	7.3	8.5	9.6	11.6	11.4	11.0	9.5	8.5	7.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	8.8	8.6	9.5	11.7	12.2	15.7	14.5	13.1	11.2	10.2	9.2	(27)	
		MCDB	9.0	8.9	8.7	10.3	13.1	13.6	17.7	16.5	14.3	11.6	10.6	9.2	(28)	
	2%	WB	8.1	8.1	8.0	8.6	10.1	11.2	13.9	13.1	12.2	10.7	9.6	8.9	(29)	
		MCDB	8.3	8.3	8.1	9.2	10.9	12.2	15.3	14.3	13.0	11.1	9.8	8.9	(30)	
	5%	WB	7.4	7.4	7.4	8.1	9.3	10.7	12.8	12.5	11.7	10.2	9.0	8.1	(31)	
		MCDB	7.7	7.7	7.7	8.6	10.1	11.6	13.9	13.4	12.4	10.5	9.2	8.4	(32)	
	10%	WB	6.5	6.6	6.6	7.5	8.6	10.2	12.0	12.0	11.2	9.8	8.4	7.3	(33)	
		MCDB	7.0	7.1	7.1	8.0	9.5	10.9	13.0	12.7	11.9	10.2	8.8	7.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.5	3.7	3.9	4.1	4.2	3.8	3.6	3.6	3.1	3.2	3.5	3.7	(35)	
		MCDBR	3.6	4.0	3.8	4.1	5.3	4.7	5.3	4.7	3.5	3.0	3.1	4.0	(36)	
	5% WB	MCWBR	4.1	4.4	4.0	3.4	3.5	3.4	3.7	3.3	2.8	3.0	3.6	4.6	(37)	
		MCWBR	3.6	3.8	3.6	3.6	4.1	4.0	5.1	3.9	3.2	2.9	3.1	3.9	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.306	0.343	0.354	0.377	0.368	0.360	0.365	0.356	0.359	0.336	0.295	0.378	(40)	
		taud	2.047	2.194	2.306	2.287	2.389	2.456	2.468	2.494	2.409	2.299	2.088	2.391	(41)	
	Edn at Noon	Edn at Noon	334	591	748	806	851	865	850	828	743	599	343	200	(42)	
		Edh at Noon	39	68	86	106	104	99	96	86	78	60	36	24	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.17	0.60	1.62	3.06	4.37	4.73	4.26	3.40	2.06	0.89	0.25	0.10	(44)	
	RadStd	RadStd	0.02	0.07	0.14	0.24	0.34	0.46	0.27	0.32	0.14	0.08	0.03	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (3 neighbors)	+0.51	+1.14	N/A	N/A	N/A	N/A	N/A	N/A	+30	N/A

Nomenclature: See separate page