

TORSHAVN, Faroe Islands

WMO: 060110

Lat: 62.0231N

Lon: 6.7647W

Elev: 200

StdP: 14.59

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	25.6	27.8	17.6	13.5	28.3	19.7	14.9	29.5	50.8	40.4	45.3	41.7	12.9	320	0.821

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.2	57.7	54.3	56.4	53.4	55.4	52.8	55.4	56.7	54.4	55.5	53.5	54.7	10.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.7	64.2	55.9	53.7	61.8	54.8	52.8	59.9	54.1	23.5	56.8	22.9	55.8	22.4	54.8	60.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.9	35.2	30.9	22.7	62.1	2.8	2.8	20.6	64.1	19.0	65.8	17.4	67.3	15.3	69.4		
(5)			21.2	57.7	2.6	1.5	19.3	58.7	17.8	59.6	16.4	60.4	14.5	61.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	39.5	38.9	39.6	41.6	44.5	48.3	51.5	52.1	50.2	46.1	42.1	40.0		
	DBStd	6.34	4.84	5.13	4.93	4.60	3.77	2.85	2.26	2.28	3.22	4.34	4.90	5.49		
	HDD50	2178	324	311	324	252	173	64	11	8	35	128	239	309		
	HDD65	7457	789	731	789	702	636	500	418	400	445	585	688	774		
	CDD50	195	0	0	0	0	2	14	58	73	40	8	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	13.0	15.3	15.9	15.6	13.6	11.4	10.2	9.4	9.6	12.5	13.6	15.2	14.2		
	PrecAvg	54.8	6.1	4.6	5.2	3.7	2.8	2.6	3.0	3.5	5.2	6.3	5.9	6.5		
(15) Precipitation	PrecMax	77.0	10.7	9.3	9.9	8.0	7.2	5.3	6.7	9.3	12.6	12.9	10.6	12.7		
	PrecMin	26.8	2.0	1.1	1.0	0.4	0.6	0.2	0.8	0.8	0.0	1.7	2.0	2.6		
	PrecStd	10.2	2.2	2.0	2.0	1.6	1.5	1.2	1.3	1.7	2.4	2.5	2.0	2.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.2	50.2	50.0	51.3	55.4	58.2	59.6	59.7	57.9	55.5	52.2	51.3		
		MCWB	48.1	48.2	47.5	47.9	50.2	53.4	55.5	56.2	54.3	53.4	50.3	49.4		
	2%	DB	48.7	48.6	48.4	49.7	52.4	54.9	57.4	57.7	56.1	53.7	50.6	49.9		
		MCWB	46.8	46.7	46.4	47.2	49.1	51.2	53.9	54.6	53.5	51.7	48.8	48.0		
	5%	DB	47.4	47.4	47.3	48.4	50.5	53.5	55.9	56.4	55.0	52.5	49.6	48.5		
		MCWB	45.6	45.3	45.2	46.3	47.9	50.5	53.1	53.6	52.7	50.7	47.9	46.7		
	10%	DB	46.0	45.9	45.9	47.3	49.2	52.2	54.8	55.3	54.1	51.4	48.8	47.2		
		MCWB	44.0	43.7	43.7	45.3	46.9	49.7	52.4	52.9	52.0	49.8	47.2	45.4		
	0.4%	WB	48.6	49.0	48.3	49.4	52.2	54.6	56.8	57.7	55.7	54.0	51.1	50.2		
		MCDB	49.4	50.2	49.3	50.5	54.1	56.8	58.3	59.3	57.1	54.9	51.9	51.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.4	47.1	46.9	47.9	49.9	52.4	55.1	55.6	54.1	52.2	49.5	48.5		
		MCDB	48.4	48.4	48.1	49.0	51.5	54.0	56.1	56.9	55.3	53.1	50.2	49.4		
	5%	WB	45.9	45.7	45.7	46.8	48.6	51.2	54.1	54.4	53.3	51.2	48.5	47.1		
		MCDB	47.2	47.2	47.0	48.0	49.9	52.6	55.1	55.6	54.4	52.1	49.4	48.2		
	10%	WB	44.4	44.0	44.2	45.7	47.5	50.3	53.1	53.6	52.6	50.3	47.4	45.8		
		MCDB	45.8	45.7	45.5	47.0	48.8	51.6	54.2	54.6	53.7	51.2	48.5	47.1		
	5% DB	MDBR	5.8	6.1	6.1	5.8	5.9	5.5	5.1	5.2	5.2	5.3	5.8	6.1		
		MCDBR	7.1	7.2	6.7	6.2	7.2	7.4	7.0	6.5	5.8	5.5	6.1	7.2		
		MCWBR	7.7	7.7	6.7	5.4	5.5	5.2	4.9	4.6	4.9	5.6	6.7	7.8		
		MCWBR	6.9	7.1	6.7	5.7	6.3	6.2	5.8	5.6	5.4	5.4	6.0	7.0		
(35) Mean Daily Temperature Range	5% WB	MCWBR	7.6	7.8	7.0	5.4	5.4	4.9	4.6	4.6	5.1	5.9	6.9	7.7		
(40) Clear-Sky Solar Irradiance	taub		0.309	0.345	0.355	0.378	0.369	0.361	0.366	0.358	0.359	0.337	0.298	0.378		
	taud		2.047	2.194	2.303	2.287	2.389	2.456	2.468	2.492	2.413	2.302	2.091	2.377		
	Ebn at Noon		105	187	237	255	270	274	270	262	236	190	108	63		
	Edh at Noon		13	22	27	34	33	31	30	27	25	19	11	8		
(44) All-Sky Solar Radiation	RadAvg		55	192	516	976	1392	1506	1354	1084	655	282	79	31		
	RadStd		5	23	46	76	111	147	86	102	46	25	8	1		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.92	+2.05	N/A	N/A	N/A	N/A	N/A	N/A	+54	N/A
(47) Regional (3 neighbors)		+0.92	+2.05	N/A	N/A	N/A	N/A	N/A	N/A	+54	N/A

Nomenclature: See separate page