

TORSHAVN, Faroe Islands

WMO: 060110

Lat: 62.0231N

Lon: 6.7647W

Elev: 61

StdP: 100.59

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.6	-2.3	-8.0	1.9	-2.0	-6.8	2.1	-1.4	22.7	4.7	20.2	5.4	5.8	320	0.821

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.9	14.3	12.4	13.5	11.9	13.0	11.5	13.0	13.7	12.4	13.1	12.0	12.6	4.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
12.6	9.2	13.3	12.1	8.8	12.7	11.6	8.6	12.3	36.9	13.8	35.4	13.2	34.3	12.7	15.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.7	13.8	DB	-5.2	16.7	1.6	1.6	-6.3	17.8	-7.2	18.8	-8.1	19.6	-9.3	20.8	(4)
(5)			WB	-6.0	14.3	1.4	0.8	-7.0	14.8	-7.9	15.3	-8.7	15.8	-9.7	16.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	4.2	3.8	4.2	5.3	6.9	9.1	10.8	11.2	10.1	7.8	5.6	4.5	(6)	
	DBStd	3.52	2.69	2.85	2.74	2.55	2.10	1.58	1.26	1.27	1.79	2.41	2.72	3.05	(7)	
	HDD10.0	1210	180	173	180	140	96	36	6	4	19	71	133	172	(8)	
	HDD18.3	4143	438	406	438	390	353	278	232	222	247	325	382	430	(9)	
	CDD10.0	108	0	0	0	0	1	8	32	41	22	4	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.8	6.8	7.1	7.0	6.1	5.1	4.6	4.2	4.3	5.6	6.1	6.8	6.4	(14)	
(15) Precipitation	PrecAvg	1392	155	116	133	94	72	66	76	90	132	160	149	166	(15)	
	PrecMax	1955	272	236	252	202	184	134	171	236	320	328	268	322	(16)	
	PrecMin	681	50	29	25	10	15	5	21	21	0	42	51	65	(17)	
	PrecStd	260	56	51	52	40	37	30	33	43	62	64	52	65	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.1	10.1	10.0	10.7	13.0	14.6	15.3	15.4	14.4	13.1	11.2	10.7	(19)	
		MCWB	8.9	9.0	8.6	8.8	10.1	11.9	13.1	13.5	12.4	11.9	10.1	9.6	(20)	
	2%	DB	9.3	9.2	9.1	9.8	11.4	12.7	14.1	14.3	13.4	12.1	10.4	9.9	(21)	
		MCWB	8.2	8.2	8.0	8.5	9.5	10.7	12.2	12.6	11.9	10.9	9.4	8.9	(22)	
	5%	DB	8.6	8.5	8.5	9.1	10.3	12.0	13.3	13.5	12.8	11.4	9.8	9.2	(23)	
		MCWB	7.5	7.4	7.3	7.9	8.8	10.3	11.7	12.0	11.5	10.4	8.8	8.2	(24)	
	10%	DB	7.8	7.7	7.7	8.5	9.6	11.2	12.7	13.0	12.3	10.8	9.3	8.5	(25)	
		MCWB	6.7	6.5	6.5	7.4	8.3	9.8	11.4	11.6	11.1	9.9	8.4	7.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	9.5	9.1	9.6	11.2	12.6	13.8	14.3	13.2	12.2	10.6	10.1	(27)	
		MCDB	9.7	10.1	9.6	10.3	12.3	13.8	14.6	15.2	13.9	12.7	11.0	10.5	(28)	
	2%	WB	8.5	8.4	8.3	8.9	10.0	11.3	12.8	13.1	12.3	11.2	9.7	9.2	(29)	
		MCDB	9.1	9.1	8.9	9.5	10.8	12.2	13.4	13.8	13.0	11.7	10.1	9.7	(30)	
	5%	WB	7.7	7.6	7.6	8.2	9.2	10.7	12.3	12.5	11.8	10.7	9.2	8.4	(31)	
		MCDB	8.4	8.4	8.3	8.9	10.0	11.4	12.8	13.1	12.5	11.2	9.6	9.0	(32)	
	10%	WB	6.9	6.7	6.8	7.6	8.6	10.1	11.7	12.0	11.4	10.2	8.6	7.7	(33)	
		MCDB	7.7	7.6	7.5	8.3	9.4	10.9	12.3	12.6	12.1	10.7	9.2	8.4	(34)	
(35) Mean Daily Temperature Range	MDBR		3.2	3.4	3.4	3.2	3.3	3.1	2.8	2.9	2.9	3.0	3.2	3.4	(35)	
	5% DB	MCDBR	4.0	4.0	3.7	3.4	4.0	4.1	3.9	3.6	3.2	3.1	3.4	4.0	(36)	
		MCWBR	4.3	4.3	3.7	3.0	3.1	2.9	2.7	2.5	2.7	3.1	3.7	4.3	(37)	
	5% WB	MCDBR	3.8	3.9	3.7	3.1	3.5	3.2	3.1	3.0	3.0	3.0	3.4	3.9	(38)	
		MCWBR	4.2	4.3	3.9	3.0	3.0	2.7	2.6	2.6	2.8	3.3	3.9	4.3	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.309	0.345	0.355	0.378	0.369	0.361	0.366	0.358	0.359	0.337	0.298	0.378	(40)	
	taud		2.047	2.194	2.303	2.287	2.389	2.456	2.468	2.492	2.413	2.302	2.091	2.377	(41)	
	Ebn at Noon		332	591	747	805	850	865	850	826	743	599	342	199	(42)	
	Edh at Noon		40	68	86	106	104	99	96	86	78	60	36	24	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.17	0.61	1.63	3.08	4.39	4.75	4.27	3.42	2.06	0.89	0.25	0.10	(44)	
	RadStd		0.02	0.07	0.14	0.24	0.35	0.46	0.27	0.32	0.14	0.08	0.03	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.51	+1.14	N/A	N/A	N/A	N/A	N/A	N/A	+30	N/A	(46)
(47)	Regional (3 neighbors)	+0.51	+1.14	N/A	N/A	N/A	N/A	N/A	N/A	+30	N/A	(47)

Nomenclature: See separate page