

SILSTRUP, Denmark

WMO: 060190

Lat: 56.9300N

Lon: 8.6412E

Elev: 135

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	19.5	22.6	14.8	11.7	22.6	17.6	13.4	24.8	57.0	42.8	49.9	41.3	9.0	60	0.755

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.2	76.1	65.0	72.7	63.4	69.7	62.1	66.4	73.3	64.8	70.7	63.2	68.3	10.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.0	89.7	68.8	62.4	84.8	67.1	61.0	80.6	65.7	31.1	73.7	29.9	71.2	28.8	68.4	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
47.7	39.9	32.7	17.9	81.8	4.5	4.0	14.7	84.7	12.0	87.0	9.5	89.2	6.2	92.1
			17.1	69.1	4.5	2.4	13.8	70.9	11.2	72.3	8.6	73.7	5.3	75.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	34.6	34.5	38.2	45.0	51.4	56.7	61.4	61.2	56.8	49.9	43.1	38.4	(6)
	DBStd	10.94	6.28	6.14	5.67	5.03	5.66	4.63	4.79	3.63	3.97	4.47	5.33	6.63	(7)
	HDD50	2124	478	435	367	166	48	1	0	0	1	56	213	359	(8)
	HDD65	6372	943	855	832	599	423	254	136	129	250	469	658	824	(9)
	CDD50	1271	0	0	0	16	91	202	355	347	204	52	4	0	(10)
	CDD65	45	0	0	0	0	1	5	26	11	2	0	0	0	(11)
	CDH74	198	0	0	0	0	1	25	127	39	6	0	0	0	(12)
	CDH80	21	0	0	0	0	0	1	15	5	0	0	0	0	(13)
(14) Wind	WSAvg	14.3	16.3	15.6	15.3	13.0	13.6	13.5	12.3	12.8	13.5	14.5	15.2	16.3	(14)
(15) Precipitation	PrecAvg	32.3	3.0	2.1	1.8	1.7	1.9	2.3	2.4	3.1	3.5	4.0	3.4	3.1	(15)
	PrecMax	42.4	4.7	4.8	3.7	3.7	3.9	5.7	4.0	6.1	7.6	7.7	7.2	6.6	(16)
	PrecMin	21.2	0.4	0.6	0.2	0.4	0.1	0.0	0.4	0.7	1.2	1.2	1.0	0.9	(17)
	PrecStd	5.4	1.2	1.1	0.9	0.9	0.9	1.3	1.1	1.4	1.7	1.7	1.6	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.7	46.9	53.7	65.4	73.0	77.0	82.2	78.5	73.7	63.4	56.1	51.3	(19)
		MCWB	47.1	44.9	47.9	55.4	61.3	64.5	66.2	66.1	63.9	59.0	54.6	49.9	(20)
	2%	DB	46.5	45.0	48.8	60.4	68.8	72.8	77.4	73.6	68.2	59.9	53.4	49.4	(21)
		MCWB	45.2	43.4	45.3	51.8	59.6	62.2	65.6	63.6	61.3	57.1	52.1	48.0	(22)
	5%	DB	45.0	43.7	46.4	56.4	64.9	68.6	73.9	70.2	65.0	57.8	51.8	48.0	(23)
		MCWB	43.6	42.4	44.0	50.3	57.3	60.9	65.2	62.3	59.9	55.7	50.5	46.8	(24)
	10%	DB	43.6	42.4	44.8	53.2	61.0	64.7	70.2	67.6	62.8	56.1	50.4	46.6	(25)
		MCWB	42.2	41.3	42.7	48.2	55.1	58.6	63.2	61.3	58.7	54.2	49.0	45.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.6	45.5	48.3	56.2	63.6	66.4	69.0	67.9	65.1	60.1	54.9	50.4	(27)
		MCDB	48.2	46.1	52.3	62.2	70.2	74.5	76.4	73.6	69.7	62.3	55.6	51.2	(28)
	2%	WB	45.6	43.9	46.0	52.9	61.0	63.8	67.0	65.6	62.7	58.0	52.2	48.5	(29)
		MCDB	46.3	44.7	47.9	58.2	66.7	70.8	74.3	71.0	67.4	59.3	52.9	49.2	(30)
	5%	WB	44.0	42.7	44.5	50.7	58.2	61.6	65.5	63.8	61.0	56.1	50.9	47.1	(31)
		MCDB	44.8	43.5	46.0	55.4	63.6	67.3	72.4	68.0	64.2	57.4	51.7	47.8	(32)
	10%	WB	42.4	41.5	43.1	48.6	55.6	59.4	63.9	62.4	59.5	54.5	49.2	45.7	(33)
		MCDB	43.4	42.4	44.4	52.5	59.9	63.7	69.7	66.1	62.0	55.8	50.2	46.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	5.9	7.7	10.9	11.8	11.5	12.2	11.3	9.1	7.4	5.9	5.8	(35)
		MCDBR	6.8	6.9	9.3	16.2	17.5	17.7	17.5	15.4	12.5	8.7	6.6	5.9	(36)
	5% WB	MCWBR	7.1	6.4	6.7	9.7	10.5	10.0	8.5	7.6	7.5	7.1	6.7	6.6	(37)
		MCWBR	6.7	6.9	8.9	14.9	16.1	16.2	16.0	13.1	11.6	8.4	6.3	6.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.314	0.336	0.353	0.388	0.378	0.370	0.386	0.389	0.368	0.348	0.324	0.298	(40)
		taud	2.217	2.285	2.336	2.290	2.383	2.428	2.401	2.396	2.439	2.405	2.287	2.198	(41)
	Ebn at Noon		174	224	254	261	273	276	269	259	248	219	169	145	(42)
		Edh at Noon	17	24	30	36	35	34	34	32	27	21	16	13	(43)
(44) All-Sky Solar Radiation	RadAvg		129	308	748	1268	1683	1841	1689	1325	891	440	165	91	(44)
	RadStd		26	51	66	148	158	145	171	98	91	54	30	11	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (32 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	-229	-304	N/A	N/A

Nomenclature: See separate page