

MIDTJYLLANDS AP, Denmark

WMO: 060600

Lat: 56.293N

Lon: 9.114E

Elev: 170

StdP: 14.61

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	18.9	11.0	9.7	17.0	15.1	11.9	21.7	32.9	43.0	28.8	43.4	4.3	20	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	81.4	65.8	77.8	64.3	74.2	62.8	68.0	76.5	66.2	74.5	64.4	71.2	9.7	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.0	93.2	70.5	63.2	87.1	68.9	61.6	82.4	67.3	32.3	76.6	30.9	74.8	29.6	70.8	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	22.1	19.7	7.7	86.5	5.0	2.9	4.1	88.6	1.1	90.4	-1.7	92.0	-5.3	94.1
			7.2	71.3	4.9	2.1	3.7	72.9	0.8	74.1	-2.0	75.3	-5.6	76.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	34.0	34.4	37.9	45.3	52.3	57.6	62.3	62.2	56.2	48.8	41.4	36.1
	DBStd	11.96	7.50	7.08	6.37	6.23	6.02	5.14	5.26	4.98	4.78	5.83	6.26	7.99
	HDD50	2313	498	436	376	167	43	2	0	0	6	90	264	431
	HDD65	6491	963	856	840	591	398	230	121	118	267	502	709	896
	CDD50	1378	0	0	1	26	113	231	380	379	191	53	4	0
	CDD65	82	0	0	0	0	2	9	37	31	3	0	0	0
	CDH74	803	0	0	0	4	37	120	367	259	16	0	0	0
	CDH80	152	0	0	0	0	2	18	81	50	1	0	0	0
Wind	WSAvg	9.5	10.4	10.6	10.6	9.5	9.4	9.6	8.5	8.3	8.8	9.1	9.4	9.6
Precipitation	PrecAvg	32.6	3.0	2.3	2.0	1.8	1.9	2.5	2.7	3.3	3.3	3.7	3.0	3.1
	PrecMax	39.9	4.9	5.1	4.0	3.4	4.2	4.9	5.0	5.6	6.7	8.1	6.5	6.7
	PrecMin	20.4	0.2	0.7	0.2	0.2	0.1	0.2	0.7	0.8	1.2	1.0	1.0	0.8
	PrecStd	4.6	1.3	1.2	1.0	0.9	0.9	1.2	1.1	1.2	1.5	1.6	1.3	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.3	50.3	57.7	71.3	78.4	82.7	86.5	84.6	76.2	65.0	57.2	52.2
		MCWB	47.7	47.8	48.5	57.2	62.7	64.5	67.6	67.0	63.7	59.2	55.3	50.7
	2%	DB	47.0	47.6	52.6	65.6	73.4	77.6	82.1	80.7	71.5	61.1	54.0	50.3
		MCWB	45.7	46.1	46.1	53.3	59.9	63.8	66.2	66.0	61.9	57.4	52.2	49.2
	5%	DB	45.3	45.7	49.1	61.1	68.8	72.8	78.4	76.5	67.4	58.9	51.9	48.2
		MCWB	44.0	44.3	45.0	51.7	57.2	61.2	64.9	64.4	60.2	56.3	50.1	47.0
	10%	DB	43.8	44.1	46.5	56.7	64.5	68.4	74.0	72.1	64.4	57.1	50.0	46.5
		MCWB	42.5	42.6	43.7	49.3	55.2	59.4	63.0	63.2	58.8	54.6	48.5	45.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	48.5	50.5	59.1	65.8	68.6	70.2	70.6	66.5	60.8	55.6	51.5
		MCDB	48.7	49.1	54.9	68.0	75.8	77.6	81.1	78.4	72.7	63.1	56.6	52.3
	2%	WB	46.0	46.2	47.5	54.7	61.7	65.4	68.3	67.6	63.2	58.6	52.7	49.3
		MCDB	46.8	47.1	50.5	62.6	69.8	73.6	77.9	75.2	68.4	60.5	53.9	50.0
	5%	WB	44.2	44.4	45.7	52.4	59.1	62.6	66.3	65.9	61.5	56.7	50.5	47.2
		MCDB	45.0	45.4	48.2	59.2	66.7	70.6	75.3	73.5	65.9	58.4	51.7	48.0
	10%	WB	42.6	42.7	44.0	50.1	56.3	60.3	64.2	64.3	59.9	55.0	48.6	45.5
		MCDB	43.5	43.6	46.0	55.3	62.9	67.0	71.3	70.5	63.6	56.8	49.8	46.3
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.8	12.1	16.1	17.0	15.8	16.6	16.0	13.9	11.3	8.8	8.4
		MCDBR	7.9	8.4	15.6	23.7	24.7	24.1	24.5	22.5	18.2	12.1	8.5	7.6
		MCWBR	8.0	7.3	10.4	13.4	13.4	12.5	11.3	10.0	10.5	9.0	7.8	7.7
	5% WB	MCDBR	7.9	8.0	13.2	20.9	21.3	20.6	21.6	19.1	15.5	10.6	8.4	7.7
MCWBR		8.1	7.4	9.7	12.7	13.0	12.2	11.2	9.9	9.8	8.7	8.2	7.8	
Clear-Sky Solar Irradiance	taub		0.314	0.334	0.355	0.390	0.382	0.376	0.392	0.393	0.370	0.349	0.326	0.300
	taud		2.221	2.278	2.300	2.257	2.326	2.364	2.337	2.345	2.395	2.384	2.291	2.215
	Ebn at Noon		179	227	254	262	272	275	267	258	247	220	174	153
	Edh at Noon		18	25	31	37	37	36	36	34	28	22	16	14
All-Sky Solar Radiation	RadAvg		146	334	761	1265	1659	1785	1637	1297	893	458	180	104
	RadStd		26	47	70	153	158	146	183	104	94	54	29	11

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	-270	N/A	N/A
Regional (34 neighbors)		+0.65	N/A	N/A	N/A	N/A	N/A	-221	-301	N/A	N/A

Nomenclature: See separate page